



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

June 25, 2010

Mr. Gerardo Rios
Chief – Permits Office
U. S. EPA, Region IX
75 Hawthorne Street, Air 3
San Francisco, CA 94105

Dear Mr. Rios:

Subject: City of Hope Medical Center (ID 023194) – Title V Permit Revision

City of Hope Medical Center has proposed to revise their Title V permit by adding an emergency internal combustion engine (A/N 452326) and removing two emergency internal combustion engines, a spray booth and an incinerator (A/N's 180215, C21426, 283149, 027700). This is a hospital facility (SIC 8069) located at 1500 E. Duarte Road, Duarte, CA 91010. This proposed permit revision is considered as a "minor permit revision" to their Title V permit. Attached for your review are the evaluation and permit for the proposed revision.

If you have any questions or need additional information regarding the proposed permit revision, please call Grace Vu at (909) 396-2628.

Very truly yours,

A handwritten signature in black ink, appearing to read 'Brian L. Yeh', is written over a faint, larger version of the same signature.

Brian L. Yeh
Senior Manager
General Commercial and Energy

BLY:GV:Cover Letter_023194

Attachments

FACILITY PERMIT TO OPERATE

**CITY OF HOPE MEDICAL CENTER
1500 E DUARTE RD
DUARTE, CA 91010**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By _____
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	DRAFT	06/08/2010
B	RECLAIM Annual Emission Allocation	DRAFT	06/08/2010
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	DRAFT	06/08/2010
E	Administrative Conditions	DRAFT	06/08/2010
F	RECLAIM Monitoring and Source Testing Requirements	DRAFT	06/08/2010
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	DRAFT	06/08/2010
H	Permit To Construct and Temporary Permit to Operate	DRAFT	06/08/2010
I	Compliance Plans & Schedules	DRAFT	06/08/2010
J	Air Toxics	DRAFT	06/08/2010
K	Title V Administration	DRAFT	06/08/2010
 Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	DRAFT	06/08/2010
B	Rule Emission Limits	DRAFT	06/08/2010

**FACILITY PERMIT TO OPERATE
 CITY OF HOPE MEDICAL CENTER**

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR: CITY OF HOPE MEDICAL CENTER

LEGAL OPERATOR (if different than owner):

EQUIPMENT LOCATION: 1500 E DUARTE RD
 DUARTE, CA 91010-3012

MAILING ADDRESS: 1500 E DUARTE RD
 DUARTE, CA 91010

RESPONSIBLE OFFICIAL: JONATHAN SMITHERS

TITLE: DIRECTOR OF ENGR. & PLANT OPERATIONS

TELEPHONE NUMBER: (626) 359-8111

CONTACT PERSON: EARL STROTMAN

TITLE: LEAD STATIONARY ENGINEER

TELEPHONE NUMBER: (626) 359-8111

INITIAL TITLE V PERMIT ISSUED: July 13, 2005

TITLE V PERMIT EXPIRATION DATE: July 12, 2010

TITLE V	RECLAIM
YES	NOx: NO SOx: NO CYCLE: 0 ZONE: INLAND

FACILITY PERMIT TO OPERATE CITY OF HOPE

Facility Equipment and Requirements (Section D)

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application number	Permit to Operate number	Equipment description
175699	D10962	ETHYLENE OXIDE STERILIZATION HOSPITAL
217251	D36401	I C E (50-500 HP) EM ELEC GEN DIESEL
217252	D22390	I C E (50-500 HP) NON-EM PORT N-RENT GASOLINE
269895	D64727	I C E (>500 HP) EM ELEC GEN DIESEL
269896	D64728	I C E (>500 HP) EM ELEC GEN DIESEL
269898	D64729	I C E (>500 HP) EM ELEC GEN DIESEL
274107	D71056	ETHYLENE OXIDE STERILIZATION HOSPITAL
274108	D71057	ETHYLENE OXIDE STERILIZATION CTL (HOSPITAL)
303977	D91222	I C E (50-500 HP) EM ELEC GEN DIESEL
314936	D98623	I C E (>500 HP) EM ELEC GEN DIESEL
314937	D98624	I C E (>500 HP) EM ELEC GEN DIESEL
314938	D98625	I C E (>500 HP) EM ELEC GEN DIESEL
314939	D98626	I C E (>500 HP) EM ELEC GEN DIESEL
316435	F11044	BOILER (>20-50 MMBTU/HR) COMB GAS-LPG
316436	F11046	BOILER (>20-50 MMBTU/HR) COMB GAS-LPG
316437	F11047	BOILER (>20-50 MMBTU/HR) COMB GAS-LPG
355721	F26612	CHARBROILER - NATURAL GAS
411676	F73865	BOILER (<5 MMBTU/HR) NATURAL GAS
430068	N14408	SERV STAT STORAGE & DISPENSING GASOLINE
452326		I C E (50-500 HP) EM ELEC GEN DIESEL

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.

FACILITY PERMIT TO OPERATE CITY OF HOPE

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGELMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]

2. THE OPERATOR SHALL NOT PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPMV BY WEIGHT AS SUPPLIED BY THE SUPPLIER.
[RULE 431.2]

3. THE OPERATOR SHALL NOT USE OR SELL GASEOUS FUEL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 40 PPMV CALCULATED AS HYDROGEN SULFIDE AVERAGED OVER FOUR HOURS.
[RULE 431.1]

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D10962
A/N 175699

Equipment Description:

STERILIZER, ETHYLENE OXIDE, CASTLE, MODEL NO. 3145, 20" W. X 36" L. X 20" H., WITH A 1/4- H.P. EXHAUST BLOWER.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT MUST NOT BE USED TO PROCESS MORE THAN TWO LOADS IN ANY ONE DAY.
[RULE 1303(b)(2)-OFFSET]
4. A RECORD MUST BE PREPARED, INCLUDING THE NUMBER OF LOADS RUN DAILY TO DEMONSTRATE COMPLIANCE WITH CONDITION NO.3. THE RECORD FORMAT MUST BE APPROVED IN WRITING BY THE DIRECTOR OF ENFORCEMENT OF THE DISTRICT. IT MUST BE RETAINED FOR AT LEAST FIVE YEARS AND MUST BE MADE AVAILABLE FOR REVIEW AT THE REQUEST OF THE DISTRICT.
[RULE 1303(b)(2)-OFFSET]

Emissions And Requirements:

5. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

ETHYLENE OXIDE: RULE 1405(d)
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D36401
A/N 217251

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. NTA855-G2, 6 CYLINDERS, FOUR CYCLE, TURBOCHARGED, AFTERCOOLED, 465 BHP, WITH 1 EXHAUST.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE RETARDED A MINIMUM OF 4° (FOUR DEGREES) RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
4. THE INJECTION IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED AND CERTIFIED, AT A MINIMUM, ONCE EVERY FIVE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS SHALL BE PERFORMED BY A QUALIFIED MECHANIC AND ACCORDING TO THE ENGINE MANUFACTURER'S PROCEDURES.
[RULE 1303(a)(1)-BACT]
5. THE ENGINE IS LIMITED TO AN OPERATING SCHEDULE OF NO MORE THAN 11.5 HOURS IN ANY ONE DAY AND NO MORE THAN 125 HOURS (CUMULATIVE) IN ANY ONE CALENDAR YEAR UNLESS ADDITIONAL HOURS ARE OTHERWISE AUTHORIZED BY THE EXECUTIVE OFFICER. THIS EQUIPMENT MAY ONLY OPERATE DURING MAINTENANCE TESTING, PERFORMANCE TESTING, OR IN CASES OF EMERGENCY.
[RULE 1304(a)-MODELING AND OFFSET]
6. THIS ENGINE SHALL NOT OPERATE MORE THAN 125 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. AN OPERATIONAL NON-RESETTING TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

FACILITY PERMIT TO OPERATE CITY OF HOPE

8. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

9. THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.

[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

10. THIS ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.

[RULE 1470]

Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D22390
A/N 217252

Equipment Description:

INTERNAL COMBUSTION ENGINE, FORD, PORTABLE, GASOLINE-FUELED, MODEL NO. F10B-435, SERIAL NO.6815, 8 CYLINDERS, FOUR CYCLE, NATURALLY ASPIRATED, 62 BHP, WITH 1 EXHAUST. -

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]

Periodic Monitoring:

4. THE OPERATOR SHALL MONITOR AND MAINTAIN ENGINE OPERATING LOG AS REQUIRED BY RULE 1110.2 FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST.
[RULES 1110.2, 3004(a)(4)]

Emissions And Requirements:

5. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 176 PPM, RULE 1110.2
NOx: 80 PPM, RULE 1110.2
VOC: 240 PPM, RULE 1110.2
PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D64727
A/N 269895

Equipment Description:

INTERNAL COMBUSTION ENGINE NO.1, CATERPILLAR, MODEL NO. 3516, SERIAL NO. 25Z00808, FOUR CYCLE, LEAN BURN, TURBOCHARGED, AFTERCOOLED, DIESEL-FUELED, 2153 HP, DRIVING A 1500-KW EMERGENCY GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN OPERATIONAL NON-RESETTING TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS

FACILITY PERMIT TO OPERATE CITY OF HOPE

TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.

[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.

[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D64728
A/N 269896

Equipment Description:

INTERNAL COMBUSTION ENGINE NO.2 CATERPILLAR, MODEL NO. 3516, SERIAL NO. 25Z00807, FOUR CYCLE, LEAN BURN, TURBOCHARGED, AFTERCOOLED, DIESEL-FUELED, 2153 HP, DRIVING A 1500-KW EMERGENCY GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN OPERATIONAL NON-RESETTING TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS

FACILITY PERMIT TO OPERATE CITY OF HOPE

TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.

[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.

[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D64729
A/N 269898

Equipment Description:

INTERNAL COMBUSTION ENGINE NO.3, CATERPILLAR, MODEL NO. 3516, SERIAL NO. 25Z00809, FOUR CYCLE, LEAN BURN, TURBOCHARGED, AFTERCOOLED, DIESEL-FUELED, 2153 HP, DRIVING A 1500-KW EMERGENCY GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN OPERATIONAL NON-RESETTING TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470 []
7. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS

FACILITY PERMIT TO OPERATE CITY OF HOPE

TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.

[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

**FACILITY PERMIT TO OPERATE
CITY OF HOPE**

PERMIT TO OPERATE

**Permit No. D71056
A/N 274107**

Equipment Description:

STERILIZER/AERATOR, ETHYLENE OXIDE GAS, AMSCO, MODEL NO. EAGLE 3028, SERIAL NUMBER 0109592-02, 1'-8" W. X 3'-2" L. X 1'-8" H; (INTERNAL DIMENSIONS), STEAM HEATED, WITH A 1 1/2 H.P. EXHAUST BLOWER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE MAXIMUM NUMBER OF LOADS PROCESSED IN THIS EQUIPMENT SHALL NOT EXCEED TWO IN ANY ONE DAY AND TWENTY-FIVE IN ANY CALENDAR MONTH.
[RULE 1303(b)(2)-OFFSET]
4. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE STERILIZER IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND HAS BEEN ISSUED A PERMIT TO CONSTRUCT BY THE EXECUTIVE OFFICER.
[RULE 1405]
5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITIONS 3. THE RECORDS SHALL BE KEPT FOR A MINIMUM OF FIVE YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET]

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
ETHYLENE OXIDE: RULE 1405(d)
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D71057
A/N 274108

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. CATALYTIC OXIDIZER, DONALDSON, 1'-8" W. x 3'-2" L. x 1'-8" H; (EXTERNAL DIMENSIONS), STEAM HEATED, WITH A VACUUM PUMP AND A 1/2 H.P. EXHAUST BLOWER.
2. EXHAUST SYSTEM WITH A 0.6 H.P. BLOWER AND A 0.75 H.P. VACUUM PUMP VENTING THE STERILIZER/AERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE TEMPERATURE OF THE EXHAUST FROM THE CATALYST BED SHALL BE MAINTAINED BETWEEN 280 AND 550 DEGREES FAHRENHEIT AS INDICATED BY A PROPER TEMPERATURE GAUGE AND/OR RECORDER, WHEN THE ETHYLENE OXIDE STERILIZER/AERATOR IT SERVES IS IN OPERATION.
[RULE 1405]
4. THIS EQUIPMENT SHALL BE SUBJECT TO ANNUAL SOURCE TEST REQUIREMENT AS PER DISTRICT RULE 1405(d) (6).
[RULE 1405]
5. RECORDS SHALL BE MAINTAINED TO SHOW COMPLIANCE WITH CONDITION NUMBERS 3 AND THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1405]

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
ETHYLENE OXIDE: RULE 1405(d)

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D91222
A/N 303977

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, MODEL NO. 3306 ATAAC, 377 BHP, DIESEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. OPERATION OF THIS ENGINE FOR MAINTENANCE TESTING SHALL NOT EXCEED 0.5 HOUR A WEEK.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN OPERATIONAL NON-RESETTING TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS

FACILITY PERMIT TO OPERATE CITY OF HOPE

TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.

[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D98623
A/N 314936

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, 16 CYLINDERS, TURBOCHARGED, AFTERCOOLED, MODEL NO. 3516 DITA (2000 KW), 2847 BHP, DIESEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 64 HOURS IN ANY ONE YEAR.
[RULE 1304 (a)-MODELING AND OFFSET]
4. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO PRODUCTION TIMING AS ESTABLISHED BY CATERPILLAR IN PRODUCT NEWS BULLETIN REQUIREMENTS TO COMPLY WITH SCAQMD CERTIFIED EQUIPMENT.
[RULE 1303(a)(1)-BACT]
5. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. THIS ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

FACILITY PERMIT TO OPERATE CITY OF HOPE

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D98624
A/N 314937

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, 16 CYLINDERS, TURBOCHARGED, AFTERCOOLED, MODEL NO. 3516 DITA (2000 KW), SERIAL NO. 4XF00599, 2847 BHP, DIESEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 64 HOURS IN ANY ONE YEAR.
[RULE 1304 (a)-MODELING AND OFFSET]
4. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO PRODUCTION TIMING AS ESTABLISHED BY CATERPILLAR IN PRODUCT NEWS BULLETIN REQUIREMENTS TO COMPLY WITH SCAQMD CERTIFIED EQUIPMENT.
[RULE 1303(a)(1)-BACT]
5. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. THIS ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

FACILITY PERMIT TO OPERATE CITY OF HOPE

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS-
PM: RULE 1470

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D98625
A/N 314938

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, 16 CYLINDERS, TURBOCHARGED, AFTERCOOLED MODEL NO. 3516 DITA (2000 KW), SERIAL NO. 4XF00600, 2847 BHP, DIESEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 64 HOURS IN ANY ONE YEAR.
[RULE 1304 (a)-MODELING AND OFFSET]
4. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO PRODUCTION TIMING AS ESTABLISHED BY CATERPILLAR IN PRODUCT NEWS BULLETIN REQUIREMENTS TO COMPLY WITH SCAQMD CERTIFIED EQUIPMENT.
[RULE 1303(a)(1)-BACT]
5. AN OPERATIONAL NON-RESETTING TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. THIS ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

FACILITY PERMIT TO OPERATE CITY OF HOPE

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. D98626
A/N 314939

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, 16 CYLINDERS, TURBOCHARGED, AFTERCOOLED, MODEL NO. 3516 DITA (2000 KW), 2847 BHP, DIESEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 64 HOURS IN ANY ONE YEAR.
[RULE 1304 (a)-MODELING AND OFFSET]
4. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO PRODUCTION TIMING AS ESTABLISHED BY CATERPILLAR IN PRODUCT NEWS BULLETIN REQUIREMENTS TO COMPLY WITH SCAQMD CERTIFIED EQUIPMENT.
[RULE 1303(a)(1)-BACT]
5. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. THIS ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

FACILITY PERMIT TO OPERATE CITY OF HOPE

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. F11044
A/N 316435

Equipment Description:

BOILER #1, CLEAVER BROOKS, MODEL NO. CBI700-600-150ST, NATURAL GAS OR LIQUEFIED PETROLEUM GAS (LPG) FIRED, RATED AT 25,106,250 BTU PER HOUR, WITH ONE CLEAVER BROOKS INTEGRAL LOW-NOX BURNER AND AN INDUCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS OR LIQUEFIED PETROLEUM GAS (LPG) ONLY.
[RULE 1303(a)(1)-BACT]
4. BOILER EMISSIONS SHALL NOT EXCEED 30 PPM FOR OXIDES OF NITROGEN (NO_x), AND 400 PPM OF CARBON MONOXIDE (CO), MEASURED BY VOLUME, ON A DRY BASIS, AT 3% O₂.
[RULE 1146, RULE 1303(a)(1)-BACT]
5. OPERATING RECORDS SHALL BE MAINTAINED TO RECORD THE DAILY USAGE OF NATURAL GAS OR LPG WHENEVER THE BOILER OPERATES. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]

Periodic Monitoring:

6. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

FACILITY PERMIT TO OPERATE CITY OF HOPE

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

[RULE 3004 (a)(4)]

8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004 (a)(4)]

9. IF ANNUAL FUEL OIL USAGE EXCEEDS 2,000,000 GALLONS IN ANY ONE YEAR, THEN OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT(S) BY CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 5.2. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL

FACILITY PERMIT TO OPERATE CITY OF HOPE

CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 409 LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 409 LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

10. FOR UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS, OR GREATER THAN 336 HOURS OF OPERATION BUT NOT EXCEEDING 2,000,000 GALLONS IN ANY ONE YEAR, THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOX: 30 PPMV, RULE 1146, RULE 1303
CO: 400 PPMV, RULE 1146, RULE 1303
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. F11046
A/N 316436

Equipment Description:

BOILER #2, CLEAVER BROOKS, MODEL NO. CBI-700-600-150ST, NATURAL GAS OR LIQUEFIED PETROLEUM GAS (LPG) FIRED, RATED AT 25,106,250 BTU PER HOUR, WITH ONE CLEAVER BROOKS INTEGRAL LOW-NOX BURNER AND AN INDUCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS OR LIQUEFIED PETROLEUM GAS (LPG) ONLY.
[RULE 1303(a)(1)-BACT]
4. BOILER EMISSIONS SHALL NOT EXCEED 30 PPM FOR OXIDES OF NITROGEN (NO_x), AND 400 PPM OF CARBON MONOXIDE (CO), MEASURED BY VOLUME, ON A DRY BASIS, AT 3% O₂.
[RULE 1146, RULE 1303(a)(1)-BACT]
5. OPERATING RECORDS SHALL BE MAINTAINED TO RECORD THE DAILY USAGE OF NATURAL GAS OR LPG WHENEVER THE BOILER OPERATES. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]

Periodic Monitoring:

6. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE

FACILITY PERMIT TO OPERATE CITY OF HOPE

TIME PERIOD.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

[RULE 3004 (a)(4)]

8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004 (a)(4)]

9. IF ANNUAL FUEL OIL USAGE EXCEEDS 2,000,000 GALLONS IN ANY ONE YEAR, THEN OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT(S) BY CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD

FACILITY PERMIT TO OPERATE CITY OF HOPE

5.2 . THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 409 LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 409 LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

10. FOR UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS, OR GREATER THAN 336 HOURS OF OPERATION BUT NOT EXCEEDING 2,000,000 GALLONS IN ANY ONE YEAR, THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOX: 30 PPMV, RULE 1146, RULE 1303
CO: 400 PPMV, RULE 1146, RULE 1303
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. F11047
A/N 316437

Equipment Description:

BOILER #3, CLEAVER BROOKS, MODEL NO. CBI-700-600-150ST, NATURAL GAS OR LIQUEFIED PETROLEUM GAS (LPG) FIRED, RATED AT 25,106,250 BTU PER HOUR, WITH ONE CLEAVER BROOKS INTEGRAL LOW.-NOX BURNER AND AN INDUCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS OR LIQUEFIED PETROLEUM GAS (LPG) ONLY.
[RULE 1303(a)(1)-BACT]
4. BOILER EMISSIONS SHALL NOT EXCEED 30 PPM FOR OXIDES OF NITROGEN (NO_x), AND 400 PPM OF CARBON MONOXIDE (CO), MEASURED BY VOLUME, ON A DRY BASIS, AT 3% O₂.
[RULE 1146, RULE 1303(a)(1)-BACT]
5. OPERATING RECORDS SHALL BE MAINTAINED TO RECORD THE DAILY USAGE OF NATURAL GAS OR LPG WHENEVER THE BOILER OPERATES. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]

Periodic Monitoring:

6. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE

FACILITY PERMIT TO OPERATE CITY OF HOPE

TIME PERIOD.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

[RULE 3004 (a)(4)]

8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004 (a)(4)]

9. IF ANNUAL FUEL OIL USAGE EXCEEDS 2,000,000 GALLONS IN ANY ONE YEAR, THEN OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT(S) BY CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD

FACILITY PERMIT TO OPERATE CITY OF HOPE

5.2 . THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 409 LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 409 LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

10. FOR UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS, OR GREATER THAN 336 HOURS OF OPERATION BUT NOT EXCEEDING 2,000,000 GALLONS IN ANY ONE YEAR, THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOX: 30 PPMV, RULE 1146, RULE 1303
CO: 400 PPMV, RULE 1146, RULE 1303
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. F26612
A/N 355721

Equipment Description:

CHARBROILER, MAGIKITCH'N, SERIAL NO. 23306, 3'-0" W. X 2'-6" L. X 3'-6" H., RATED AT 240,000 BTU PER HOUR, WITH SIX NATURAL GAS BURNERS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE FIRED ON NATURAL GAS ONLY.
[RULE 1303(a)(1)-BACT]

Periodic Monitoring:

4. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
 - A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT;
OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;

FACILITY PERMIT TO OPERATE CITY OF HOPE

C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND

D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]

Emissions And Requirements:

5. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407

PM: 0.1 GR/SCF, RULE 409

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. F73865
A/N 411676

Equipment Description:

BOILER, MIURA, WATER TUBE TYPE, MODEL NO. LX-100, SERIAL NO. 46S47818, RATED AT 4,200,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH ONE MIURA LOW NOX BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL COMPLY WITH THE REQUIREMENTS OF RULE 1146.1.
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO₂, AND NO MORE THAN 100 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1303(a)(1)-BACT]
5. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTING ACCORDING TO THE CONDITIONS IN THIS PERMIT.
[RULE 217]
6. SOURCE TESTING SHALL BE CONDUCTED WITHIN 180 DAYS AFTER INITIAL START-UP OF THIS EQUIPMENT OR WITHIN 60 DAYS AFTER RECEIPT OF THIS PERMIT, UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.
[RULE 217]
7. SOURCE TESTING SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH NOX AND CO EMISSION LIMITS SPECIFIED IN CONDITION NO. 4.
[RULE 217, RULE 1303(a)(1)-BACT]
8. SOURCE TESTING SHALL BE CONDUCTED IN ACCORDANCE WITH SCAQMD METHOD 100.1. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS OPERATING AT MAXIMUM, MINIMUM, AND AVERAGE FIRING RATES.
[RULE 217]

FACILITY PERMIT TO OPERATE CITY OF HOPE

9. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 14 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT.
[RULE 217]

10. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765), WITHIN 45 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT, AND
- V. THE FUEL FLOW RATE.

[RULE 217]

11. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

[RULE 217]

12. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217.

[RULE 217]

Periodic Monitoring:

13. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) BY CONDUCTING A TEST AT LEAST ONCE EVERY FIVE YEARS USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD OR, IF NOT AVAILABLE, A NON- AQMD APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

[RULE 3004 (a)(4)]

14. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) BY CONDUCTING A TEST AT LEAST ONCE EVERY FIVE YEARS USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD OR, IF NOT AVAILABLE, A NON-AQMD APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1303 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

[RULE 3004 (a)(4)]

FACILITY PERMIT TO OPERATE CITY OF HOPE

Emissions And Requirements:

15. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1
NOx: 12 PPMV, RULE 1303
CO: 100 PPMV, RULE 1303
CO: 400 PPMV, RULE 1146.1
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No. N14408
A/N 430068

Equipment Description:

Fuel Storage and Dispensing Facility Consisting of

1. 1 - GASOLINE ABOVEGROUND STORAGE TANK, CONTAINMENT SOLUTIONS HOOVERVAULT (G-70-194), RECTANGULAR, 11'-10" L X 6'-11" W X 4'-9" H, 2,000 GALLON CAPACITY, CONCRETE INSULATION, EQUIPPED WITH A PRESSURE/VACUUM RELIEF VALVE, AND A SUBMERGED FILL TUBE
2. 1 - GASOLINE NOZZLE DISPENSING 1 PRODUCT ON A TANK TOP MOUNTED DISPENSER, EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM, BALANCE RETRACTOR (G-70-52-AM)

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. ALL PERMIT CONDITIONS APPLICABLE TO THE EQUIPMENT DESCRIBED IN THE PREVIOUS PERMIT TO OPERATE M99223 SHALL REMAIN IN EFFECT UNTIL THE NEW OR MODIFIED EQUIPMENT IS CONSTRUCTED AND OPERATED AS DESCRIBED IN THIS NEW PERMIT. THIS PERMIT TO CONSTRUCT/OPERATE SHALL BECOME INVALID IF THE MODIFICATION AS DESCRIBED IN THE EQUIPMENT DESCRIPTION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE.
[RULE 203]
4. EXCEPT FOR DIESEL TRANSFERS, PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS.
[RULE 461]
5. EXCEPT FOR DIESEL TRANSFERS, PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES, AS DEFINED IN RULE 461.
[RULE 461]
6. ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS.
[RULE 461, RULE 1303 (a)(1)-BACT]

**FACILITY PERMIT TO OPERATE
 CITY OF HOPE**

7. THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED, OPERATED, AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE SYSTEM INCLUDING NOZZLE, VAPOR HOSE, SWIVELS, AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURES DESCRIBED BY THE CALIFORNIA AIR RESOURCES BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED.

NITROGEN FLOWRATES (CFH)	DYNAMIC BACK PRESSURE (INCHES OF WATER)
60	0.35
80	0.62

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP-201 4, METHODOLOGY I RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TESTS

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R46ITESTING@AQMD GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 96-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR, THE NAME OF THE CONTRACTOR, THE LOCATION OF THE FACILITY, AND THE SCHEDULED START AND COMPLETION DATES OF THE DYNAMIC BACK PRESSURE TESTS.

[RULE 461]

8. A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES, ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARE TEST PROCEDURE METHOD TP-201 3 RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R46ITESTING@AQMD GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR, THE NAME OF THE CONTRACTOR, THE LOCATION OF THE FACILITY, AND THE SCHEDULED START AND COMPLETION DATES OF THE STATIC PRESSURE LEAK DECAY TEST.

[RULE 461]

9. IF THE CARB EXECUTIVE ORDER REQUIRES THE INSTALLATION OF A LIQUID REMOVAL DEVICE, A LIQUID REMOVAL PATE TEST SHALL BE CONDUCTED TO DEMONSTRATE THE REMOVAL OF GASOLINE FROM THE VAPOR PASSAGE OF THE COAXIAL HOSE THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARE TEST PROCEDURE METHOD TP-201 6 RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R46ITESTING@AQMD GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR, THE NAME

FACILITY PERMIT TO OPERATE CITY OF HOPE

OF THE CONTRACTOR, THE LOCATION OF THE FACILITY, AND THE SCHEDULED START AND COMPLETION DATES OF THE LIQUID RMOVAL RATE TEST.

[RULE 461]

10. THE TESTING FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT.

[RULE 461]

11. ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

[RULE 461]

Periodic Monitoring:

12. THE OPERATOR SHALL HAVE A PERSON THAT HAS BEEN TRAINED IN ACCORDANCE WITH RULE 461(C)(6) CONDUCT A SEMI-ANNUAL INSPECTION OF THE GASOLINE TRANSFER AND DISPENSING EQUIPMENT. THE FIRST INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT C, THE SECOND INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT D, AND THE SUBSEQUENT INSPECTIONS SHALL ALTERNATE PROTOCOLS. THE OPERATOR SHALL KEEP RECORDS OF THE INSPECTION AND THE REPAIRS IN ACCORDANCE TO RULE 461 AND SECTION K OF THIS PERMIT.

[RULE 3004 (a)(4)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 461

FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE

Permit No.
A/N 452326

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3304BDITA, SERIAL NO. 9HK00371, TURBOCHARGED, AFTERCOOLED, FOUR CYLINDERS, 167 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 431.2 AND RULE 1470.
[RULE 1470, RULE 431.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING AND NO MORE THAN 4.2 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. OPERATING BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN OPERATIONAL NON-RESETTING ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

FACILITY PERMIT TO OPERATE CITY OF HOPE

7. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:

- A. EMERGENCY USE.
- B. MAINTENANCE AND TESTING.
- C. OTHER (DESCRIBE THE REASON FOR OPERATING).

IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.

[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:

- A. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
- B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF THREE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.

[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE CITY OF HOPE

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

[RULE 3004 (a) (4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE CITY OF HOPE

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, BOILER, > 400,000 BTU/HR BUT < 2 MMBTU/HR.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409
NOx: 30 PPMV, RULE 1146.2
CO: 400 PPMV, RULE 1146.2
CO: 2000 PPMV, RULE 407

FACILITY PERMIT TO OPERATE CITY OF HOPE

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, HAND WIPING OPERATION.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

SECTION K: TITLE V Administration

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
- (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
 - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
 - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
 - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
 - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]

10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]

12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]

13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
- (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

SECTION K: TITLE V Administration EMERGENCY PROVISIONS

17. An emergency¹ constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

¹ "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

SECTION K: TITLE V Administration RECORDKEEPING PROVISIONS

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
 - (B) The date(s) analyses were performed;
 - (C) The company or entity that performed the analyses;
 - (D) The analytical techniques or methods used;
 - (E) The results of such analyses; and
 - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]
21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:
- (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

SECTION K: TITLE V Administration

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
 - (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
 - (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

SECTION K: TITLE V Administration

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn:
Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

- 25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

PERIODIC MONITORING

- 26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations:

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 109	5-2-2003	Federally enforceable
RULE 1107	1-6-2006	Non federally enforceable
RULE 1107	11-9-2001	Federally enforceable
RULE 1110.2	2-1-2008	Non federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	7-13-2007	Non federally enforceable
RULE 1136	6-14-1996	Federally enforceable
RULE 1146	11-17-2000	Federally enforceable
RULE 1146	9-5-2008	Non federally enforceable
RULE 1146.1	5-13-1994	Federally enforceable
RULE 1146.1	9-5-2008	Non federally enforceable
RULE 1151	12-11-1998	Federally enforceable
RULE 1151	12-2-2005	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	2-1-2008	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and Offset Exemption	6-14-1996	Federally enforceable
RULE 1401	3-4-2005	Non federally enforceable
RULE 1405	1-4-1991	Non federally enforceable
RULE 1406	7-8-1994	Non federally enforceable

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1470	6-1-2007	Non federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 3004(a)(4)-Periodic Monitoring	12-12-1997	Federally enforceable
RULE 401	11-9-2001	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 431.1	6-12-1998	Federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 442	12-15-2000	Federally enforceable
RULE 461	6-3-2005	Federally enforceable
RULE 461, Bellowsless Conditions	3-7-2008	Non federally enforceable
RULE 473	5-7-1976	Non federally enforceable
RULE 481	1-11-2002	Federally enforceable

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 01-06-2006]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS								
Less Water and Less Exempt Compounds								
Effective Dates								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 01-06-2006]

VOC LIMITS								
Less Water and Less Exempt Compounds								
Effective Dates, cont.								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 01-06-2006]

- (2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 11-09-2001]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 11-09-2001]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS								
Less Water and Less Exempt Compounds								
Effective Dates								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 11-09-2001]

VOC LIMITS								
Less Water and Less Exempt Compounds								
Effective Dates, cont.								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Cur rent	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5

- (2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-08-1996]

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

TABLE OF STANDARDS

VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water And Less Exempt Compounds

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior Coatings	350	450		350			
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250				100		50
Graphic Arts (Sign) Coatings	500						

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-08-1996]

Industrial Maintenance						
Primers and Topcoats						
Alkyds	420					
Catalyzed Epoxy	420					
Bituminous Coatings	420					
Materials						
Inorganic Polymers	420					
Vinyl Chloride Polymers	420					
Chlorinated Rubber	420					
Acrylic Polymers	420					
Urethane Polymers	420					
Silicones	420					
Unique Vehicles	420					
Japans/Faux Finishing	350	700		350		
Coatings						
Magnesite Cement Coatings	600			450		
Mastic Coatings	300					
Metallic Pigmented Coatings	500					
Multi-Color Coatings	420		250			
Pigmented Lacquer	680		550			275
Pre-Treatment Wash Primers	780					
Primers, Sealers, and	350					
Undercoaters						
Quick-Dry Enamels	400					
Roof Coatings	300					
Shellac						
Clear	730					
Pigmented	550					
Stains	350					
Swimming Pool Coatings						
Repair	650					
Other	340					
Traffic Coatings	250		150			
Waterproofing Sealers	400					
Wood Preservatives						
Below-Ground	350					
Other	350					

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

TABLE OF STANDARDS (cont.)

VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007]

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings, except anti-graffiti coatings, for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007] TABLE OF STANDARDS VOC LIMITS

**Grams of VOC Per Liter of Coating,
 Less Water and Less Exempt Compounds**

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350							
Clear Wood Finishes	350					275		
Varnish	350					275		
Sanding Sealers	350					275		
Lacquer	680	550			275			
Clear Brushing Lacquer	680				275			
Concrete-Curing Compounds	350						100	
Concrete-Curing Compounds For Roadways and Bridges**	350							
Dry-Fog Coatings	400						150	
Fire-Proofing Exterior Coatings	450	350						
Fire-Retardant Coatings***								
Clear	650							
Pigmented	350							
Flats	250	100						50
Floor Coatings	420		100			50		
Graphic Arts (Sign) Coatings	500							
Industrial Maintenance (IM) Coatings	420			250		100		
High Temperature IM Coatings			420					
Zinc-Rich IM Primers	420		340			100		
Japans/Faux Finishing Coatings	700	350						
Magnesite Cement Coatings	600	450						
Mastic Coatings	300							
Metallic Pigmented Coatings	500							
Multi-Color Coatings	420	250						
Nonflat Coatings	250		150			50		



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER


APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007]

COATING CATEGORY	Ceiling Limit	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Nonflat High Gloss	250		150				50	
Pigmented Lacquer	680	550			275			
Pre-Treatment Wash Primers	780		420					
Primers, Sealers, and Undercoaters	350		200			100		
Quick-Dry Enamels	400		250			150	50	
Quick-Dry Primers, Sealers, and Undercoaters	350		200			100		
Recycled Coatings			250					
Roof Coatings	300		250		50			
Roof Coatings, Aluminum	500				100			
Roof Primers, Bituminous	350		350					
Rust Preventative Coatings	420		400			100		
Shellac								
Clear	730							
Pigmented	550							
Specialty Primers	350					250	100	
Stains	350		250				100	
Stains, Interior	250							
Swimming Pool Coatings								
Repair	650		340					
Other	340							
Traffic Coatings	250	150					100	
Waterproofing Sealers	400		250			100		
Waterproofing Concrete/Masonry Sealers	400					100		
Wood Preservatives								
Below-Ground	350							
Other	350							

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.

** Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

*** The Fire-Retardant Coating category will be eliminated on January 1, 2007 and subsumed by the coating category for which they are formulated.



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS

[RULE 1113 07-13-2007]

TABLE OF STANDARDS (cont.)

VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1136 06-14-1996]

Except as otherwise provided in Rule 1136

- (a) The operator shall not apply any coating to a wood product which has a VOC content, including any VOC-containing material added to the original coating supplied by the manufacturer, which exceeds the applicable limit specified below:

(1)


VOC LIMITS

Grams Per Liter (lb/gal) of Coating, [lbs VOC/lb of solids],
Less Water and Less Exempt Compounds

<u>COATING</u>	<u>Current Limit</u>		<u>On and After</u>
	<u>I</u>	<u>or</u>	<u>7/1/2005</u>
	<u>II</u>		
Clear Sealers	550 (4.6) [1.39]	680 (5.7) [3.36]	275 (2.3) [0.36]
Clear Topcoat	550 (4.6) [1.37]	275 (2.3) [0.35]	275 (2.3) [0.35]
Pigmented Primers, Sealers & Undercoats	550 (4.6) [1.06]	600 (5.0) [1.08]	275 (2.3) [0.21]
Pigmented Topcoats	550 (4.6) [1.10]	275 (2.3) [0.25]	275 (2.3) [0.25]

The operator shall use coatings on a wood product that comply with either all VOC limits in column I or all VOC limits in column II. The operator that applies a primer, sealer or undercoat, but not a topcoat, to a wood product, shall be subject to column I for that wood product.

- (2) Notwithstanding the requirements of clause (a)(1), an operator that applies a topcoat and a primer, sealer or undercoat to a shutter may, until July 1, 2005, choose to comply with the VOC limits specified below for that shutter:



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1136 06-14-1996]

VOC LIMITS

Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],
Less Water and Less Exempt Compounds

COATING

Clear Sealers	275 (2.3) [0.36]
Clear Topcoat	680 (5.7) [2.99]
Pigmented Primers, Sealers & Undercoats	275 (2.3) [0.33]
Pigmented Topcoats	600 (5.0) [1.38]

(3)

VOC LIMITS


Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],
Less Water and Less Exempt Compounds

<u>COATING</u>	<u>Current Limit</u>	<u>On and After 7/1/2005</u>
Barrier Coat - Plastic Components	760 (6.3) [3.9]	275 (2.3) [0.28]
Composite Wood Edge Filler	550 (4.6) [1.15]	275 (2.3) [0.31]
Extreme Performance Coatings	420 (3.5) [0.51]	275 (2.3) [0.33]
Fillers	500 (4.2) [0.66]	275 (2.3) [0.18]
High-Solid Stains	550 (4.6) [1.23]	350 (2.9) [0.42]
Inks	500 (4.2) [0.96]	500 (4.2) [0.96]
Mold-Seal Coatings	750 (6.3) [4.2]	750 (6.3) [4.2]
Multi-Colored Coatings	685 (5.7) [2.6]	275 (2.3) [0.33]

VOC LIMITS

Grams Per Liter (lb/gal) of Material

<u>COATING</u>	<u>Current Limit</u>	<u>On and After 7/1/2005</u>
Low-Solids Barrier Coat - Plastic Components	760 (6.3)	120 (1.0)
Low-Solid Stains, Toners, and Washcoats	480 (4.0)	120 (1.0)



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1136 06-14-1996]

Any coating subject to this rule that meets any of the three VOC limit formats (grams per liter, lb/gal, or lbs VOC/lb of solids) is in compliance with this subparagraph.

- (4) The VOC limit for japan coatings is 700 grams per liter of coatings, less water and exempt compounds, as applied.
- (b) A person shall not use a stripper on wood products unless:
- (1) it contains less than 350 grams of VOC per liter of material; or
 - (2) the VOC composite vapor pressure is 2 mm Hg (0.04 psia) or less at 20°C (68°F).

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1151 12-11-1998]

Except as otherwise provided in Rule 1151

(1) VOC Content of Coatings

A person shall not apply a coating to Group I vehicles and equipment, and Group II vehicles, or their parts and components, which has a VOC content which exceeds the limits contained in subparagraphs (1)(A) and (1)(B). Compliance with the VOC limits shall be based on VOC content, including any VOC material added to the original coating supplied by the manufacturer, less water and exempt compounds, as applied to the vehicle, mobile equipment, or parts and components.

(A) Group I Vehicles and Equipment


The operator who applies coatings to Group I vehicles and equipment, or their parts or components, shall not apply a coating which has a VOC content in excess of the limits in Table 1.

TABLE 1

VOC LIMITS
 Grams Per Liter of Coating,
Less Water and Exempt Compounds

<u>COATING</u>	<u>On and After December 12, 1998</u>	
	<u>g/L</u>	<u>lb/gal</u>
Pretreatment	780	6.5
Primer/Primer Surfacer/ Primer Sealer	250	2.1
Topcoats		
General	340	2.8
Metallic/Iridescent	340*	2.8*
Multi-Colored	685	5.7
Multistage	340*	2.8*
Specialty Coating	840	7.0

*The VOC limits for Metallic/Iridescent and Multistage topcoats for spot repairs on Group I vehicles and mobil equipment will be 3.5 lb/gal (less water and exempt compounds).



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1151 12-11-1998]

(B) Group II Vehicles

The operator who applies coatings to Group II vehicles, or their parts or components, shall not apply a coating which has a VOC content in excess of the limits in Table 2.

TABLE 2

COATING	VOC Limits					
	Grams Per Liter of Coating, Less Water and Exempt Compounds					
	On and After December 12, 1998		On and After July 1, 1999		On and After October 1, 1999	
	<u>g/L</u>	<u>lb/gal</u>	<u>g/L</u>	<u>lb/gal</u>	<u>g/L</u>	<u>lb/gal</u>
Pretreatment	780	6.5	780	6.5	780	6.5
Primer/Primer Surfacer	250	2.1	250	2.1	250	2.1
Primer Sealer	340	2.8	340	2.8	340	2.8
Topcoats						
General	420	3.5	420	3.5	420	3.5
Metallic/Iridescent	420	3.5	420	3.5	420	3.5
Multi-Colored	685	5.7	685	5.7	685	5.7
Multistage System						
≥ 2 gal/day ¹	540	4.5	420 ¹	3.5	420	3.5
< 2 gal/day ²	540	4.5	540 ²	4.5	420	3.5
Multi-Colored Multistage	420	3.5	420	3.5	420	3.5
Specialty Coating	840	7.0	840	7.0	840	7.0

¹ On and after July 1, 1999, any person who uses two gallons or more of combined basecoat and clearcoat, as applied, on any given day shall comply with the 420 g/L (3.5 lb/gal) limit.

² Any person who uses less than two gallons of combined basecoat and clearcoat, as applied, on each day up to September 30, 1999 shall comply with the 3.5 lb/gal limit on and after October 1, 1999.

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1151 12-11-1998]

(2) Exempt Compounds

The operator shall not apply a coating which contains any Group II exempt compounds as defined in Rule 102 except for methylene chloride; carbon tetrachloride; perchloroethylene; or cyclic, branched, or linear, completely methylated siloxanes (VMS).

(3) Carcinogenic Materials

The operator shall not apply the coatings in which cadmium or hexavalent chromium was introduced as a pigment or as an agent to impart any property or characteristic to the coatings during manufacturing, distribution, or use of the applicable coatings.

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1151 12-02-2005]

The following limits of this rule shall sunset on June 30, 2008, and the limits specified in Appendix A shall become effective on July 1, 2008.

Except as otherwise provided in Rule 1151

(1) VOC Content of Coatings

A person shall not apply a coating to Group I vehicles and equipment, and Group II vehicles, or their parts and components, which has a VOC content which exceeds the limits contained in subparagraphs (1)(A) and (1)(B). Compliance with the VOC limits shall be based on VOC content, including any VOC material added to the original coating supplied by the manufacturer, less water and exempt compounds, as applied to the vehicle, mobile equipment, or parts and components.

(A) Group I Vehicles and Equipment

A person who applies coatings to Group I vehicles and equipment, or their parts or components, shall not apply a coating which has a VOC content in excess of the limits in Table 1.

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1151 12-02-2005]

TABLE 1

<u>COATING</u>	VOC LIMITS			of Coating,
	Grams Per Liter			
	<u>Less Water and Exempt Compounds</u>			
	On	and	After	
	<u>December 12, 1998</u>			
	<u>g/L</u>		<u>lb/gal</u>	
Pretreatment	780		6.5	
Primer/Primer Primer Sealer	250	Surfacer/	2.1	
Topcoats				
General	340		2.8	
Metallic/Iridescent	340*		2.8*	
Multi-Colored	685		5.7	
Multistage	340*		2.8*	
Specialty Coating	840		7.0	

*The VOC limits for Metallic/Iridescent and Multistage topcoats for spot repairs on Group I vehicles and mobile equipment will be 3.5 lb/gal (less water and exempt compounds).

(B) Group II Vehicles

A person who applies coatings to Group II vehicles, or their parts or components, shall not apply a coating which has a VOC content in excess of the limits in Table 2.



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1151 12-02-2005]

TABLE 2

COATING	VOC Limits					
	Grams Per Liter of Coating, Less Water and Exempt Compounds					
	On and After <u>December 12, 1998</u>		On and After <u>July 1, 1999</u>		On and After <u>October 1, 1999</u>	
	<u>g/L</u>	<u>lb/gal</u>	<u>g/L</u>	<u>lb/gal</u>	<u>g/L</u>	<u>lb/gal</u>
Pretreatment	780	6.5	780	6.5	780	6.5
Primer/Primer Surfacer	250	2.1	250	2.1	250	2.1
Primer Sealer	340	2.8	340	2.8	340	2.8
Topcoats						
General	420	3.5	420	3.5	420	3.5
Metallic/Tridescent	420	3.5	420	3.5	420	3.5
Multi-Colored	685	5.7	685	5.7	685	5.7
Multistage System						
≥ 2 gal/day ¹	540	4.5	420 ¹	3.5	420	3.5
< 2 gal/day ²	540	4.5	540 ²	4.5	420	3.5
Multi-Colored Multistage	420	3.5	420	3.5	420	3.5
Specialty Coating	840	7.0	840	7.0	840	7.0

¹ On and after July 1, 1999, any person who uses two gallons or more of combined basecoat and clearcoat, as applied, on any given day shall comply with the 420 g/L (3.5 lb/gal) limit.

² Any person who uses less than two gallons of combined basecoat and clearcoat, as applied, on each day up to September 30, 1999 shall comply with the 3.5 lb/gal limit on and after October 1, 1999.



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1151 12-02-2005]

(2) Exempt Compounds

A person shall not apply a coating which contains any Group II exempt compounds as defined in Rule 102 except for methylene chloride; carbon tetrachloride; perchloroethylene; or cyclic, branched, or linear, completely methylated siloxanes (VMS).

(3) Carcinogenic Materials


A person shall not apply the coatings in which cadmium or hexavalent chromium was introduced as a pigment or as an agent to impart any property or characteristic to the coatings during manufacturing, distribution, or use of the applicable coatings.

Appendix A

Effective July 1, 2008, the emission limits specified in this appendix shall become effective and replace the limits specified above

Except as otherwise provided in Rule 1151

- (1) A person shall not apply any coating to a vehicle, mobile equipment, or associated parts or components, that have a VOC content in excess of the limits contained in Table A of this paragraph. Compliance with the VOC limits shall be based on VOC content, including any VOC material added to the original coating supplied by the manufacturer, less water and exempt compounds, as applied to the vehicle, mobile equipment or parts and components.



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1151 12-02-2005]

Table A – Coating Categories and VOC limits

Coating Categories	VOC Limits Less Water and Less Exempt Compounds					
	Effective Dates					
	July 1, 2008		January 1, 2009		January 1, 2010	
	g/L	lb/gal	g/L	lb/gal	g/L	lb/gal
Adhesion Promoter					540	4.5
Clear Coating	250	2.1				
Color Coating	420	3.5				
Multi-Color Coating			680	5.7		
Pretreatment Coating			660	5.5		
Primer					250	2.1
Single-Stage Coating					340	2.8
Temporary Protective Coating			60	0.5		
Truck Bed Liner Coating			310	2.6		
Underbody Coating			430	3.6		
Uniform Finishing Coating			540	4.5		
Any other coating type			250	2.1		

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1151 12-02-2005]

- (1) **Most Restrictive VOC Limit**
If any representation on information on the container of any automotive coating, or any label or sticker affixed to the container, or in any sales, advertising, or technical literature supplied by a person that indicates that the coating meets the definition of or is recommended for use for more than one of the coating categories listed in paragraph (1), then the lowest VOC content limit shall apply.
- (2) **VOC Limits Compliance Dates**
The VOC limits in effect as of December 2, 2005 shall be applicable until superceded by the VOC limits and effectiveness dates in Table A of paragraph (1).
- (3) **Exempt Compounds**
A person shall not manufacture, sell, offer for sale, distribute for use in the District, or apply any coating which contains any Group II Exempt Compounds as defined in Rule 102.
- (4) **Carcinogenic Materials**
A person shall not manufacture the coatings in which cadmium or hexavalent chromium was introduced as a pigment or as an agent to impart any property or characteristic to the coatings during manufacturing, distribution, or use of the applicable coatings.

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-07-2003]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-07-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-07-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)


FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 02-01-2008]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	CURRENT LIMITS*	EFFECTIVE 1/1/2008*	EFFECTIVE 1/1/2009
SOLVENT CLEANING ACTIVITY	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application			
(i) General	25 (0.21)		
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)		
(iii) Medical Devices & Pharmaceuticals	800 (6.7)		
(B) Repair and Maintenance Cleaning			
(i) General	25 (0.21)		
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)		



FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 02-01-2008]

	CURRENT LIMITS*	EFFECTIVE 1/1/2008*	EFFECTIVE 1/1/2009
SOLVENT CLEANING ACTIVITY (cont.)	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals			
(A) Tools, Equipment, & Machinery	800 (6.7)		
(B) General Work Surfaces	600 (5.0)		
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)		
(D) Cleaning of Ink Application Equipment			
(i) General	25 (0.21)		
(ii) Flexographic Printing	25 (0.21)		
(iii) Gravure Printing			
(A) Publication	100 (0.83)		
(B) Packaging	25 (0.21)		
(iv) Lithographic (Offset) or Letter Press Printing			
(A) Roller Wash, Blanket Wash, & On-Press Components			
(I) Newsprint	100 (0.83)		

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 02-01-2008]

SOLVENT CLEANING ACTIVITY (cont.)	CURRENT LIMITS*	EFFECTIVE 1/1/2008*	EFFECTIVE 1/1/2009
	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(II) Other Substrates	500 (4.2)	100 (0.83)	
(B) Removable Press Components	25 (0.21)		
(v) Screen Printing	500 (4.2)	100 (0.83)	
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)		
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)		

* The specified limits remain in effect unless revised limits are listed in subsequent columns.

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a).

Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter ² Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER


APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148

FACILITY PERMIT TO OPERATE CITY OF HOPE MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter ² Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100



FACILITY PERMIT TO OPERATE CITY OF HOPE

PERMIT TO OPERATE


Permit No.
A/N 452326

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3304BDITA, SERIAL NO. 9HK00371, TURBOCHARGED, AFTERCOOLED, FOUR CYLINDERS, 167 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 431.2 AND RULE 1470.
[RULE 1470, RULE 431.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING AND NO MORE THAN 4.2 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. OPERATING BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]



FACILITY PERMIT TO OPERATE CITY OF HOPE

7. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:
- A. EMERGENCY USE.
 - B. MAINTENANCE AND TESTING.
 - C. OTHER (DESCRIBE THE REASON FOR OPERATING).

IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.

[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:
- A. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF THREE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.

[RULE 1303 (b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
 - PM: RULE 1470



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT <i>ENGINEERING & COMPLIANCE</i> APPLICATION PROCESSING AND CALCULATIONS	PAGES 4	PAGE NO. I
	APPL. NO. 452326	DATE 6/17/2010
	PROCESSED BY GV02	CHECKED BY

EVALUATION REPORT FOR PERMIT TO OPERATE

COMPANY NAME AND ADDRESS

City of Hope Medical Center
1500 E. Duarte Road
Duarte, CA 91010

EQUIPMENT LOCATION

AQMD ID 23194
City of Hope Medical Center
1500 E. Duarte Road
Duarte, CA 91010

EQUIPMENT DESCRIPTION

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3304BDITA, SERIAL NO. 9HK00371, TURBOCHARGED, AFTERCOOLED, FOUR CYLINDERS, 167 BHP.


BACKGROUND

The internal combustion engine drives an emergency back-up electrical generator at this hospital and research center. The engine has been operated at the site since 2000 under an Air Resources Board (ARB) permit. The applicant has since assumed ownership of the equipment and filed this permit application. Since this engine has been installed at the location site since 2000, it is required to meet the Best Available Control Technology (BACT) requirements for Tier 1 engines for the criteria pollutants. Based on the manufacturer's emissions data provided with this application, the engine meets the Tier 1 emission standards for NO_x and VOC (6.9 and 1.0 grams/bhp-hr). The CO and PM₁₀ emissions comply with Tier 2 levels (3.7 and 0.22 grams/bhp-hr).

The engine is classified as an "in-use" unit as per Rule 1470 and subject to the rule requirements for this engine type.

CALCULATIONS

Please see attachment.



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT <i>ENGINEERING & COMPLIANCE</i> APPLICATION PROCESSING AND CALCULATIONS	PAGES 4	PAGE NO. 2
	APPL. NO. 452326	DATE 6/17/2010
	PROCESSED BY GV02	CHECKED BY

RULES EVALUATION

RULE 212-STANDARDS FOR APPROVING PERMITS AND ISSUING PUBLIC NOTICES

The engine is not located within 1,000 feet of a K-12 school. Public notice will not be required for this project.

RULE 401 - VISIBLE EMISSIONS

This rule limits visible emissions to opacity of less than 20 percent (Ringlemann No.1), as published by the United States Bureau of Mines. Compliance is expected with well maintained and properly operated equipment.

RULE 402 - NUISANCE

The engine is not expected to create a public nuisance based on experience with identical diesel fueled engines. Therefore, compliance with Rule 402 is expected.

RULE 407 – LIQUID AND GASEOUS AIR CONTAMINANTS

Exempt per Rule 407(b)(1).

RULE 431.2-SULFUR CONTENT OF LIQUID FUELS

Diesel fuel supplied to this equipment must contain 15 ppm or less sulfur by weight. Compliance is expected.

RULE 1110.2 – EMISSIONS FROM GASEOUS- AND LIQUID FUELED ENGINES

The engine will operate on an emergency basis for less than 200 hours per year, which will be verified with an elapsed time meter; therefore, the equipment is exempt from the requirements of this rule.

NEW SOURCE REVIEW (NSR)

The equipment must be constructed with BACT. It is exempt from the offset and modeling requirements. The equipment is a Tier 1 engine, as certified by EPA and CARB, which is considered BACT for this rating of equipment (100 bhp to 175 bhp). Compliance with this rule is achieved.


RULE 1401 – NEW SOURCE REVIEW OF TOXIC AIR CONTAMINANTS

Exempt per Rule 1401 (g)(1)(F).

RULE 1470 – REQUIREMENTS FOR STATIONARY DIESEL-FUELED INTERNAL COMBUSTION AND OTHER COMPRESSION IGNITION ENGINES

The PM emission rate from the engine is 0.08 g/bhp-hr, which is less than the 0.15 g/bhp-hr limit required by this rule. In addition, the engine will operate at a distance greater than 500 feet from a K-12 school. As a result, no operational restrictions for testing and maintenance will be placed on the permit.

The engine cannot be part of a Demand Response Program (DRP) and enrolled in an Interruptible Service Contract (ISC) since its PM emission level of 0.08 gram/bhp-hr is higher than the required level of 0.01 gram/bhp-hr or less. Compliance with this rule is expected.




SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT <i>ENGINEERING & COMPLIANCE</i> APPLICATION PROCESSING AND CALCULATIONS	PAGES 4	PAGE NO. 3
	APPL. NO. 452326	DATE 6/17/2010
	PROCESSED BY GV02	CHECKED BY

RECOMMENDATION(S)

This equipment is expected to comply with all applicable Rules and Regulations of the District. A Permit to Operate, subject to the following conditions, is recommended:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
3. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 431.2 AND RULE 1470.
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING AND NO MORE THAN 4.2 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING.
5. OPERATING BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
6. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
7. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE.
 - B. MAINTENANCE AND TESTING.
 - C. OTHER (DESCRIBE THE REASON FOR OPERATING).




SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT <i>ENGINEERING & COMPLIANCE</i> APPLICATION PROCESSING AND CALCULATIONS	PAGES 4	PAGE NO. 4
	APPL. NO. 452326	DATE 6/17/2010
	PROCESSED BY GV02	CHECKED BY

IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.

8. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:
 - A. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF THREE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.



N S R D A T A S U M M A R Y S H E E T

Application No: 452326
Application Type: Permit to Operate without prior Permit to Construct
Application Status: PENDAPPRV
Previous Apps,Dev,Permit #: NONE

Company Name: CITY OF HOPE MEDICAL CENTER
Company ID: 23194
Address: 1500 E DUARTE RD,DUARTE, CA 91010-3012
RECLAIM: NO
RECLAIM Zone: 02A
Air Basin: SC
Zone: 09
Title V: YES

Device ID: 0 - ICE-PPS
Estimated Completion Date: 01-01-2000
Heat Input Capacity: 0 Million BTU/hr
Priority Reserve: NONE - No Priority Access Requested
Recommended Disposition: 31 - PERMIT TO OPERATE GRANTED
PR Expiration:
School Within 1000 Feet: NO
Operating Weeks Per Year: 50
Operating Days Per Week: 1
Monday Operating Hours: 08:00 to 09:00
Tuesday Operating Hours: 00:00 to 00:00
Wednesday Operating Hours: 00:00 to 00:00
Thursday Operating Hours: 00:00 to 00:00
Friday Operating Hours: 00:00 to 00:00
Saturday Operating Hours: 00:00 to 00:00
Sunday Operating Hours: 00:00 to 00:00



Emittant: CO
 BACT:
 Cost Effectiveness: NO
 Source Type: MINOR
 Emis Increase: 0
 Modeling: N/A
 Public Notice: N/A
 CONTROLLED EMISSION
 Max Hourly: 0.11 lbs/hr
 Max Daily: 0.11 lbs/day
 UNCONTROLLED EMISSION
 Max Hourly: 0.11 lbs/hr
 Max Daily: 0.11 lbs/day
 CURRENT EMISSION
 BACT 30 days Avg: 0 lbs/day
 Annual Emission: 5.5 lbs/yr
 District Exemption: 1304 (a) (4) -10/12/1995-Emergency Equipment

Emittant: NOX
 BACT:
 Cost Effectiveness: NO
 Source Type: MINOR
 Emis Increase: 0
 Modeling: N/A
 Public Notice: N/A
 CONTROLLED EMISSION
 Max Hourly: 2.34 lbs/hr
 Max Daily: 2.34 lbs/day
 UNCONTROLLED EMISSION
 Max Hourly: 2.34 lbs/hr
 Max Daily: 2.34 lbs/day
 CURRENT EMISSION
 BACT 30 days Avg: 0 lbs/day
 Annual Emission: 117 lbs/yr
 District Exemption: 1304 (a) (4) -10/12/1995-Emergency Equipment

Emittant: PM10
 BACT:
 Cost Effectiveness: NO
 Source Type: MINOR
 Emis Increase: 0
 Modeling: N/A
 Public Notice: N/A
 CONTROLLED EMISSION
 Max Hourly: 0.03 lbs/hr
 Max Daily: 0.03 lbs/day
 UNCONTROLLED EMISSION
 Max Hourly: 0.03 lbs/hr
 Max Daily: 0.03 lbs/day
 CURRENT EMISSION
 BACT 30 days Avg: 0 lbs/day
 Annual Emission: 1.5 lbs/yr
 District Exemption: 1304 (a) (4) -10/12/1995-Emergency Equipment



Emittant: ROG
BACT:
Cost Effectiveness: NO
Source Type: MINOR
Emis Increase: 0
Modeling: N/A
Public Notice: N/A
CONTROLLED EMISSION
Max Hourly: 0.11 lbs/hr
Max Daily: 0.11 lbs/day
UNCONTROLLED EMISSION
Max Hourly: 0.11 lbs/hr
Max Daily: 0.11 lbs/day
CURRENT EMISSION
BACT 30 days Avg: 0 lbs/day
Annual Emission: 5.5 lbs/yr
District Exemption: 1304 (a) (4) -10/12/1995-Emergency Equipment

Emittant: SOX
BACT:
Cost Effectiveness: NO
Source Type: MINOR
Emis Increase: 0
Modeling: N/A
Public Notice: N/A
CONTROLLED EMISSION
Max Hourly: 0 lbs/hr
Max Daily: 0 lbs/day
UNCONTROLLED EMISSION
Max Hourly: 0 lbs/hr
Max Daily: 0 lbs/day
CURRENT EMISSION
BACT 30 days Avg: 0 lbs/day
Annual Emission: 0.5 lbs/yr
District Exemption: 1304 (a) (4) -10/12/1995-Emergency Equipment

SUPERVISOR'S APPROVAL: _____ SUPERVISOR'S REVIEW DATE: _____

Processed By: gracev 6/3/2010 2:01:12 PM

