



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

November 8, 2011

Mr. Devin Burns
Environmental Manager
Southern California Public Power Authority (SCPPA)
164 W. Magnolia Blvd
Burbank, CA 91502

Subject: RECLAIM/Title V Facility Permit Revision (Facility ID# 128243)

Dear Mr. Burns:

Please find attached the revised Title Page, Table of Contents, Section D, and Section H of your RECLAIM/Title V Facility Permit. The revised permit reflects approval of the administrative permit revision for issuing the Permits to Operate for the following equipment that was previously issued Permits to Construct:

Equipment	Application No.	Device No.	Process/System ID	Permit Type
Turbine No. 1	464716	D4	3/1	PO
SCR/CO Catalyst	465931	C9/C10	3/1	PO
Ammonia Tank	386307	D1	1/1	PO

Please review the attached Sections D and H carefully. Insert the enclosed sections into your Facility Permit and discard the earlier version. Questions concerning changes to your permit should be directed to Mr. Chris Perri at (909) 396-2696.

Sincerely,

Brian L. Yeh
Senior Manager
Mechanical, Chemical, & Public Services

BLY:AYL:JTY:cgp

Attachment

cc: Mr. Gerardo Rios



FACILITY PERMIT TO OPERATE


**BURBANK CITY, BURBANK WATER & POWER, SCPPA
164 W MAGNOLIA BLVD
BURBANK, CA 91502**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By 

Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	3	04/10/2009
B	RECLAIM Annual Emission Allocation	9	01/01/2011
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	4	11/08/2011
E	Administrative Conditions	3	04/10/2009
F	RECLAIM Monitoring and Source Testing Requirements	3	04/10/2009
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	3	04/10/2009
H	Permit To Construct and Temporary Permit to Operate	5	11/08/2011
I	Compliance Plans & Schedules	3	04/10/2009
J	Air Toxics	3	04/10/2009
K	Title V Administration	3	04/10/2009
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	3	04/10/2009
B	Rule Emission Limits	3	04/10/2009



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1- INORGANIC MATERIAL STORAGE					
STORAGE TANK, PRESSURIZED, AQUEOUS AMMONIA 19%, WITH VAPOR BALANCE SYSTEM, 12000 GALS A/N: 386307	D1				C157.1, E144.1, E193.1
Process 3- INTERNAL COMBUSTION- POWER GENERATION					
GAS TURBINE, NO. 1, COMBINED CYCLE, NATURAL GAS, GENERAL ELECTRIC, MODEL PG7241FA, WITH DRY LOW NOX COMBUSTORS, 1787 MMBTU/HR WITH A/N: 464716 GENERATOR, 181.1 MW GENERATOR, HEAT RECOVERY STEAM STEAM TURBINE, STEAM, 142 MW	D4	C9 C10	NOX: MAJOR SOURCE**	CO: 2 PPMV (4) [RULE 1303(a) (1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 2000 PPMV (5) [RULE 407, 4-2-1982]; NOX: 2 PPMV (4) [RULE 2005, 5-6-2005]; PM: 0.01 GRAINS/SCF (5A) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]; PM: 11 LBS/HR (5C) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; SO2: (9) [40CFR 72 - Acid Rain Provisions, 11-24-1997]; SOX: 150 PPMV (8) [40CFR 60 Subpart GG, 3-6-1981]; VOC: 2 PPMV (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A63.1, A99.1, A99.2, A195.2, A195.3, A195.4, A327.1, A433.1, C1.4, D29.2, D29.3, D82.1, D82.2, E57.1, E193.1, I296.1, K40.1, K67.2

* (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
 (5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 5: INTERNAL COMBUSTION: POWER GENERATION					
BURNER, DUCT, NATURAL GAS, 583 MMBTU/HR A/N: 464716	D6	C9 C10	NOX: MAJOR SOURCE**	CO: 2 PPMV (4) [RULE 1303(a) (1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 2000 PPMV (5) [RULE 407, 4-2-1982]; NOX: 0.2 LBS/MMBTU (8B) [40CFR 60 Subpart Da, 10-4-1991]; NOX: 2 PPMV (4) [RULE 2005, 5-6-2005]; NOX: 114 PPMV NATURAL GAS (8A) [40CFR 60 Subpart GG, 3-6-1981]; PM: 0.01 GRAINS/SCF (5A) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; PM: 0.03 LBS/MMBTU (8A) [40CFR 60 Subpart Da, 10-4-1991]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]; PM: 11 LBS/HR (5B) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; SO2: 0.2 LBS/MMBTU (8A) [40CFR 60 Subpart Da, 10-4-1991]; SOX: 150 PPMV (8A) [40CFR 60 Subpart GG, 3-6-1981]; VOC: 2 PPMV (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a) (1)-BACT, 12-6-2002]	A63.1, A99.1, A99.2, A195.2, A195.3, A195.4, A327.1, A433.1, C1.4, D29.2, D29.3, D82.1, D82.2, E57.1, E193.1, I296.1, K40.1, K67.2
CO OXIDATION CATALYST, SERVING UNIT NO. 1, ENGELHARD, WITH 360 CUBIC FEET CATALYST VOLUME, HEIGHT: 67 FT, WIDTH: 26 FT, DEPTH: 3 IN A/N: 465931	C9	D4 D6			

* (1) (1A) (1B) Denotes RECLAIM emission factor
(3) Denotes RECLAIM concentration limit
(5) (5A) (5B) Denotes command and control emission limit
(7) Denotes NSR applicability limit
(9) See App B for Emission Limits
(2) (2A) (2B) Denotes RECLAIM emission rate
(4) Denotes BACT emission limit
(6) Denotes air toxic control rule limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 3: INTERNAL COMBUSTION, POWER GENERATION					
SELECTIVE CATALYTIC REDUCTION, SERVING UNIT NO. 1, CORMETECH, VANADIUM-TITANIUM, 1100 CU.FT.; WIDTH: 26 FT ; HEIGHT: 67 FT ; LENGTH: 1 FT 4 IN WITH A/N: 465931 AMMONIA INJECTION, GRID	C10	D4 D6		NH3: 5 PPMV (4) [RULE 1303(a) (1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A195.1, D12.1, D12.2, D12.3, D29.1, D232.1, E73.1, E179.1, E179.2, E193.1
STACK, NO.1, HEIGHT: 150 FT ; DIAMETER: 19 FT A/N: 464716	S12				
Process 4: RULE 219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECIFIC RULES					
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS	E13			VOC: (9) [RULE 1113, 11-8-1996; RULE 1113, 7-13-2007; RULE 1171, 11-7-2003; RULE 1171, 2-1-2008]	K67.1

* (1) (1A) (1B) Denotes RECLAIM emission factor
 (3) Denotes RECLAIM concentration limit
 (5) (5A) (5B) Denotes command and control emission limit
 (7) Denotes NSR applicability limit
 (9) See App B for Emission Limits
 (2) (2A) (2B) Denotes RECLAIM emission rate
 (4) Denotes BACT emission limit
 (6) Denotes air toxic control rule limit
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
BURBANK CITY, BURBANK WATER & POWER, SCPPA**

SECTION D: DEVICE ID INDEX

**The following sub-section provides an index
to the devices that make up the facility
description sorted by device ID.**



**FACILITY PERMIT TO OPERATE
BURBANK CITY, BURBANK WATER & POWER, SCPPA**

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D1	1	1	0
D4	1	3	0
D6	2	3	0
C9	2	3	0
C10	3	3	0
S12	3	3	0
E13	3	4	0



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

- (a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or
- (b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 11-9-2001]

F24.1 Accidental release prevention requirements of Section 112(r)(7):

- a). The operator shall comply with the accidental release prevention requirements pursuant to 40 CFR Part 68 and shall submit to the Executive Officer, as a part of an annual compliance certification, a statement that certifies compliance with all of the requirements of 40 CFR Part 68, including the registration and submission of a risk management plan (RMP).
- b). The operator shall submit any additional relevant information requested by the Executive Officer or designated agency.

[40CFR 68 - Accidental Release Prevention, 5-24-1996]

DEVICE CONDITIONS

A. Emission Limits



**FACILITY PERMIT TO OPERATE
BURBANK CITY, BURBANK WATER & POWER, SCPPA**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

A63.1 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
CO	Less than or equal to 7988 LBS IN ANY ONE MONTH
PM10	Less than or equal to 9375 LBS IN ANY ONE MONTH
VOC	Less than or equal to 3638 LBS IN ANY ONE MONTH
SOX	Less than or equal to 1006 LBS IN ANY ONE MONTH

The operator shall calculate the emission limit(s) by using the monthly fuel use data and the following emissions factors: PM10 with duct firing = 7.98 lb/MMscf, PM10 without duct firing = 6.93 lb/MMscf, VOC with duct ring = 2.69 lb/MMscf, VOC without duct firing = 2.69 lb/MMscf, VOC startups = 30 lb/event, VOC shutdown = 17 lb/event, SOx = 0.75 lb/MMscf.

The operator shall calculate the emission limit(s) for CO, after the CO CEMS certification based upon the readings from the AQMD certified CEMS. In the event the CO CEMS is not operating or the emissions exceed the valid upper range of the analyzer, the emissions shall be calculated in accordance with the approved CEMS plan.

For the purposes of this condition, the limit(s) shall be based on the total combined emissions from equipment D4 (Gas Turbine 1) and D6 (Duct Burner).

[RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D4, D6]

A99.1 The 2.0 PPM NOX emission limit(s) shall not apply during startup and shutdown periods. Startup time shall not exceed 6 hours per startup per day. Shutdown time shall not exceed 30 minutes per shutdown per day. Written records of startups and shutdowns shall be maintained and made available upon request from AQMD.



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[RULE 2005, 5-6-2005]

[Devices subject to this condition : D4, D6]

- A99.2 The 2.0 PPM CO emission limit(s) shall not apply during the turbine commissioning, startup, and shutdown periods. Startup time shall not exceed 6 hours per startup per day. Shutdown time shall not exceed 30 minutes per shutdown per day. Written records of commissioning, startups, and shutdowns shall be maintained and made available upon request from AQMD.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D4, D6]

- A195.1 The 5 PPMV NH₃ emission limit(s) is averaged over 60 minutes at 15 percent oxygen, dry.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C10]

- A195.2 The 2 PPMV NO_x emission limit(s) is averaged over 3 hours at 15 percent oxygen, dry.

[RULE 2005, 5-6-2005]

[Devices subject to this condition : D4, D6]

- A195.3 The 2 PPMV CO emission limit(s) is averaged over 1 hour at 15 percent oxygen, dry.



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D4, D6]

A195.4 The 2 PPMV VOC emission limit(s) is averaged over 1 hour at 15 percent, dry.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D4, D6]

A327.1 For the purpose of determining compliance with District Rule 475, combustion contaminant emissions may exceed the concentration limit or the mass emission limit listed, but not both limits at the same time.

[RULE 475, 10-8-1976; RULE 475, 8-7-1978]

[Devices subject to this condition : D4, D6]

A433.1 The operator shall comply with the 2.0 ppmv NOx BACT emission concentration limit at all times, except as specified in Condition A195.1 and under the following conditions::

Emission Limits	Averaging Time	Operation Requirements
440 lbs/startup	6 hours	The 440 lbs/startup emission limit shall apply to a startup event which shall not exceed 6 hours per day

For the purposes of this condition, the limit(s) shall be based on the total combined emissions from equipment D4 (Gas Turbine 1) and D6 (Duct Burner).



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[RULE 2005, 5-6-2005]

[Devices subject to this condition : D4, D6]

C. Throughput or Operating Parameter Limits

C1.4 The operator shall limit the number of start-ups to no more than 3 in any one month.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]

[Devices subject to this condition : D4, D6]

C157.1 The operator shall install and maintain a pressure relief valve set at 25 psig.

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D1]

D. Monitoring/Testing Requirements

D12.1 The operator shall install and maintain a(n) flow meter to accurately indicate the flow rate of the total hourly throughput of injected ammonia. The operator shall continuously record the flow rate with a measuring device or gauge accurate to +/- 5 percent, calibrated once every 12 months.

The operator shall maintain the ammonia injection rate between 0 and 350 lbs/hr



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2012, 5-6-2005]

[Devices subject to this condition : C10]

- D12.2 The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature of the exhaust at the inlet to the SCR reactor. The operator shall continuously record the temperature with a measuring device or gauge accurate to +/- 5 percent, calibrated once every 12 months.

The operator shall maintain the temperature between 0 and 900 degrees F

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2012, 5-6-2005]

[Devices subject to this condition : C10]

- D12.3 The operator shall install and maintain a(n) pressure gauge to accurately indicate the differential pressure across the the SCR catalyst bed in inches of water column. The operator shall continuously record the pressure with a measuring device or gauge accurate to +/- 5 percent, calibrated once every 12 months.

The operator shall maintain the differential pressure between 0 and 5 inches of water column

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2012, 5-6-2005]

[Devices subject to this condition : C10]

- D29.1 The operator shall conduct source test(s) for the pollutant(s) identified below.



**FACILITY PERMIT TO OPERATE
BURBANK CITY, BURBANK WATER & POWER, SCPPA**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR

The test shall be conducted at least quarterly during the first twelve months of operation and at least annually thereafter. The NOx concentration, as determined by the CEMS, shall be simultaneously recorded during the ammonia slip test. If the CEMS is inoperable, a test shall be conducted to determine the NOx emissions using District Method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted and the results submitted to the AQMD within 45 days after the test date. The AQMD shall be notified of the date and time of the test at least 7 days prior to the test.

The test shall be conducted to demonstrate compliance with the rule 1303 concentration limit.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C10]

D29.2 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District method 100.1	1 hour	Outlet of the SCR
CO emissions	District method 100.1	1 hour	Outlet of the SCR
SOX emissions	Approved District method	District-approved averaging time	Fuel Sample



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

ROG emissions	Approved District method	1 hour	Outlet of the SCR
PM emissions	Approved District method	District-approved averaging time	Outlet of the SCR
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR
Aldehydes	Approved District method	District-approved averaging time	Outlet of the SCR
Benzene	Approved District method	District-approved averaging time	Outlet of the SCR
Formaldehyde	Approved District method	District-approved averaging time	Outlet of the SCR
Polynuclear Aromatic Hydrocarbons (PAH)	Approved District method	District-approved averaging time	Outlet of the SCR



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The test shall be conducted after AQMD approval of the source test protocol, but no later than 180 days after the initial startup. The AQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted to determine the oxygen levels in the exhaust. In addition, the tests shall measure the fuel flow rate (CFH), the flue gas flow rate, and the turbine and steam turbine generating output in MW.

The test shall be conducted in accordance with a AQMD approved source test protocol. the protocol shall be submitted to the AQMD no later than 45 days before the proposed test date and shall be approved by AQMD before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the tests, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The test shall be conducted for all pollutants 1) when the gas turbine and duct burner are operating simultaneously at 100 percent of maximum heat input and 2) when the gas turbine is operating alone at 100 percent of maximum heat input. In addition, tests shall be conducted when the gas turbine is operating alone at loads of 75 and 50 percent of maximum heat input for the NOx, CO, VOC and NH3 tests.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1401, 3-4-2005; RULE 2005, 5-6-2005]

[Devices subject to this condition : D4, D6]

D29.3 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
SOX emissions	Approved District method	District-approved averaging time	Fuel Sample



**FACILITY PERMIT TO OPERATE
BURBANK CITY, BURBANK WATER & POWER, SCPPA**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

ROG emissions	Approved District method	1 hour	Outlet of the SCR
PM emissions	Approved District method	District-approved averaging time	Outlet of the SCR

The test shall be conducted at least once every three years. The results shall be submitted to the AQMD within 60 days after the test date. The AQMD shall be notified of the date and time of the test at least 10 days prior to the test. The test shall be conducted 1) when the gas turbine and duct burner are operating simultaneously at 100 percent of maximum heat input and 2) when the gas turbine is operating alone at 100 percent of maximum heat input.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration and/or monthly emissions limit.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D4, D6]

D82.1 The operator shall install and maintain a CEMS to measure the following parameters:



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

CO concentration in ppmv

Concentrations shall be corrected to 15 percent oxygen on a dry basis.

The CEMS will convert the actual CO concentrations to mass emission rates (lbs/hr) and record the hourly emission rates on a continuous basis.

The CEMS shall be installed and operated, in accordance with an AQMD approved Rule 218 CEMS plan application. The operator shall not install the CO CEMS prior to receiving AQMD approval of the CO CEMS plan. The CO CEMS shall be installed and operating no later than 90 days after initial startup of the turbine.

The CEMS shall be installed and operated to measure CO concentrations over a 15 minute averaging time period.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D4, D6]

D82.2 The operator shall install and maintain a CEMS to measure the following parameters:

NOX concentration in ppmv

Concentrations shall be corrected to 15 percent oxygen on a dry basis.

[RULE 2012, 5-6-2005]

[Devices subject to this condition : D4, D6]



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D232.1 The operator shall install and maintain a continuous emission monitoring device to accurately indicate the NH₃ concentration in the flue gas exiting the exhaust stack. The monitoring device shall be approved by the Executive Officer and shall monitor and record NH₃ concentrations and alert the operator (via audible or visible alarm) whenever NH₃ concentrations are near, at, or in excess of the permitted NH₃ limit of 5 ppmv, corrected to 15 percent oxygen. It shall continuously monitor, compute, and record the following parameters.

Ammonia concentration, uncorrected in ppmv.

Oxygen concentration in percent.

Ammonia concentration in ppmv, corrected to 15 percent oxygen.

Date, time, extent (in time) of all excursions above 5 ppmv, corrected to 15 percent oxygen.

The continuous emission monitoring device described above shall be operated and maintained according to a Quality Assurance Plan (QAP) approved by the Executive Officer. The QAP must address contingencies for monitored ammonia concentrations near, at, or above the permitted compliance limit, and remedial actions to reduce ammonia levels once an exceedance has occurred.

The continuous emission monitoring device may not be used for compliance determination or emission information determination without corroborative data using an approved reference method for the determination of ammonia.

The continuous emission monitoring device shall be installed and operating no later than 90 days after initial startup of the turbine.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C10]



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E. Equipment Operation/Construction Requirements

E57.1 The operator shall vent this equipment to the CO oxidation and SCR control whenever this equipment is in operation..

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 2005, 5-6-2005]

[Devices subject to this condition : D4, D6]

E73.1 Notwithstanding the requirements of Section E conditions, the operator may, at his discretion, choose not to use ammonia injection if all of the following requirement(s) are met:

The SCR inlet exhaust temperature is 450 degrees F or less not to exceed 6 hours during a startup and 0.5 hours during a shutdown.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]

[Devices subject to this condition : C10]

E144.1 The operator shall vent this equipment, during filling, only to the vessel from which it is being filled.

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D1]

E179.1 For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour.



**FACILITY PERMIT TO OPERATE
BURBANK CITY, BURBANK WATER & POWER, SCPPA**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Condition Number 12-1

Condition Number 12-2

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C10]

E179.2 For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every month and shall be calculated based upon the average of the continuous monitoring for that month.

Condition Number 12-3

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C10]

E193.1 The operator shall construct, operate, and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the Final California Energy Commission Certificate for 01-AFC-6 prepared for this project.

[CA PRC CEQA, 11-23-1970]

[Devices subject to this condition : D1, D4, D6, C10]

I. Administrative



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

1296.1 This equipment shall not be operated unless the operator demonstrates to the Executive Officer that the facility holds sufficient RTCs to offset the annual emissions increase for the first 12 months of operation. In addition, this equipment shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the start of operation, the facility holds sufficient RTCs in an amount equal to the annual emissions increase.

For the purposes of this condition, the annual emission increase is 132962 lbs. of NO_x

RTC's held for the purpose of demonstrating compliance with this condition either at the commencement of initial operation or of a compliance year may be sold only after 12 months of start of initial operation or after the fourth quarter of the applicable compliance year, respectively.

[RULE 2005, 5-6-2005]

[Devices subject to this condition : D4, D6]

K. Record Keeping/Reporting

K40.1 The operator shall provide to the District a source test report in accordance with the following specifications:



FACILITY PERMIT TO OPERATE BURBANK CITY, BURBANK WATER & POWER, SCPPA

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Source test results shall be submitted to the District no later than 60 days after the source test was conducted.

Emission data shall be expressed in terms of concentration (ppmv) corrected to 15 percent oxygen (dry basis), mass rate (lbs/hr), and lbs/MM Cubic Feet. In addition, solid PM emissions, if required to be tested, shall also be reported in terms of grains per DSCF.

All exhaust flow rate shall be expressed in terms of dry standard cubic feet per minute (DSCFM) and dry actual cubic feet per minute (DACFM).

All moisture concentration shall be expressed in terms of percent corrected to 15 percent oxygen.

Source test results shall also include the oxygen levels in the exhaust, fuel flow rate (CFH), the flue gas temperature, and the generator power output (MW) under which the test was conducted.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 2005, 5-6-2005]

[Devices subject to this condition : D4, D6]

- K67.1 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):



**FACILITY PERMIT TO OPERATE
BURBANK CITY, BURBANK WATER & POWER, SCPPA**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

For architectural applications where no thinners, reducers, or other VOC containing materials are added, maintain semi-annual records for all coating consisting of (a) coating type, (b) VOC content as supplied in grams per liter (g/l) of materials for low-solids coatings, (c) VOC content as supplied in g/l of coating, less water and exempt solvent, for other coatings.

For architectural applications where thinners, reducers, or other VOC containing materials are added, maintain daily records for each coating consisting of (a) coating type, (b) VOC content as applied in grams per liter (g/l) of materials used for low-solids coatings, (c) VOC content as applied in g/l of coating, less water and exempt solvent, for other coatings.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : E13]

K67.2 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Natural gas fuel use.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 2012, 5-6-2005]

[Devices subject to this condition : D4, D6]



**FACILITY PERMIT TO OPERATE
BURBANK CITY, BURBANK WATER & POWER, SCPPA**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

NONE