

**PROPOSED**

Issue Date

**CERTIFIED MAIL**  
**RETURN RECEIPT REQUESTED**  
(xxxx xxxx xxxx xxxx xxxx)

11-xxxE CAB  
File No. 0078

Mr. Dennis K. Morgan  
Terminal Manager  
Chevron Products Company  
933 North Nimitz Highway  
Honolulu, Hawaii 96817

Dear Mr. Morgan:

**Subject: Covered Source Permit (CSP) No. 0078-01-C**  
**Application Renewal No. 0078-05**  
**Chevron Products Company**  
**Honolulu Marketing Terminal - Marine**  
**Located at: 777 North Nimitz Highway, Honolulu, Oahu**  
**Date of Expiration: 5 Years from Issue Date**

The subject covered source permit is issued in accordance with Hawaii Administrative Rules (HAR), Title 11, Chapter 60.1. The issuance of this permit is based on the plans, specifications, and information that you submitted as part of your application received on May 30, 2008 and the additional information received on June 29 and July 8 and 12, 2011. The conditions of this permit renewal supersede all conditions contained in all prior permits.

The covered source permit is issued subject to the conditions/requirements set forth in the following attachments:

Attachment I: Standard Conditions  
Attachment IIA: Special Conditions - Equipment in Gasoline Service  
Attachment IIB: Special Conditions - Storage Tanks  
Attachment IIC: Special Conditions - Marine Vessel Loading Dock  
Attachment II - INSIG: Special Conditions - Insignificant Activities  
Attachment III: Annual Fee Requirements  
Attachment IV: Annual Emissions Reporting Requirements

## PROPOSED

Mr. Dennis K. Morgan  
Issue Date  
Page 2

The following forms are enclosed for your use and submittal as required:

- Compliance Certification Form
- Annual Emissions Report Form - Storage Tanks
- Annual Emissions Report Form - Marine Vessel Loading Back
- Monitoring Report Form - Equipment Leaks
- Monitoring Report Form - Storage Tanks
- Monitoring Report Form - Marine Vessel Loading Dock
- Excess Emissions Report Form - Equipment Leaks

This permit: (a) shall not in any manner affect the title of the premises upon which the equipment is to be located; (b) does not release the permittee from any liability for any loss due to personal injury or property damage caused by, resulting from or arising out of the design, installation, maintenance, or operation of the equipment; and (c) in no manner implies or suggests that the Hawaii Department of Health, or its officers, agents, or employees, assumes any liability, directly or indirectly, for any loss due to personal injury or property damage caused by, resulting from or arising out of the design, installation, maintenance, or operation of the equipment.

Sincerely,

STUART YAMADA, P.E., CHIEF  
Environmental Management Division

MM:smk  
Enclosures

c: CAB Monitoring Section

**ATTACHMENT I: STANDARD CONDITIONS  
COVERED SOURCE PERMIT NO. 0078-01-C**

**Issuance Date:**

**Expiration Date:**

This permit is granted in accordance with the Hawaii Administrative Rules (HAR), Title 11, Chapter 60.1, Air Pollution Control, and is subject to the following standard conditions:

1. Unless specifically identified, the terms and conditions contained in this permit are consistent with the applicable requirement, including form, on which each term or condition is based.  
  
(Auth.: HAR §11-60.1-90)
2. This permit, or a copy thereof, shall be maintained at or near the source and shall be made available for inspection upon request. The permit shall not be willfully defaced, altered, forged, counterfeited, or falsified.  
  
(Auth.: HAR §11-60.1-6; SIP §11-60-11)<sup>2</sup>
3. This permit is not transferable whether by operation of law or otherwise, from person to person, from place to place, or from one piece of equipment to another without the approval of the Department of Health, except as provided in HAR, Section 11-60.1-91.  
  
(Auth.: HAR §11-60.1-7; SIP §11-60-9)<sup>2</sup>
4. A request for transfer from person to person shall be made on forms furnished by the Department of Health.  
  
(Auth.: HAR §11-60.1-7)
5. In the event of any changes in control or ownership of the facilities to be constructed or modified, this permit shall be binding on all subsequent owners and operators. The permittee shall notify the succeeding owner and operator of the existence of this permit and its conditions by letter, copies of which will be forwarded to the Department of Health and the U.S. Environmental Protection Agency (EPA), Region 9.  
  
(Auth.: HAR §11-60.1-5, §11-60.1-7, §11-60.1-94)
6. The facility covered by this permit shall be constructed and operated in accordance with the application, and any information submitted as part of the application, for the Covered Source Permit. There shall be no deviation unless additional or revised plans are submitted to and approved by the Department of Health, and the permit is amended to allow such deviation.  
  
(Auth.: HAR §11-60.1-2, §11-60.1-4, §11-60.1-82, §11-60.1-84, §11-60.1-90)

7. This permit (a) does not release the permittee from compliance with other applicable statutes of the State of Hawaii, or with applicable local laws, regulations, or ordinances, and (b) shall not constitute, nor be construed to be an approval of the design of the covered source.

(Auth.: HAR §11-60.1-5, §11-60.1-82)

8. The permittee shall comply with all the terms and conditions of this permit. Any permit noncompliance constitutes a violation of HAR, Chapter 11-60.1 and the Clean Air Act and is grounds for enforcement action; for permit termination, suspension, reopening, or amendment; or for denial of a permit renewal application.

(Auth.: HAR §11-60.1-3, §11-60.1-10, §11-60.1-19, §11-60.1-90)

9. If any term or condition of this permit becomes invalid as a result of a challenge to a portion of this permit, the other terms and conditions of this permit shall not be affected and shall remain valid.

(Auth.: HAR §11-60.1-90)

10. The permittee shall not use as a defense in an enforcement action that it would have been necessary to halt or reduce the permitted activity to maintain compliance with the terms and conditions of this permit.

(Auth.: HAR §11-60.1-90)

11. This permit may be terminated, suspended, reopened, or amended for cause pursuant to HAR, Sections, 11-60.1-10 and 11-60.1-98, and Hawaii Revised Statutes (HRS), Chapter 342B-27, after affording the permittee an opportunity for a hearing in accordance with HRS, Chapter 91.

(Auth.: HAR §11-60.1-3, §11-60.1-10, §11-60.1-90, §11-60.1-98)

12. The filing of a request by the permittee for the termination, suspension, reopening, or amendment of this permit, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

(Auth.: HAR §11-60.1-90)

13. This permit does not convey any property rights of any sort, or any exclusive privilege.

(Auth.: HAR §11-60.1-90)

14. The permittee shall notify the Department of Health and U.S. EPA, Region 9, in writing of the following dates:
- The **anticipated date of initial start-up** for each emission unit of a new source or significant modification not more than sixty (60) days or less than thirty (30) days prior to such date;
  - The **actual date of construction commencement** within fifteen (15) days after such date; and
  - The **actual date of start-up** within fifteen (15) days after such date.

(Auth.: HAR §11-60.1-90)

15. The permittee shall furnish, in a timely manner, any information or records requested in writing by the Department of Health to determine whether cause exists for terminating, suspending, reopening, or amending this permit, or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Department of Health copies of records required to be kept by the permittee. For information claimed to be confidential, the Director of Health may require the permittee to furnish such records not only to the Department of Health but also directly to the U.S. EPA, Region 9, along with a claim of confidentiality.

(Auth.: HAR §11-60.1-14, §11-60.1-90)

16. The permittee shall notify the Department of Health in writing, of the **intent to shut down air pollution control equipment for necessary scheduled maintenance** at least twenty-four (24) hours prior to the planned shutdown. The submittal of this notice shall not be a defense to an enforcement action. The notice shall include the following:
- Identification of the specific equipment to be taken out of service, as well as its location and permit number;
  - The expected length of time that the air pollution control equipment will be out of service;
  - The nature and quantity of emissions of air pollutants likely to be emitted during the shutdown period;
  - Measures such as the use of off-shift labor and equipment that will be taken to minimize the length of the shutdown period; and
  - The reasons why it would be impossible or impractical to shut down the source operation during the maintenance period.

(Auth.: HAR §11-60.1-15; SIP §11-60-16)<sup>2</sup>

17. **Except for emergencies which result in noncompliance with any technology-based emission limitation in accordance with HAR, Section 11-60.1-16.5, in the event any emission unit, air pollution control equipment, or related equipment malfunctions or**

**breaks down in such a manner as to cause the emission of air pollutants in violation of HAR, Chapter 11-60.1 or this permit**, the permittee shall immediately notify the Department of Health of the malfunction or breakdown, unless the protection of personnel or public health or safety demands immediate attention to the malfunction or breakdown and makes such notification infeasible. In the latter case, the notice shall be provided as soon as practicable. Within five (5) working days of this initial notification, the permittee shall also submit, in writing, the following information:

- a. Identification of each affected emission point and each emission limit exceeded;
- b. Magnitude of each excess emission;
- c. Time and duration of each excess emission;
- d. Identity of the process or control equipment causing the excess emission;
- e. Cause and nature of each excess emission;
- f. Description of the steps taken to remedy the situation, prevent a recurrence, limit the excessive emissions, and assure that the malfunction or breakdown does not interfere with the attainment and maintenance of the National Ambient Air Quality Standards and state ambient air quality standards;
- g. Documentation that the equipment or process was at all times maintained and operated in a manner consistent with good practice for minimizing emissions; and
- h. A statement that the excess emissions are not part of a recurring pattern indicative of inadequate design, operation, or maintenance.

The submittal of these notices shall not be a defense to an enforcement action.

(Auth.: HAR §11-60.1-16; SIP §11-60-16)<sup>2</sup>

18. The permittee may request confidential treatment of any records in accordance with HAR, Section 11-60.1-14.

(Auth.: HAR §11-60.1-14, §11-60.1-90)

19. This permit shall become invalid with respect to the authorized construction if construction is not commenced as follows:

- a. Within eighteen (18) months after the permit takes effect, is discontinued for a period of eighteen (18) months or more, or is not completed within a reasonable time.
- b. For phased construction projects, each phase shall commence construction within eighteen (18) months of the projected and approved commencement dates in the permit. This provision shall be applicable only if the projected and approved commencement dates of each construction phase are defined in Attachment II, Special Conditions, of this permit.

(Auth.: HAR §11-60.1-9, §11-60.1-90)

20. The Department of Health may extend the time periods specified in Standard Condition No. 19 upon a satisfactory showing that an extension is justified. Requests for an extension shall be submitted in writing to the Department of Health.

(Auth.: HAR §11-60.1-9, §11-60.1-90)

21. The permittee shall submit fees in accordance with HAR, Chapter 11-60.1, Subchapter 6.

(Auth.: HAR §11-60.1-90)

22. All certifications shall be in accordance with HAR, section 11-60.1-4.

(Auth.: HAR §11-60.1-4, HAR §11-60.1-90)

23. The permittee shall allow the Director of Health, the Regional Administrator for the U.S. EPA and/or an authorized representative, upon presentation of credentials or other documents required by law:

- a. To enter the premises where a source is located or emission-related activity is conducted, or where records must be kept under the conditions of this permit and inspect at reasonable times all facilities, equipment, including monitoring and air pollution control equipment, practices, operations, or records covered under the terms and conditions of this permit and request copies of records or copy records required by this permit; and
- b. To sample or monitor at reasonable times substances or parameters to ensure compliance with this permit or applicable requirements of HAR, Chapter 11-60.1.

(Auth.: HAR §11-60.1-11, §11-60.1-90)

24. Within thirty (30) days of **permanent discontinuance of the construction, modification, relocation, or operation of a covered source covered by this permit**, the discontinuance shall be reported in writing to the Department of Health by a responsible official of the source.

(Auth.: HAR §11-60.1-8; SIP §11-60-10)<sup>2</sup>

25. Each permit renewal application shall be submitted to the Department of Health and the U.S. EPA, Region 9, no less than twelve (12) months and no more than eighteen (18) months prior to the permit expiration date. The Director may allow a permit renewal application to be submitted no less than six (6) months prior to the permit expiration date, if the Director determines that there is reasonable justification.

(Auth.: HAR §11-60.1-101, 40 CFR §70.5(a)(1)(iii))<sup>1</sup>

26. The terms and conditions included in this permit, including any provision designed to limit a source's potential to emit, are federally enforceable unless such terms, conditions, or requirements are specifically designated as not federally enforceable.

(Auth.: HAR §11-60.1-93)

27. The compliance plan and compliance certification submittal requirements shall be in accordance with HAR, Sections 11-60.1-85 and 11-60.1-86. As specified in HAR, Section 11-60.1-86, the compliance certification shall be submitted to the Department of Health and the U.S. EPA, Region 9, once per year, or more frequently as set by any applicable requirement.

(Auth.: HAR §11-60.1-90)

28. **Any document (including reports) required to be submitted by this permit shall be certified as being true, accurate, and complete by a responsible official in accordance with HAR, Sections 11-60.1-1 and 11-60.1-4, and shall be mailed to the following address:**

**Clean Air Branch  
Environmental Management Division  
Hawaii Department of Health  
919 Ala Moana Boulevard, Room 203  
Honolulu, HI 96814**

**Upon request and as required by this permit, all correspondence to the State of Hawaii Department of Health associated with this Covered Source Permit shall have duplicate copies forwarded to:**

**Chief  
Permits Office, (Attention: Air-3)  
Air Division  
U.S. Environmental Protection Agency  
Region 9  
75 Hawthorne Street  
San Francisco, CA 94105**

(Auth.: HAR §11-60.1-4, §11-60.1-90)

29. To determine compliance with submittal deadlines for time-sensitive documents, the postmark date of the document shall be used. If the document was hand-delivered, the date received (“stamped”) at the Clean Air Branch shall be used to determine the submittal date.

(Auth.: HAR §11-60.1-5, §11-60.1-90)

---

<sup>1</sup>The citations to the Code of Federal Regulations (CFR) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the CFR. Due to the integration of the preconstruction and operating permit requirements, permit conditions may incorporate more stringent requirements than those set forth in the CFR.

<sup>2</sup>The citations to the State Implementation Plan (SIP) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the SIP.

## PROPOSED

### ATTACHMENT IIA: SPECIAL CONDITIONS - EQUIPMENT IN GASOLINE SERVICE COVERED SOURCE PERMIT NO. 0078-01-C

**Issuance Date:**

**Expiration Date:**

In addition to the standard conditions of the covered source permit, the following special conditions shall apply to the permitted facility:

#### **Section A. Equipment Description**

1. Attachment IIA of this permit encompasses each piece of equipment used in a system that transfers gasoline or gasoline vapors. Equipment under Attachment IIA is each valve, pump, pressure relief device, sampling connection system, open-ended valve or line, flange or other connector in the gasoline liquid transfer. Conditions from Attachment IIA are not applicable to equipment and components specified in Attachment IIC, Special Condition No. A.1 for the marine vessel loading dock.

(Auth.: HAR §11-60.1-3)

#### **Section B. Federal Regulations**

1. Each piece of equipment in gasoline service is subject to the provisions of the following federal regulations:
  - a. 40 Code of Federal Regulations (CFR) Part 63, National Emission Standards for Hazardous Air Pollutants, Subpart A, General Provisions.
  - b. 40 CFR Part 63, Subpart BBBB, National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161; 40 CFR §60.2, §60.110b, §63.11081)<sup>1</sup>

2. The permittee shall comply with all applicable requirements of these standards, including all emission limits, notification, testing, monitoring and reporting requirements. The major requirements of these standards are detailed in the special conditions of this permit.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161)

#### **Section C. Operational Limitations and Standards**

1. Leak Inspection
  - a. The permittee shall perform monthly leak inspection of all equipment in gasoline service. For the monthly leak inspection, detection methods incorporating sight, sound, and smell are acceptable.

- b. A log book shall be used and shall be signed by the responsible official or operator at the completion of each inspection. A section of the log book shall contain a list, summary description, or diagram(s) showing the location of all equipment in gasoline service at the facility.
- c. Each detection of a liquid or vapor leak shall be recorded in the log book.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161, 40 CFR §63.11089)<sup>1</sup>

2. Leak Repair

- a. When a leak is detected, an initial attempt at repair shall be made as soon as practicable, but no later than five (5) calendar days after the leak is detected. Repair or replacement of leaking equipment shall be completed within fifteen (15) calendar days after detection of each leak, except as provided in Attachment IIA, Special Condition No. C.2.b.
- b. Delay of repair of leaking equipment will be allowed if the repair is not feasible within fifteen (15) days.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161; 40 CFR §63.11089)<sup>1</sup>

**Section D. Monitoring and Recordkeeping Requirements**

1. Records

All records, including support information, shall be maintained for at least five (5) years from the date of the monitoring sample, measurement, test, report, or application. Support information includes all maintenance, inspection, and repair records, and copies of all reports required by this permit. These records shall be true, accurate, and maintained in a permanent form suitable for inspection and made available to the Department of Health or its representative(s) upon request.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-81, §11-60.1-90)

2. Recordkeeping

- a. The permittee shall prepare and maintain a record describing the types, identification numbers, and locations of all equipment in gasoline service. If an instrument program is implemented for leak inspections, the record shall contain a full description of the program.
- b. The permittee shall record in a log book for each leak that is detected the following information:

- i. The equipment type and identification number;
- ii. The nature of the leak (i.e., vapor or liquid) and the method of detection (i.e., sight, sound, or smell);
- iii. The date the leak was detected and the date of each attempt to repair the leak;
- iv. Repair methods applied in each attempt to repair the leak;
- v. "Repair delayed" and the reason for the delay if the leak is not repaired within fifteen (15) calendar days after discovery of the leak;
- vi. The expected date of successful repair of the leak if the leak is not repaired within fifteen (15) days; and
- vii. The date of successful repair of the leak.

(Auth: HAR §11-60.1-3, §11-60.1-81, §11-60.1-90; 40 CFR §63.11094)

### **Section E. Notification and Reporting Requirements**

#### 1. Standard Condition Reporting

Notification and reporting pertaining to the following events shall be done in accordance with Attachment I, Standard Condition Nos. 17 and 24, respectively:

- a. Emissions of air pollutants in violation of HAR, Chapter 11-60.1 or this permit (excluding technology-based emission exceedances due to emergencies); and
- b. Permanent discontinuance of construction, modification, relocation, or operation of the facility covered by this permit.

(Auth.: HAR §11-60.1-8, §11-60.1-15, §11-60.1-16, §11-60.1-90; SIP §11-60-10, §11-60-16)<sup>2</sup>

#### 2. Notifications

- a. The permittee shall submit to the Department of Health and U.S. EPA, Region 9, an initial notification as specified in 40 CFR §63.9(b). If the facility is in compliance with the requirements of 40 CFR Part 63, Subpart BBBBBB, at the time the initial notification is due, the notification of compliance status under Attachment IIA, Special Condition No. E.2.b, may be submitted in lieu of the initial notification.
- b. The permittee shall submit to the Department of Health and U.S. EPA, Region 9, notification of compliance status as specified in 40 CFR §63.9(h). Notification of compliance status shall be submitted in accordance with Attachment IIA, Special Condition No. E.6.
- c. The permittee shall submit to the Department of Health and U.S. EPA, Region 9, additional notifications specified in 40 CFR §63.9, as applicable.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90; 40 CFR §63.11093)<sup>1</sup>

3. Deviations

The permittee shall report **within five (5) days** any deviations from the permit requirements, including those attributed to upset conditions, the probable cause of such deviations, and any corrective actions or preventive measures taken. Corrective actions may include a requirement for additional testing, more frequent monitoring, or implementation of a corrective action plan.

(Auth.: HAR §11-60.1-3, §11-60.1-15, §11-60.1-16, §11-60.1-90)

4. Monitoring Report

The permittee shall complete and submit a **semi-annual** monitoring report to the Department of Health and U.S. EPA, Region 9. Each report shall be submitted **within sixty (60) days after** the end of each semi-annual calendar period (January 1 - June 30 and July 1 - December 31). The enclosed **Monitoring Report Form - Equipment Leaks** shall be used for reporting.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-90; 40 CFR §63.11095)

5. Excess Emissions Report

The permittee shall complete and submit an excess emissions report to the Department of Health and U.S. EPA, Region 9, at the time the semi-annual monitoring report specified in Attachment IIA, Special Condition No. E.4 is submitted. The enclosed **Excess Emissions Report Form - Equipment Leaks** shall be used for reporting.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-90; 40 CFR §63.11089, §63.11095)

6. Compliance Certification

a. During the permit term, the permittee shall submit at least **annually** to the Department of Health and U.S. EPA, Region 9, the attached **Compliance Certification Form** pursuant to HAR, Subsection 11-60.1-86. The permittee shall indicate whether or not compliance is being met with each term or condition of this permit. The compliance certification shall include, at a minimum, the following information:

- i. The identification of each term or condition of the permit that is the basis of the certification;
- ii. The compliance status;
- iii. Whether compliance was continuous or intermittent;
- iv. The methods used for determining the compliance status of the source currently

and over the reporting period;

- v. Any additional information indicating the source's compliance status with any applicable enhanced monitoring and compliance certification, including the requirements of Section 114 (a)(3) of the Clean Air Act or any applicable monitoring and analysis provisions of Section 504(b) of the Clean Air Act;
  - vi. Brief description of any deviations including identifying as possible exceptions to compliance any periods during which compliance is required and which the excursion or exceedances as defined in 40 CFR 64 occurred; and
  - vii. Any additional information as required by the Department of Health, including information to determine compliance.
- b. The compliance certification shall be submitted within **sixty (60) days after** the end of each calendar year, and shall be signed and dated by a responsible official.
  - c. Upon the written request of the permittee, the deadline for submitting the compliance certification may be extended, if the Department of Health determines that reasonable justification exists for the extension.

(Auth.: HAR §11-60.1-4, §11-60.1-86, §11-60.1-90)

#### **Section F. Agency Notification**

1. Any document (including reports) required to be submitted by this covered source permit shall be done in accordance with Attachment I, Standard Condition No. 28.

(Auth.: HAR §11-60.1-4, §11-60.1-90)

---

<sup>1</sup>The citations to the Code of Federal Regulations (CFR) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the CFR. Due to the integration of the preconstruction and operating permit requirements, permit conditions may incorporate more stringent requirements than those set forth in the CFR.

<sup>2</sup>The citations to the State Implementation Plan (SIP) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the SIP.

**PROPOSED**

**ATTACHMENT IIB: SPECIAL CONDITIONS - STORAGE TANKS  
COVERED SOURCE PERMIT NO. 0078-01-C**

**Issuance Date:**

**Expiration Date:**

In addition to the standard conditions of the covered source permit, the following special conditions shall apply to the permitted facility:

**Section A. Equipment Description**

1. Attachment IIB of this permit encompasses the following storage tanks:

<b>Tank No.</b>	<b>Capacity (barrels)</b>	<b>Tank Description</b>
3	7,570	geodesic dome fixed roof and internal floating roof with <u>mechanical shoe primary seal</u>
4	38,805	geodesic dome fixed roof and internal floating roof with <u>mechanical shoe primary seal</u>
5	46,497	fixed cone roof and internal floating roof with primary <u>mechanical shoe seal and secondary wiper seal</u>
6	1,400	internal floating roof with vapor-mounted <u>primary seal</u>
9	31,863	geodesic dome fixed roof and internal floating roof with <u>mechanical shoe primary seal</u>
10	29,276	fixed cone roof and internal floating roof with primary <u>mechanical shoe seal and secondary wiper seal</u>
24	1,301	fixed cone roof and internal floating roof with <u>mechanical shoe primary seal and secondary wiper seal</u>
27	13,062	geodesic dome fixed roof and internal floating roof with <u>mechanical shoe primary seal</u>
28	13,408	geodesic dome fixed roof and internal floating roof with <u>mechanical shoe primary seal</u>
29	12,075	geodesic dome fixed roof and internal floating roof with <u>mechanical shoe primary seal</u>
30	11,666	geodesic dome fixed roof and internal floating roof with <u>mechanical shoe primary seal and secondary flex seal</u>
31	15,019	geodesic dome fixed roof and internal floating roof with <u>vapor-mounted primary seal and secondary seal</u>
34	3,410	fixed cone roof and internal floating roof with <u>vapor-mounted primary seal</u>
47	9,806	fixed cone roof and internal floating roof with <u>mechanical shoe primary seal</u>
-----	greater than or equal to 40,000 gallons (952 barrels)	tanks storing VOL with true vapor pressure equal to or greater than 1.5 psia

(Auth.: HAR §11-60.1-3)

2. The permittee shall identify the tank number and product type for each storage tank. The identification number and product type shall be displayed on each tank at a conspicuous location.

(Auth.: HAR §11-60.1-5)

**Section B. Federal Regulations**

1. Tank Nos. 5, 10, and 30

The storage tanks are subject to the provisions of the following federal regulations:

- a. 40 CFR Part 60, Standards of Performance for New Stationary Sources, Subpart A, General Provisions;
- b. 40 CFR Part 60, Standards of Performance for New Stationary Sources, Subpart Kb, Standards of Performance for Volatile Organic Liquid Storage Vessels (including Petroleum Liquid Storage Vessels) for which construction, reconstruction, or modification commenced after July 23, 1984;
- c. 40 CFR Part 63, National Emission Standards for Hazardous Air Pollutants, Subpart A, General Provisions; and
- d. 40 CFR Part 63, Subpart BBBB, National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161; 40 CFR §60.2, §60.110b, §63.11081)<sup>1</sup>

2. Tank Nos. 3, 4, 5, 6, 9, 10, 24, 27, 28, 29, 30, 31, 34, and 47

The storage tanks are subject to the provisions of the following federal regulations:

- a. 40 CFR Part 63, National Emission Standards for Hazardous Air Pollutants, Subpart A, General Provisions; and
- b. 40 CFR Part 63, Subpart BBBB, National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161; 40 CFR §63.11081)<sup>1</sup>

3. The permittee shall comply with all applicable provisions of these standards including all emission limits, notification, testing, monitoring, and reporting requirements. The major requirements of these standards are detailed in the special conditions of this permit.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161)

**Section C. Operational Limitations and Standards**

1. General (Tank Nos. 5, 10, and 30)

The storage tanks are subject to the control requirements specified in 40 CFR part 60, Subpart Kb, and are deemed in compliance with 40 CFR Part 63, Subpart BBBB, if

requirements of Attachment IIB and 40 CFR Part 60, Subpart Kb, are met. The permittee shall report this determination in the notification of compliance status report pursuant to Attachment IIB, Special Condition No. E.2.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161; 40 CFR §63.11087)<sup>1</sup>

2. Construction and Operation (Tank Nos. 5, 10, and 30)

The storage tanks shall have a fixed roof with an internal floating roof and meet the following specifications:

- a. The true vapor pressure of the volatile organic liquid (VOL) stored shall be maintained below eleven (11) pounds per square inch (psia) at all times.
- b. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside the fixed roof storage tank. The internal floating roof shall be floating on the liquid surface at all times except during initial fill and during those intervals when the storage tank is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of emptying or refilling shall be continuous and shall be accomplished as rapidly as possible.
- c. The storage tank shall be equipped with one of the following closure devices between the wall of the storage tank and the edge of the internal floating roof:
  - i. A foam or liquid-filled seal mounted in contact with the liquid (liquid-mounted seal);
  - ii. Two (2) seals mounted one above the other so that each forms a continuous closure that completely covers the space between the wall of the storage tank and the edge of the internal floating roof. The lower seal may be vapor-mounted, but both must be continuous; or
  - iii. A mechanical shoe seal.
- d. Each opening in a noncontact internal floating roof except for automatic bleeder vents (vacuum breaker vents) and rim space vents is to provide a projection below the liquid surface.
- e. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use.
- f. Automatic bleeder vents shall be equipped with a gasket and are to be closed at all times when the roof is being floated off or is being landed on the roof leg supports.
- g. Rim space vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting.
- h. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The sample well shall have a slit fabric cover that covers at least ninety (90) percent of the opening.

- i. Each penetration of the internal floating roof that allows for the passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover.
- j. Each penetration of the internal floating roof that allows for passage of a ladder shall have a gasketed sliding cover.

(Auth.: HAR §11-60.1-3, §11-60.1-39, §11-60.1-90, §11-60.1-161; 40 CFR 60.112b)<sup>1</sup>

3. Construction and Operation (Tank Nos. 3, 4, 6, 9, 24, 27, 28, 29, 31, 34, and 47)

The gasoline storage tanks shall be equipped with an internal floating roof and meet the following specifications:

- a. The true vapor pressure of the VOL stored inside the storage tanks shall be maintained below eleven (11) psia at all times.
- b. The gasoline storage tanks shall meet either one of the following requirements:
  - i. Equip each internal floating roof gasoline storage tank according to the requirements of 40 CFR §60.112b(a)(1), except for the secondary seal requirements under 40 CFR §60.112b(a)(1)(ii)(B) and the requirements in §60.112b(a)(1)(iv) through (ix).
  - ii. Equip and operate each internal floating roof gasoline storage tank according to the requirements in 40 CFR §63.1063(a)(1)(i) and 40 CFR §63.1063(b).

(Auth.: HAR §11-60.1-3, §11-60.1-39, §11-60.1-90; 40 CFR §63.11087)<sup>1</sup>

4. Compliance Date (Tank Nos. 3, 4, 6, 9, 24, 27, 28, 29, 31, 34, and 47)

The permittee shall be in compliance with the applicable requirements specified in Attachment IIB, Special Condition No. C.3 for the internal floating roof storage tanks at the first degassing and cleaning activity after January 10, 2011, or by January 10, 2018, whichever is first.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161; 40 CFR §63.11087)<sup>1</sup>

5. Tanks Greater Than 40,000 Gallons Capacity

Tanks greater than 40,000 gallons in capacity storing VOL with a true vapor pressure equal to or greater than 1.5 psia (e.g., transmix, denatured ethanol, naphtha, aviation gasoline, motor gasoline, etc.) shall be either pressurized to prevent vapor or gas loss to the atmosphere or designed and equipped with one of the following vapor loss control devices:

- a. A floating roof as specified in HAR §11-60.1-39 (a)(1);
- b. A vapor recovery system as specified in HAR §11-60.1-39 (a)(2); or
- c. Other equipment or means of equal efficiency for purposes of air pollution control as may be approved by the Department of Health.

(Auth.: HAR §11-60.1-3, §11-60.1-39, §11-60.1-90)

#### **Section D. Monitoring and Recordkeeping Requirements**

##### 1. Records

Except for the record required by Attachment IIB, Special Condition Nos. D.7.d and D.8.d, the permittee shall maintain records, including support information, at the facility for at least five (5) years from the date of the monitoring samples, measurements, tests, reports, or application. Support information includes all maintenance, inspection, and repair records, and copies of all reports required by this permit. These records shall be in a permanent form suitable for inspection and made available to the Department of Health or its representative upon request.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90)

##### 2. Inspection (Tank Nos. 5, 10, and 30)

- a. For a tank equipped with the seal system specified in Attachment IIB, Special Condition No. C.2.c.i, inspect in accordance with Attachment IIB, Special Condition Nos. D.3, D.4, and D.5.
- b. For a tank equipped with a double-seal system, as specified in Attachment IIB, Special Condition No. C.2.c.ii, inspect in accordance with:
  - i. Attachment IIB, Special Condition Nos. D.3, D.4, and D.5; or alternatively
  - ii. Attachment IIB, Special Condition Nos. D.3 and D.5, except that for the requirements of Special Condition No. D.5, inspect at least every **five (5) years** instead of ten (10) years.
- c. For a tank equipped with the seal system specified in Attachment IIB, Special Condition No. C.2.c.iii, inspect in accordance with Attachment IIB, Special Condition Nos. D.3, D.4, and D.5.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90, §11-60.1-161; 40 CFR §60.113b; SIP §11-60-15)<sup>1,2</sup>

##### 3. Initial Inspection (Tank Nos. 5, 10, and 30)

After installing the control equipment required to meet Attachment IIB, Special Condition Nos. C.2.b through C.2.j, the permittee shall visually inspect the internal floating roof, the primary seal, and the secondary seal (if one is in service), prior to filling the storage vessel

with VOL. If there are holes, tears, or other openings in the primary seal, the secondary seal, or the seal fabric or defects in the internal floating roof, or both, the permittee shall repair the items before filling the storage vessel.

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90, §11-60.1-161, 40 CFR 60.113b, SIP §11-60-15)<sup>1,2</sup>

4. Annual Inspection (Tank Nos. 5, 10, and 30)

The permittee shall visually inspect the internal floating roof, the primary seal, and the secondary seal (if one is in service) through manholes and roof hatches on the fixed roof at least once every **twelve (12) months** after initial fill. If the internal floating roof is not resting on the surface of the VOL inside the storage tank, or there is liquid accumulated on the roof, or the seal is detached, or there are holes or tears in the seal fabric, the permittee shall repair the items or empty and remove the storage tank from service within **forty-five (45) days**. If a failure that is detected during inspections required by this condition cannot be repaired within **forty-five (45) days** and if the tank cannot be emptied within **forty-five (45) days**, a **thirty (30) day** extension may be requested from the Department of Health in the annual inspection report required by Attachment IIB, Special Condition No. E.9. Such a request for an extension must document that alternate storage capacity is unavailable and specify a schedule of actions the permittee will take that will assure that the control equipment will be repaired or the storage tank will be emptied as soon as possible.

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90, §11-60.1-161, 40 CFR 60.113b, SIP §11-60-15)<sup>1,2</sup>

5. Inspection after Tank Emptied and Degassed (Tank Nos. 5, 10, and 30)

The permittee shall visually inspect the internal floating roof, the primary seal, the secondary seal (if one is in service), gaskets, slotted membranes, and sleeve seals (if any) each time the storage tank is emptied and degassed. If the internal floating roof has defects, the primary seal has holes, tears, or other openings in the seal or seal fabric, or the secondary seal has holes, tears, or other openings in the seal or seal fabric, or the gaskets no longer close off the liquid surfaces from the atmosphere, or the slotted membrane has more than ten (10) percent open area, the permittee shall repair the items, as necessary, so that none of the conditions specified in this paragraph exist before refilling the storage tank with VOL. In no event shall inspections conducted in accordance with this condition occur at intervals greater than **ten (10) years** for tank inspections specified in Attachment IIB, Special Condition Nos. D.2.a, D.2.b.i, and D.2.c. In no event, shall inspections conducted in accordance with this condition occur at intervals greater than **five (5) years** for inspections specified in Attachment IIB, Special Condition No. D.2.b.ii.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90, §11-60.1-161; 40 CFR 60.115b, 60.116b; SIP §11-60-15)<sup>1,2</sup>

6. Inspections (Tank Nos. 3, 4, 6, 9, 24, 27, 28, 29, 31, 34, and 47)
  - a. Internal floating roof storage tank inspections of the floating roof systems shall be performed according to the requirements of 40 CFR §60.113b(a) for option specified in Attachment IIB, Special Condition Nos. C.3.b.i.
  - b. Internal floating roof storage tank inspections of the floating roof systems shall be performed according to the requirements of 40 CFR §63.1063(c)(1) for option specified in Attachment IIB, Special Condition Nos. C.3.b.ii.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161; 40 CFR §63.11092)<sup>1</sup>

7. Records (Tank Nos. 5, 10, and 30)
  - a. The permittee shall keep records of each inspection performed as required by Attachment IIA, Special Condition Nos. D.2, D3, and D.4. Records shall include the tank identification, the date the tank was inspected, and the observed condition of each component of the control equipment (seals, internal floating roof, and fittings, etc.).
  - b. Records shall be maintained on the type of VOL stored, the period of storage, and the maximum true vapor pressure (in psia) of the VOL stored during the respective storage period. Determination of the true vapor pressure shall be done in accordance with 40 CFR §60.116b(e).
  - c. Records shall be maintained on the yearly throughput of each VOL stored inside the tanks.
  - d. Records showing the dimensions (feet) of the storage tanks and the analysis showing the capacity (gallons or barrels) of the storage tanks shall be maintained for the life of each tank.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90, §11-60.1-161, 40 CFR 60.113b, SIP §11-60-15)<sup>1,2</sup>

8. Records (Tank Nos. 3, 4, 6, 9, 24, 27, 28, 29, 31, 34, and 47)
  - a. The permittee shall keep records for each gasoline storage tank in accordance with:
    - i. 40 CFR §60.115b(a) if complying with Attachment IIB, Special Condition No. C.3.b.i;  
or
    - ii. 40 CFR §63.1065 if complying with Attachment IIB, Special Condition Nos. C.3.b.ii.
  - b. Records shall be maintained on the type of VOL stored, the period of storage, and the maximum true vapor pressure (in psia) of VOL during the respective storage period. Determination of the true vapor pressure shall be done in accordance with 40 CFR §60.116b(e).
  - c. Records shall be maintained on the annual throughput for each VOL stored inside the tanks.

- d. Records showing the dimensions (feet) of the storage tank and the analysis showing the capacity (gallons or barrels) of the storage tank shall be maintained for the life of each tank.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161; 40 CFR §63.11094)<sup>1</sup>

### **Section E. Notification and Reporting Requirements**

#### 1. Standard Condition Reporting

Notification and reporting pertaining to the following events shall be done in accordance with Attachment I, Standard Condition Nos. 16, 17 and 24, respectively:

- a. Intent to shut down air pollution control equipment for necessary scheduled maintenance;
- b. Emissions of air pollutants in violation of HAR, Chapter 11-60.1 or this permit (excluding technology-based emission exceedences due to emergencies); and
- c. Permanent discontinuance of construction, modification, relocation, or operation of the facility, or any storage tank covered by this permit.

(Auth.: HAR §11-60.1-8, §11-60.1-15, §11-60.1-16, §11-60.1-90; SIP §11-60-10; SIP §11-60-16)<sup>2</sup>

#### 2. Notifications

- a. The permittee shall submit to the Department of Health and U.S. EPA, Region 9, an initial notification as specified in 40 CFR §63.9(b). If the facility is in compliance with the requirements of 40 CFR Part 63, Subpart BBBBBB, at the time the initial notification is due, the notification of compliance status under Attachment IIB, Special Condition No. E.2.b may be submitted in lieu of the initial notification.
- b. The permittee shall submit to the Department of Health and U.S. EPA, Region 9, notification of compliance status as specified in 40 CFR §63.9(h). The notification of Compliance Status must specify which compliance options included in Table 1 to 40 CFR Part 63, Subpart BBBBBB, are used to comply with Subpart BBBBBB. Notification of compliance status shall be submitted in accordance with Attachment IIB, Special Condition No. E.6.
- c. The permittee shall submit to the Department of Health and U.S. EPA, Region 9, additional notifications specified in 40 CFR §63.9, as applicable.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90; 40 CFR §63.11093)<sup>1</sup>

#### 3. Deviations

The permittee shall report in writing **within five (5) working days** any deviations from permit requirements, including those attributed to upset conditions, the probable cause of

such deviations, and any corrective actions or preventive measures taken. Corrective actions may include a requirement for testing, or more frequent monitoring, or could trigger implementation of a corrective action plan.

(Auth.: HAR §11-60.1-3, §11-60.1-15, §11-60.1-16, §11-60.1-90)

#### 4. Annual Emissions

- a. As required by Attachment IV and in conjunction with the requirements of Attachment III, Annual Fee Requirements, the permittee shall submit **annually** the total tons per year emitted of each regulated air pollutant including hazardous air pollutants (HAPs). The reporting of annual emissions is due **within sixty (60) days** following the end of each calendar year. Completion and submittal of the **Annual Emissions Form: Storage Tanks**, shall be used for reporting.
- b. Upon the written request of the permittee, the deadline for reporting of annual emissions may be extended, if the Department of Health determines that reasonable justification exists for the extension.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-90)

#### 5. Monitoring Report

The permittee shall submit **semi-annually** the following written report to the Department of Health and U.S. EPA, Region 9. The report shall be submitted **within sixty (60) days** after the end of each semi-annual calendar period (January 1 - June 30 and July 1 – December 31). The enclosed **Monitoring Report Form: Storage Tanks**, shall be used for reporting.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90)

#### 6. Compliance Certification

- a. During the permit term, the permittee shall submit at least **annually** to the Department of Health and U.S. EPA, Region 9, the attached **Compliance Certification Form** pursuant to HAR, Subsection 11-60.1-86. The permittee shall indicate whether or not compliance is being met with each term or condition of this permit. The compliance certification shall include, at a minimum, the following information:
  - i. The identification of each term or condition of the permit that is the basis of the certification;
  - ii. The compliance status;
  - iii. Whether compliance was continuous or intermittent;
  - iv. The methods used for determining the compliance status of the source currently and over the reporting period;
  - v. Any additional information indicating the source's compliance status with any applicable enhanced monitoring and compliance certification, including the requirements of Section 114 (a)(3) of the Clean Air Act or any applicable

- vi. monitoring and analysis provisions of Section 504(b) of the Clean Air Act; Brief description of any deviations including identifying as possible exceptions to compliance any periods during which compliance is required and which the excursion or exceedances as defined in 40 CFR 64 occurred; and
- vii. Any additional information as required by the Department of Health, including information to determine compliance.

- b. The compliance certification shall be submitted within **sixty (60) days after** the end of each calendar year and shall be signed and dated by a responsible official.
- c. Upon the written request of the permittee, the deadline for submitting the compliance certification may be extended, if the Department of Health determines that reasonable justification exists for the extension.

(Auth.: HAR §11-60.1-4, §11-60.1-86, §11-60.1-90)

7. Tank Filling and Refilling (Tank Nos. 5, 10, and 30)

The permittee shall notify the Department of Health in writing at least **thirty (30) days** prior to each time each storage tank is to be filled or refilled for which an inspection is required by Attachment IIB, Special Condition Nos. D.3 and D.5. If the inspection required by Attachment IIB, Special Condition D.5 is unplanned and the required **thirty (30) day** advance notice cannot be given, the permittee shall notify the Department of Health at least **seven (7) days prior** to refilling the tank. Notification shall be made by telephone followed immediately by written documentation demonstrating why the inspection was unplanned. Alternatively, this notification, including the written documentation, may be made in writing and sent by express mail, so that the Department of Health receives the notice at least **seven (7) days prior** to the refilling.

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90, §11-60.1-161, 40 CFR 60.113b)<sup>1</sup>

8. Initial Inspection Report (Tank Nos. 5, 10, and 30)

The permittee shall furnish a report to the Department of Health and U.S. EPA, Region 9, after installing the control equipment in accordance with Attachment IIB, Special Condition Nos. C.2.b through C.2.j and performing visual inspection pursuant to Attachment IIB, Special Condition Nos. C.2.b. through C.2.j and D.3. The report shall describe the control equipment and certify that the control equipment meets the specifications of Attachment IIB, Special Condition No. D.3. This report shall be an attachment to the notification required by 40 CFR, §60.7(a)(3).

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90, §11-60.1-161; 40 CFR 60.115b)<sup>1</sup>

9. Annual Inspection Report (Tank Nos. 5, 10, and 30)

A report shall be submitted to the Department of Health and U.S. EPA, Region 9, within **thirty (30) days** of the annual visual inspection required by Attachment IIB, Special Condition No. D.4 if any conditions described in Special Condition No. D.4 are detected. Each report shall identify the storage tank, the nature of defects, and the date the storage tank was emptied or the nature and date the repair was made.

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90, §11-60-161, 40 CFR §60.115b)<sup>1</sup>

10. Other Inspection Reports (Tank Nos. 5, 10, and 30)

A report shall be submitted to the Department of Health and U.S. EPA, Region 9, for inspections required by Attachment IIB, Special Condition No. D.2.b. This report shall be submitted within **thirty (30) days** if an inspection performed pursuant to Attachment IIB, Special Condition Nos. D.4 or D.5 finds holes or tears in the seal or seal fabric, or defects in the internal floating roof, or other control equipment defects listed in Attachment IIB, Special Condition No. D.4. The report shall identify the storage tank and the reason it did not meet the specifications of Attachment IIB, Special Condition Nos. C.2.b through C.2.j or Attachment IIB, Special Condition No. D.2.b and list each repair made.

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90, §11-60-161, 40 CFR §60.113b, §60.115b; SIP §11-60-15)<sup>1,2</sup>

11. Reporting (Tank Nos. 3, 4, 6, 9, 24, 27, 28, 29, 31, 34, and 47)

The permittee shall report the applicable information for each gasoline storage tank as specified in:

- a. 40 CFR §60.115b(a) if complying with Attachment IIB, Special Condition No. C.3.b.i; or
- b. 40 CFR §63.1066 if complying with Attachment IIB, Special Condition No. C.3.b.ii.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161; 40 CFR §63.11095)<sup>1</sup>

**Section F. Agency Notification**

1. Any document (including reports) required to be submitted by this covered source permit shall be in accordance with Attachment I, Standard Condition No. 28.

(Auth.: HAR §11-60.1-4, §11-60.1-90)

---

<sup>1</sup>The citations to the Code of Federal Regulations (CFR) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the CFR. Due to the integration of the preconstruction and operating permits, permit conditions may incorporate more stringent requirements than those set forth in the CFR.

<sup>2</sup>The citations to the State Implementation Plan (SIP) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the SIP.

**PROPOSED**

**ATTACHMENT IIC: SPECIAL CONDITIONS - MARINE VESSEL LOADING DOCK  
COVERED SOURCE PERMIT NO. 0078-01-C**

**Issuance Date:**

**Expiration Date:**

In addition to the standard conditions of the covered source permit, the following special conditions shall apply to the permitted facility:

**Section A. Equipment Description**

1. Attachment IIC of this permit encompasses equipment at the marine vessel loading dock consisting of headers, flexible lines, flanges or other connectors, fittings, piping, pumps, and valves at Pier 30 for submerged loading of VOL into marine vessel storage tanks. Equipment under Attachment IIC includes the entire marine vessel loading system, except for exhaust ports or stacks.

(Auth.: HAR §11-60.1-3)

**Section B. Operational Limitations**

1. Throughput

- a. The total combined throughput for loading marine vessels at the loading dock shall not exceed 4,137,881 barrels of motor gasoline, naphtha, aviation gasoline, and Dimate, on a rolling twelve-month (12-month) basis.
- b. The total throughput for loading marine vessels at the loading dock shall not exceed 833,333 barrels of denatured ethanol on a rolling twelve-month (12-month) basis.
- c. The total throughput for loading marine vessels at the loading dock shall not exceed 6,271,619 barrels of Jet A on a rolling twelve-month (12-month) basis.

(Auth.: HAR §11-60.1-3, §11.60.1-5, §11-60.1-90)

2. Equipment

Equipment and components for the marine vessel loading dock shall be properly connected and fully functional at all times to prevent vapor and liquid leaks when transferring VOL.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90)

3. Maintenance

Equipment and components from the marine vessel loading dock shall be properly maintained and kept in good operating condition at all times. The permittee shall inspect and maintain equipment and components from the marine vessel loading dock to prevent vapor and liquid leaks when transferring VOL.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90)

**Section C. Monitoring and Recordkeeping Requirements**

1. Records

All records, including support information, shall be maintained at the facility for at least five (5) years from the date of the monitoring samples, measurements, tests, reports, or application. Support information includes all maintenance, inspection, and repair records, and copies of all reports required by this permit. These records shall be in a permanent form suitable for inspection and made available to the Department of Health or its representative upon request.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-90)

2. Throughput

The permittee shall monitor product throughput with tank gauging systems and pipeline flow meters. Product throughput shall be determined for loading VOL into marine vessels and supplying the Chevron Products Company transportation terminal with VOL. The permittee shall determine the Jet A and denatured ethanol throughput and total combined motor gasoline, naphtha, aviation gasoline, and Dimate throughput for loading marine vessel storage tanks. The throughput for loading marine vessels with Jet A, denatured ethanol, motor gasoline, naphtha, aviation gasoline, and Dimate shall be determined on a monthly and rolling twelve-month (12-month) basis.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90)

**Section D. Notification and Reporting Requirements**

1. Standard Condition Reporting

Notification and reporting pertaining to the following events shall be done in accordance with Attachment I, Standard Condition Nos. 17 and 24, respectively:

- a. Emissions of air pollutants in violation of HAR, Chapter 11-60.1 or this permit (excluding technology-based emission exceedances due to emergencies); and
- b. Permanent discontinuance of construction, modification, relocation, or operation of the facility covered by this permit.

(Auth.: HAR §11-60.1-8, §11-60.1-15, §11-60.1-16, §11-60.1-90; SIP §11-60-10; SIP §11-60-16)<sup>1</sup>

2. Deviations

The permittee shall report in writing **within five (5) working days** any deviations from permit requirements, including those attributed to upset conditions, the probable cause of such deviations and any corrective actions or preventive measures taken. Corrective actions may include a requirement for testing, or more frequent monitoring, or could trigger implementation of a corrective action plan.

(Auth.: HAR §11-60.1-3, §11-60.1-15, §11-60.1-16, §11-60.1-90)

3. Annual Emissions

- a. As required by Attachment IV and in conjunction with the requirements of Attachment III, Annual Fee Requirements, the permittee shall submit **annually** the total tons per year emitted of each regulated air pollutant, including HAPs. The reporting of annual emissions is due **within sixty (60) days following** the end of each calendar year. Completion and submittal of the **Annual Emissions Report Form: Marine Terminal**, shall be used for reporting.
- b. Upon the written request of the permittee, the deadline for reporting annual emissions may be extended, if the Department of Health determines that reasonable justification exists for the extension.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-90)

4. Monitoring Report

The permittee shall submit **semi-annually** the following written report to the Department of Health. The report shall be submitted **within sixty (60) days after** the end of each semi-annual calendar period (January 1 - June 30 and July 1 - December 31). The enclosed **Monitoring Report Form: Marine Vessel Loading Dock**, shall be used for reporting.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90, SIP §11-60-15)<sup>1</sup>

5. Inspection, Maintenance, and Repair Log

The permittee shall maintain records on inspections (e.g., liquid and vapor leak inspections), maintenance, and any repair work conducted on equipment used to transfer VOL at the marine loading dock. At a minimum, these records shall include:

- a. The date of the inspection/repair work;
- b. The date and description of the findings or any maintenance or repair work performed;

- c. The name and title of personnel performing the inspection/work; and
- d. Part(s) inspected or repaired.

6. Compliance Certification

- a. During the permit term, the permittee shall submit at least **annually** to the Department of Health and U.S. EPA, Region 9, the attached **Compliance Certification Form** pursuant to HAR, Subsection 11-60.1-86. The permittee shall indicate whether or not compliance is being met with each term or condition of this permit. The compliance certification shall include, at a minimum, the following information:
  - i. The identification of each term or condition of the permit that is the basis of the certification;
  - ii. The compliance status;
  - iii. Whether compliance was continuous or intermittent;
  - iv. The methods used for determining the compliance status of the source currently and over the reporting period;
  - v. Any additional information indicating the source's compliance status with any applicable enhanced monitoring and compliance certification, including the requirements of Section 114 (a) (3) of the Clean Air Act or any applicable monitoring and analysis provisions of Section 504 (b) of the Clean Air Act;
  - vi. Brief description of any deviations including identifying as possible exceptions to compliance any periods during which compliance is required and which the excursion or exceedances as defined in 40 CFR 64 occurred; and
  - vii. Any additional information as required by the Department of Health, including information to determine compliance.
- b. The compliance certification shall be submitted within **sixty (60) days after** the end of each calendar year and shall be signed and dated by a responsible official.
- c. Upon the written request of the permittee, the deadline for submitting the compliance certification may be extended, if the Department of Health determines that reasonable justification exists for the extension.

(Auth.: HAR §11-60.1-4, §11-60.1-86, §11-60.1-90)

**Section E. Agency Notification**

- 1. Any document (including reports) required to be submitted by this covered source permit shall be in accordance with Attachment I, Standard Condition No. 28.

(Auth.: HAR §11-60.1-4, §11-60.1-90)

---

<sup>1</sup>The citations to the State Implementation Plan (SIP) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the SIP.

**CSP No. 0078-01-C**  
**Attachment IIC**  
**Page 5 of 4**  
**Issuance Date:**  
**Expiration Date:**

**PROPOSED**

<sup>2</sup>The citations to the Code of Federal Regulations (CFR) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the CFR. Due to the integration of the preconstruction and operating permits, permit conditions may incorporate more stringent requirements than those set forth in the CFR.

**ATTACHMENT II - INSIG  
SPECIAL CONDITIONS - INSIGNIFICANT ACTIVITIES  
COVERED SOURCE PERMIT NO. 0078-01-C**

**Issuance Date:**

**Expiration Date:**

In addition to the Standard Conditions of the Covered Source Permit, the following Special Conditions shall apply to the permitted facility:

**Section A. Equipment Description**

1. Attachment II-INSIG encompasses the following insignificant activities:
  - a. 15,592 barrel fixed cone roof Tank No. 1;
  - b. 8,447 barrel fixed roof Tank No. 2;
  - c. 1,400 barrel fixed cone roof Tank No. 7;
  - d. 12,464 barrel fixed cone roof Tank No. 14;
  - e. 20,848 barrel fixed cone roof Tank No. 19;
  - f. 10,942 barrel fixed cone roof Tank No. 26;
  - g. 5,715 barrel fixed cone roof Tank No. 32;
  - h. 10,627 barrel fixed cone roof Tank No. 48;
  - i. 23,500 barrel fixed cone roof Tank No. 50;
  - j. 24,756 barrel fixed cone roof Tank No. 51;
  - k. 1,000 gallon horizontal fixed roof Tank No. 52;
  - l. 500 barrel fixed cone roof Tank No. 53;
  - m. 760 gallon recovered oil tank;
  - n. 400 gallon portable tote tank;
  - o. Oil water separator inside open concrete pit;
  - p. Three (3) oil water separators inside closed concrete pits;
  - q. Monarch System oil water separator, job no. 890, serial no. MSECS 28/75 8901;
  - r. Sump (one compartment concrete pit);
  - s. Sump (two compartment concrete pit);
  - t. 256 kW emergency Caterpillar diesel engine generator, model no. 3406B, serial no. 4RC00344PP04841; and
  - u. Marine vessel loading operations for diesel and fuel oil; and
  - v. Marine vessel unloading operations.

(Auth.: HAR §11-60.1-3)

**Section B. Operational Limitations**

1. The permittee shall take measures to operate applicable insignificant activities in accordance with the provisions of HAR, Subchapter 2 for visible emissions, fugitive dust, incineration, process industries, sulfur oxides from fuel combustion, storage of volatile organic compounds, volatile organic compound water separation, pump and compressor requirements, and waste gas disposal.

(Auth.: HAR §11-60.1-3, §11-60.1-82, §11-60.1-90)

2. The Department of Health may at any time require the permittee to further abate emissions if an inspection indicates poor or insufficient controls.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-82, §11-60.1-90)

### **Section C. Monitoring and Recordkeeping Requirements**

1. The Department of Health reserves the right to require monitoring, recordkeeping, or testing of any insignificant activity to determine compliance with the applicable requirements.

(Auth.: HAR §11-60.1-3, §11-60.1-90)

2. All records shall be maintained for at least five (5) years from the date of any required monitoring, recordkeeping, testing, or reporting. These records shall be true, accurate, and maintained in a permanent form suitable for inspection and made available to the Department of Health or its authorized representative upon request.

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90)

### **Section D. Notification and Reporting**

#### Compliance Certification

- a. During the permit term, the permittee shall submit at least **annually** to the Department of Health and U.S. EPA, Region 9, the attached *Compliance Certification Form* pursuant to HAR, Subsection 11-60.1-86. The permittee shall indicate whether or not compliance is being met with each term or condition of this permit. The compliance certification shall include, at a minimum, the following information:
  - i. The identification of each term or condition of the permit that is the basis of the certification;
  - ii. The compliance status;
  - iii. Whether compliance was continuous or intermittent;
  - iv. The methods used for determining the compliance status of the source currently and over the reporting period;
  - v. Any additional information indicating the source's compliance status with any applicable enhanced monitoring and compliance certification including the requirements of Section 114(a)(3) of the Clean Air Act or any applicable monitoring and analysis provisions of Section 504(b) of the Clean Air Act;
  - vi. Brief description of any deviations including identifying as possible exceptions to compliance any periods during which compliance is required and in which the excursion or exceedances as defined in 40 CFR 64 occurred; and
  - vii. Any additional information as required by the Department of Health including information

to determine compliance.

- b. The compliance certification shall be submitted **within ninety (90) days** after the end of each calendar year, and shall be signed and dated by a responsible official.
- c. Upon written request of the permittee, the deadline for submitting the compliance certification may be extended, if the Department of Health determines that reasonable justification exists for the extension.
- d. In lieu of addressing each emission unit as specified in *Compliance Certification Form*, the permittee may address insignificant activities as a single unit provided compliance is met with all applicable requirements. If compliance is not totally attained, the permittee shall identify the specific insignificant activity and provide the details associated with the noncompliance.

(Auth.: HAR §11-60.1-4, §11-60.1-86, §11-60.1-90)

**Section E. Agency Notification**

Any document (including reports) required to be submitted by this covered source permit shall be done in accordance with Attachment I, Standard Condition No. 28.

(Auth.: HAR §11-60.1-4, §11-60.1-90)

**PROPOSED**

**ATTACHMENT III: ANNUAL FEE REQUIREMENTS  
COVERED SOURCE PERMIT NO. 0078-01-C**

**Issuance Date:**

**Expiration Date:**

The following requirements for the submittal of annual fees are established pursuant to Hawaii Administrative Rules (HAR), Title 11, Chapter 60.1, Air Pollution Control. Should HAR, Chapter 60.1 be revised such that the following requirements are in conflict with the provisions of HAR, Chapter 60.1, the permittee shall comply with the provisions of HAR, Chapter 60.1:

1. Annual fees shall be paid in full:
  - a. Within **sixty (60) days** after the end of each calendar year; and
  - b. Within **thirty (30) days** after the permanent discontinuance of the covered source.
2. The annual fees shall be determined and submitted in accordance with Hawaii Administrative Rules, Chapter 11-60.1, Subchapter 6.
3. The annual emissions data for which the annual fees are based shall accompany the submittal of any annual fees and submitted on forms furnished by the Department of Health.
4. The annual fees and the emission data shall be mailed to:

**Clean Air Branch  
Environmental Management Division  
Hawaii Department of Health  
919 Ala Moana Boulevard, Room 203  
Honolulu, HI 96814**

**ATTACHMENT IV: ANNUAL EMISSIONS REPORTING REQUIREMENTS  
COVERED SOURCE PERMIT NO. 0078-01-C**

**Issuance Date:**

**Expiration Date:**

In accordance with the Hawaii Administrative Rules, Title 11, Chapter 60.1, Air Pollution Control, the permittee shall report to the Department of Health the nature and amounts of emissions.

1. Complete the attached forms:

Annual Emissions Report Form: Storage Tanks

Annual Emissions Report Form: Marine Vessel Loading Dock

2. The reporting period shall be from January 1 to December 31 of each year. All reports shall be submitted to the Department of Health within **sixty (60) days** after the end of each calendar year and shall be mailed to the following address:

**Clean Air Branch  
Environmental Management Division  
Hawaii Department of Health  
919 Ala Moana Boulevard, Room 203  
Honolulu, HI 96814**

3. The permittee shall retain the information submitted, including all emission calculations. These records shall be in a permanent form suitable for inspection, retained for a minimum of five (5) years, and made available to the Department of Health upon request.
4. Any information submitted to the Department of Health without a request for confidentiality shall be considered public record.
5. In accordance with HAR, Section 11-60.1-14, the permittee may request confidential treatment of specific information including information concerning secret processes or methods of manufacturing, by submitting a written request to the Director and clearly identifying the specific information that is to be accorded confidential treatment.

**COMPLIANCE CERTIFICATION FORM  
COVERED SOURCE PERMIT NO. 0078-01-C  
PAGE 1 OF \_\_\_\_**

**Issuance Date:** \_\_\_\_\_

**Expiration Date:** \_\_\_\_\_

In accordance with the Hawaii Administrative Rules, Title 11, Chapter 60.1, Air Pollution Control, the permittee shall report to the Department of Health the following certification at least annually, or more frequently as requested by the Department.

(Make Copies of the Compliance Certification Form for Future Use)

For Period: \_\_\_\_\_ Date: \_\_\_\_\_

Company/Facility Name: \_\_\_\_\_

Responsible Official (Print): \_\_\_\_\_

Title: \_\_\_\_\_

Responsible Official (Signature): \_\_\_\_\_

I certify that I have knowledge of the facts herein set forth, that the same are true, accurate and complete to the best of my knowledge and belief, and that all information not identified by me as confidential in nature shall be treated by Department of Health as public record. I further state that I will assume responsibility for the construction, modification, or operation of the source in accordance with the Hawaii Administrative Rules, Title 11, Chapter 60.1, Air Pollution Control, and any permit issued thereof.

---

**COMPLIANCE CERTIFICATION FORM  
COVERED SOURCE PERMIT NO. 0078-01-C  
(CONTINUED, PAGE 2 OF \_\_\_)**

**Issuance Date:**

**Expiration Date:**

The purpose of this form is to evaluate whether or not the facility was in compliance with the permit terms and conditions during the covered period. If there were any deviations to the permit terms and conditions during the covered period, the deviation(s) shall be certified as *intermittent compliance* for the particular permit term(s) or condition(s). Deviations include failure to monitor, record, report, or collect the minimum data required by the permit to show compliance. In the absence of any deviation, the particular permit term(s) or condition(s) may be certified as *continuous compliance*.

**Instructions:**

Please certify Sections A, B, and C below for continuous or intermittent compliance. Sections A and B are to be certified as a group of permit conditions. Section C shall be certified individually for each operational and emissions limit condition as listed in the Special Conditions section of the permit (list all applicable equipment for each condition). Any deviations shall also be listed individually and described in Section D. The facility may substitute its own generated form in verbatim for Sections C and D.

**A. Attachment I, Standard Conditions**

<u>Permit term/condition</u>	<u>Equipment</u>	<u>Compliance</u>
All standard conditions	All Equipment listed in the permit	Continuous Intermittent

**B. Special Conditions - Monitoring, Recordkeeping, Reporting, Testing, and INSIG**

<u>Permit term/condition</u>	<u>Equipment</u>	<u>Compliance</u>
All monitoring conditions	All Equipment listed in the permit	Continuous Intermittent
All recordkeeping conditions	All Equipment listed in the permit	Continuous Intermittent
All reporting conditions	All Equipment listed in the permit	Continuous Intermittent

**COMPLIANCE CERTIFICATION FORM  
COVERED SOURCE PERMIT NO. 0078-01-C  
(CONTINUED, PAGE \_\_\_\_ OF \_\_\_\_)**

**Issuance Date:**

**Expiration Date:**

**C. Special Conditions - Operational and Emissions Limitations**

Each permit term/condition shall be identified in chronological order using attachment and section numbers (e.g., Attachment II, B.1, Attachment IIA, Special Condition No. B.1.f, etc.). Each piece of equipment shall be identified using the description stated in Section A of the Special Conditions (e.g., unit no., model no., serial no., etc.). Check all methods (as required by permit) used to determine the compliance status of the respective permit term/condition.

<u>Permit Term/Condition</u>	<u>Equipment</u>	<u>Method</u>	<u>Compliance</u>
		monitoring recordkeeping reporting testing	Continuous Intermittent

**(Make Additional Copies if Needed)**

**COMPLIANCE CERTIFICATION FORM  
COVERED SOURCE PERMIT NO. 0078-01-C  
(CONTINUED, PAGE \_\_\_ OF \_\_\_)**

**Issuance Date:**

**Expiration Date:**

**D. Deviations**

<u>Permit Term/Condition</u>	<u>Equipment(s) / Brief Summary of Deviation</u>	<u>Deviation Period time (am/pm) &amp; date (mo/day/yr)</u>	<u>Date of Written Deviation Report to DOH (mo/day/yr)</u>
		Beginning:  Ending:	

\*Identify as possible exceptions to compliance any periods during which compliance is required and in which an excursion or exceedance as defined under 40 CFR 64 occurred.

**(Make Additional Copies if Needed)**

**PROPOSED**

**ANNUAL EMISSIONS REPORT FORM  
STORAGE TANKS  
COVERED SOURCE PERMIT NO. 0078-01-C  
(PAGE 1 OF 3)**

**Issuance Date:**

**Expiration Date:**

In accordance with the HAR, Title 11, Chapter 60.1, Air Pollution Control, the permittee shall report to the Department of Health the nature and amounts of emissions.

**(Make Copies for Additional Use)**

For Period: \_\_\_\_\_ Date: \_\_\_\_\_

Facility Name: \_\_\_\_\_

I certify that I have knowledge of the facts herein set forth, that the same are true, accurate and complete to the best of my knowledge and belief, and that all information not identified by me as confidential in nature shall be treated by the Department of Health as public record.

Responsible Official and Title (print): \_\_\_\_\_

Responsible Official (signature/phone): \_\_\_\_\_

-

1. Report the following for the annual reporting period:

TANK & PRODUCT DESCRIPTION	HTM 3	HTM 4	HTM 5
TANK CAPACITY (gallons)			
TANK DIAMETER (feet)			
DECK TYPE (bolted/welded)			
PRODUCT NAME			
TRUE VAPOR PRESSURE (psia)			
LIQUID MOLECULAR WEIGHT			
VAPOR MOLECULAR WEIGHT			
AVG. STORAGE TEMP. (°F)			
ANNUAL THROUGHPUT (bbls)			

**PROPOSED**

**ANNUAL EMISSIONS REPORT FORM  
STORAGE TANKS  
COVERED SOURCE PERMIT NO. 0078-01-C  
(CONTINUED, PAGE 2 OF 3)**

**Issuance Date:**

**Expiration Date:**

TANK & PRODUCT DESCRIPTION	HTM 6	HTM 9	HTM 10
TANK CAPACITY (gallons)			
TANK DIAMETER (feet)			
DECK TYPE (bolted/welded)			
PRODUCT NAME			
TRUE VAPOR PRESSURE (psia)			
LIQUID MOLECULAR WEIGHT			
VAPOR MOLECULAR WEIGHT			
AVG. STORAGE TEMP. (°F)			
ANNUAL THROUGHPUT (bbls)			

TANK & PRODUCT DESCRIPTION	HTM 24	HTM 27	HTM 28
TANK CAPACITY (gallons)			
TANK DIAMETER (feet)			
DECK TYPE (bolted/welded)			
PRODUCT NAME			
TRUE VAPOR PRESSURE (psia)			
LIQUID MOLECULAR WEIGHT			
VAPOR MOLECULAR WEIGHT			
AVG. STORAGE TEMP. (°F)			
ANNUAL THROUGHPUT (bbls)			

**PROPOSED**

**ANNUAL EMISSIONS REPORT FORM  
STORAGE TANKS  
COVERED SOURCE PERMIT NO. 0078-01-C  
(CONTINUED, PAGE 3 OF 3)**

**Issuance Date:**

**Expirations Date:**

TANK & PRODUCT DESCRIPTION	HTM 29	HTM 30	HTM 31
TANK CAPACITY (gallons)			
TANK DIAMETER (feet)			
DECK TYPE (bolted/welded)			
PRODUCT NAME			
TRUE VAPOR PRESSURE (psia)			
LIQUID MOLECULAR WEIGHT			
VAPOR MOLECULAR WEIGHT			
AVG. STORAGE TEMP. (°F)			
ANNUAL THROUGHPUT (bbls)			

TANK & PRODUCT DESCRIPTION	HTM 34	HTM 47	
TANK CAPACITY (gallons)			
TANK DIAMETER (feet)			
DECK TYPE (bolted/welded)			
PRODUCT NAME			
TRUE VAPOR PRESSURE (psia)			
LIQUID MOLECULAR WEIGHT			
VAPOR MOLECULAR WEIGHT			
AVG. STORAGE TEMP. (°F)			
ANNUAL THROUGHPUT (bbls)			

**PROPOSED**

**ANNUAL EMISSIONS REPORT FORM  
MARINE VESSEL LOADING DOCK  
COVERED SOURCE PERMIT NO. 0078-01-C**

**Issuance Date:** \_\_\_\_\_

**Expiration Date:** \_\_\_\_\_

In accordance with the HAR, Title 11, Chapter 60.1, Air Pollution Control, the permittee shall report to the Department of Health the nature and amounts of emissions.

**(Make Copies for Additional Use)**

For Period: \_\_\_\_\_ Date: \_\_\_\_\_

Facility Name: \_\_\_\_\_

**I certify that I have knowledge of the facts herein set forth, that the same are true, accurate and complete to the best of my knowledge and belief, and that all information not identified by me as confidential in nature shall be treated by the Department of Health as public record.**

Responsible Official and Title (print): \_\_\_\_\_

Responsible Official (signature/phone): \_\_\_\_\_

—

1. Report the following for the annual reporting period:

Product	Marine Vessel Loading Throughput (barrels/year)	Throughput to Transportation Terminal (barrels/year)
Motor Gasoline		
Aviation Gasoline		
Naphtha		
Denatured Ethanol		
Jet A		
Dimate		



**PROPOSED**

--	--	--	--

**PROPOSED**

**MONITORING REPORT FORM  
STORAGE TANKS  
COVERED SOURCE PERMIT NO. 0078-01-C**

**Issuance Date:**

**Expiration Date:**

In accordance with the HAR, Title II, Chapter 60.1, Air Pollution Control, the permittee shall report to the Department of Health and U.S. EPA, Region 9 the following information semi-annually:

**(Make Copies for Additional Use)**

For Period: \_\_\_\_\_ Date: \_\_\_\_\_

Facility Name: \_\_\_\_\_

**I certify that I have knowledge of the facts herein set forth, that the same are true, accurate and complete to the best of my knowledge and belief, and that all information not identified by me as confidential in nature shall be treated by the Department of Health as public record.**

Responsible Official and Title (Print): \_\_\_\_\_

Responsible Official (Signature): \_\_\_\_\_

1. Report true vapor pressure exceedances above 11 psia for the semi-annual reporting period:

Tank No.	True Vapor Pressure (psia)	How Determined	Type of Fuel Stored	Period of Exceedance	Storage Temperature (°F)

2. Report a summary of tank inspection for the semi-annual reporting period:

Tank No.	Inspection Date	Deficiencies/Defects	Date and Repair Made	Date Tank was Last Emptied
		Description		

3. Attach information specified in 40 CFR §60.115b(b) for the semi-annual reporting period as applicable.
4. Attach information specified in 40 CFR §63.1066 for the semi-annual reporting period as applicable.

**PROPOSED**

**MONITORING REPORT FORM  
MARINE VESSEL LOADING DOCK  
COVERED SOURCE PERMIT NO. 0078-01-C  
(PAGE 1 OF 3)**

**Issuance Date:** \_\_\_\_\_

**Expiration Date:** \_\_\_\_\_

In accordance with the HAR, Title 11, Chapter 60.1, Air Pollution Control, the permittee shall report to the Department of Health the following information semi-annually:

**(Make Copies for Additional Use)**

For Period: \_\_\_\_\_

Date: \_\_\_\_\_

Facility Name: \_\_\_\_\_

Equipment Location: \_\_\_\_\_

**I certify that I have knowledge of the facts herein set forth, that the same are true, accurate and complete to the best of my knowledge and belief, and that all information not identified by me as confidential in nature shall be treated by the Department of Health as public record.**

Responsible Official and Title (print): \_\_\_\_\_

Responsible Official (Signature/phone): \_\_\_\_\_

1. Report the total combined motor gasoline, naphtha, aviation gasoline, and Dimate throughput for loading marine vessel storage tanks for the semi-annual reporting period:

Month	Product Throughput (barrels)				
	Motor Gasoline (w/o ethanol)	Naphtha	Aviation Gasoline	Dimate	Total Combined Throughput 12-Month Rolling Basis
January					
February					
March					
April					
May					
June					
July					
August					
September					
October					

**PROPOSED**

November					
December					

**MONITORING REPORT FORM  
MARINE VESSEL LOADING DOCK  
COVERED SOURCE PERMIT NO. 0078-01-C  
(CONTINUED, PAGE 2 OF 3)**

**Issuance Date:**

**Expiration Date:**

2. Report the total denatured ethanol throughput for loading marine vessel storage tanks for the semi-annual reporting period:

Month	Denatured Ethanol (barrels)	Total Denatured Ethanol Throughput 12-Month Rolling Basis (barrels)
January		
February		
March		
April		
May		
June		
July		
August		
September		
October		
November		
December		

**PROPOSED**

**MONITORING REPORT FORM  
MARINE VESSEL LOADING DOCK  
COVERED SOURCE PERMIT NO. 0078-01-C  
(CONTINUED, PAGE 3 OF 3)**

**Issuance Date:**

**Expiration Date:**

3. Report the total Jet-A throughput for loading marine vessel storage tanks for the semi-annual reporting period:

Month	Jet A (barrels)	Total Jet A Throughput 12-Month Rolling Basis (barrels)
January		
February		
March		
April		
May		
June		
July		
August		
September		
October		
November		
December		



**PROPOSED**

--	--	--	--