

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

Facility Equipment and Requirements (Section D)

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application number	Permit number	Equipment description
G01840	P41684	SPRAY BOOTH PAINT AND SOLVENT
193942	D15060	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL
193946	D10247	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
193947	D10248	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
193948	D10249	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
193949	D10250	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
193950	D10251	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
193951	D10252	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
333662	F10776	IC ENGINE (51-500 HP) NON-EMERGENCY PORTABLE NON-RENTAL DIESEL
417691	F64460	IC ENGINE (51-500 HP) EMERGENCY FIRE FIGHTING – DIESEL
431843	F70563	IC ENGINE (51-500 HP) EMERGENCY FIRE FIGHTING – DIESEL
467491	F94158	IC ENGINE (51-500 HP) EMERGENCY FIRE FIGHTING – DIESEL
487973	G3214	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL
491292	N24749	GASOLINE STORAGE AND DISPENSING EQUIPMENT
492405	G3209	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL
496061	G3544	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501193	Permit to Construct/Operate	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

501194	Permit to Construct/Operate	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501195	Permit to Construct/Operate	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501196	Permit to Construct/Operate	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501197	Permit to Construct/Operate	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501198	Permit to Construct/Operate	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501199	Permit to Construct/Operate	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGELMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]

2. THE OPERATOR SHALL NOT PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT AS SUPPLIED BY THE SUPPLIER.
[RULE 431.2]

3. THE OPERATOR SHALL NOT USE NATURAL GAS CONTAINING SULFUR COMPOUNDS, CALCULATED AS H₂S, IN EXCESS OF 16 PPMV. THE OPERATOR SHALL NOT USE OR SELL GASEOUS FUEL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 40 PPMV CALCULATED AS HYDROGEN SULFIDE AVERAGED OVER FOUR HOURS.
[RULE 431.1]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. P41684
A/N G01840

Equipment Description:

SPRAY BOOTH, BINKS, MODEL NO. FF-10-7-T, FLOOR FILTER TYPE, 10'-0" W. X 7'-0" L. X 9'-8" H., WITH A 1-HP EXHAUST FAN.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
3. THIS SPRAY BOOTH SHALL NOT BE OPERATED UNLESS ALL EXHAUST AIR PASSES THROUGH FILTER MEDIA AT LEAST TWO INCHES THICK.
[RULE 1303(a)(1)-BACT]
4. A GAUGE SHALL BE INSTALLED AND MAINTAINED TO INDICATE, IN INCHES OF WATER, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE EXHAUST FILTERS. IN OPERATION, THE PRESSURE DIFFERENTIAL SHALL NOT EXCEED 0.25 INCH OF WATER.
[RULE 1303(a)(1)-BACT]
5. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 1107, 1136, 1145 AND 1171.
[RULE 1107, RULE 1136, RULE 1145, RULE 1171]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM A WEEKLY INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
 - A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
 - B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
 - C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.
[RULE 3004 (a)(4)]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

7. THE OPERATOR SHALL DETERMINE AND RECORD THE PRESSURE DROP ACROSS THE FILTER MEDIA ONCE EVERY WEEK.
[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- VOC: RULE 109
 - VOC: RULE 1107, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1136, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1145, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 481
 - PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. D15060
A/N 193942

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 4BT3.9, 4 CYLINDERS, FOUR CYCLE, TURBOCHARGED, 86 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304 (a)(4)-MODELING AND OFFSET, RULE 1470]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]
6. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.
[RULE 1470, RULE 431.2]
7. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1470, RULE 431.2]

Periodic Monitoring:

8. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
 PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
 PM: RULE 1470

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. D10247
A/N 193946

Equipment Description:

BOILER, BRYAN, SECTIONAL TYPE, MODEL NO. 24C-23, SERIAL NO. ZX25735, RATED AT 2,310,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A BRYAN GAS BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]

Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. D10248
A/N 193947

Equipment Description:

BOILER, BRYAN, WATER TUBE TYPE, MODEL NO. CL-300-WG, SERIAL NO. 49402, RATED AT 3,000,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A BRYAN GAS BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]

Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. D10249
A/N 193948

Equipment Description:

BOILER, BRYAN, WATER TUBE TYPE, MODEL NO. CL-300-WG, SERIAL NO. 49404, RATED AT 3,000,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A BRYAN GAS BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]

Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. D10250
A/N 193949

Equipment Description:

BOILER NO. 2, NATIONAL, SECTIONAL TYPE, MODEL NO. 17-309, RATED AT 2,720,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A NATIONAL GAS BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]

Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

**Permit No. D10251
A/N 193950**

Equipment Description:

BOILER NO. 1, NATIONAL, SECTIONAL TYPE, MODEL NO. 17-309, RATED AT 2,720,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A NATIONAL GAS BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]

Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. D10252
A/N 193951

Equipment Description:

BOILER, BRYAN, WATER TUBE TYPE, MODEL NO. L36S-15, SERIAL NO. 49664, RATED AT 2,450,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A BRYAN GAS BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]

Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. F10776
A/N 333662

Equipment Description:

PORTABLE INTERNAL COMBUSTION ENGINE, JOHN DEERE, MODEL NO. SERIES 300, DIESEL-FUELED, NATURALLY ASPIRATED, 4 CYLINDERS, 78 BHP, COMPRESSOR DRIVER FOR A JACKHAMMER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED FOR MORE THAN 12 MONTHS IN ANY ONE YEAR AT ANY ONE LOCATION IN THE DISTRICT.
[RULE 1110.2]

Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
NOx: 770 PPM, RULE 1110.2
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. F64460
A/N 417691

Equipment Description:

(located at the Technology Bldg.)

INTERNAL COMBUSTION ENGINE, CLARKE, DIESEL-FUELED, EMERGENCY FIRE PUMP DRIVER, MODEL NO. VMFP-L6HR, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, FOUR CYCLE, 160 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION OF THIS ENGINE. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]
7. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

- [RULE 1470, RULE 431.2]
8. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1470, RULE 431.2]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. F70563
A/N 431843

Equipment Description:

(located at Bldg. G-3)

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY FIRE PUMP DRIVER, MODEL NO. 6BT5.9-G6, SERIAL NO. 45879748, TURBOCHARGED, 6 CYLINDERS, FOUR CYCLE, 113 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING. THE ANNUAL HOURS OF OPERATION FOR MAINTENANCE AND TESTING SHALL BE REDUCED TO NO MORE THAN 30 HOURS PER YEAR BY JANUARY 1, 2006 AS REQUIRED IN RULE 1470(C)(3).
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION OF THIS ENGINE. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

7. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.
[RULE 1470, RULE 431.2]
8. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1470, RULE 431.2]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. F94158
A/N 467491

Equipment Description:

(located at the E-1 Bldg.)

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY FIRE PUMP DRIVER, MODEL NO. C-9 DITA, SERIAL NO. CLJ03854, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, 4-CYCLE, 275 BHP, EQUIPPED WITH A DIESEL PARTICULATE FILTER, CLEAN AIR SYSTEMS, CLEAN AIR PERMIT FILTER AND A HIBACK DATA LOGGING AND ALARM SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTING ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. THIS ENGINE SHALL NOT BE OPERATED FOR NON-EMERGENCY USE BETWEEN THE HOURS OF 7:30 A.M. AND 3:30 P.M. ON DAYS WHEN SCHOOL IS IN SESSION.
[RULE 1470]
6. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS ITS EXHAUST IS VENTED TO A DIESEL PARTICULATE FILTER SYSTEM WHICH IS IN FULL OPERATION AND IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 1303(a)(1)-BACT]
7. THE OPERATOR SHALL OPERATE THE DIESEL PARTICULATE FILTER SYSTEM ONLY WITH AN OPERATIONAL HIBACK DATA LOGGING AND ALARM SYSTEM.
[RULE 1303(a)(1)-BACT]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

8. THE HIBACK LOGGING AND ALARM SYSTEM SHALL BE PROGRAMMED TO INTERFACE WITH THE ENGINE CONTROL SYSTEM TO AUTOMATICALLY SHUT THE ENGINE DOWN OR SWITCH IT TO POWER DE-RATING MODE WHENEVER THE BACKPRESSURE OF THE DIESEL PARTICULATE FILTER SYSTEM EXCEEDS THE MAXIMUM BACKPRESSURE SETTING OF 40 INCHES OF WATER.
[RULE 1303(a)(1)-BACT]
9. DURING MAINTENANCE AND PERFORMANCE TESTING, THE FIRE PUMP SHALL BE OPERATED WITH A WATER FLOWRATE OF AT LEAST 300 GAL/MIN.
[RULE 1303(a)(1)-BACT]
10. THE OPERATOR SHALL KEEP MONTHLY RECORDS OF TEMPERATURE, PRESSURE, DATE AND TIME FOR THE DUTY CYCLE OF THE ENGINE AS DOWNLOADED FROM THE HIBACK LOGGING SYSTEM. THE OPERATOR SHALL ALSO RECORD THE FLOW RATE OF WATER, IN GAL/MIN, TO THE FIRE PUMP FOR THIS DUTY CYCLE. THESE MONTHLY RECORDS SHALL BE KEPT IN A FORMAT APPROVED BY THE EXECUTIVE OFFICER AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS. THE RECORDS SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a)(1)-BACT]
11. THE OPERATOR SHALL MANUALLY TEST THE LED ALARM SYSTEM FOLLOWING THE PROCEDURES DESCRIBED IN THE MANUFACTURER'S INSTRUCTION MANUAL "TESTING THE SYSTEM WITH THE OPTIONAL TEST KIT". THE TEST SHALL BE CONDUCTED WITHIN SIX MONTHS FROM THE DATE OF THE ISSUANCE OF THIS PERMIT AND ANNUALLY THEREAFTER. THE TEST RECORDS SHALL BE KEPT ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a)(1)-BACT]
12. THE OPERATOR SHALL REGENERATE THE DIESEL PARTICULATE FILTER AFTER EVERY 24 COLD ENGINE START-UPS OR WHENEVER A "YELLOW" WARNING SIGNAL IS RECEIVED FROM THE HIBACK ALARM SYSTEM, WHICHEVER OCCURS FIRST. IN ORDER TO ACHIEVE FILTER REGENERATION, THE OPERATOR SHALL RUN THE ENGINE UNTIL THE EXHAUST TEMPERATURE EXCEEDS 572 DEGREES FAHRENHEIT AND THE BACKPRESSURE MONITORING SYSTEM INDICATES A NORMAL BACKPRESSURE READING.
[RULE 1303(a)(1)-BACT]
13. AFTER EVERY 5,000 HOURS OF NORMAL ENGINE OPERATION (EXCLUDING IDLING SESSIONS), THE OPERATOR SHALL INSPECT THE INTEGRITY OF THE FILTER AND, IF NECESSARY, REPLACE IT.
[RULE 1303(a)(1)-BACT]
14. THE OPERATOR SHALL KEEP RECORDS OF PARTICULATE FILTER INSPECTIONS, REPLACEMENTS AND MANUAL REGENERATIONS. THE OPERATOR SHALL MAINTAIN THESE RECORDS FOR A MINIMUM OF FIVE YEARS AND MAKE THEM AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a)(1)-BACT]
15. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. MAINTENANCE AND TESTING HOURS

C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

16. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]
17. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.
[RULE 1470, RULE 431.2]
18. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1470, RULE 431.2]

Emissions And Requirements:

19. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. G3214
A/N 487973

Equipment Description:

[located at Parking Structure 3]

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. QSB5-G3, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, 145 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING, AND NO MORE THAN 4.2 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING .
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1470]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

7. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS :

A. EMERGENCY USE

B. MAINTENANCE AND TESTING

C. OTHERS (SPECIFY)

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READINGS (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.

[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG :

A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND

B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

9. ENGINE OPERATION LOGS SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

[RULE 1470]

10. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.

[RULE 1470, RULE 1472]

11. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.

[RULE 1470, RULE 431.2]

12. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST

[RULE 1470, RULE 431.2]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO OPERATE

Permit No. N24749
A/N 491292

Equipment Description:

Fuel Storage and Dispensing Facility Consisting of:

- 1) 1 - GASOLINE BELLOWS-LESS NOZZLE DISPENSING 1 PRODUCT, EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM, HEALY PHASE II ENHANCED VAPOR RECOVERY (EVR) SYSTEM NOT INCLUDING ISD (VR-201-I).
- 2) 1 - GASOLINE UNDERGROUND STORAGE TANK, 6,000-GALLON CAPACITY, EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM OPW (VR-102-D/I), 1 METHANOL COMPATIBLE.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT WAS ISSUED, UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. ALL PERMIT CONDITIONS APPLICABLE TO THE EQUIPMENT DESCRIBED IN THE PREVIOUS PERMIT TO OPERATE N14836 SHALL REMAIN IN EFFECT UNTIL THE NEW OR MODIFIED EQUIPMENT IS CONSTRUCTED AND OPERATED AS DESCRIBED IN THIS NEW PERMIT. THIS PERMIT TO CONSTRUCT/OPERATE SHALL BECOME INVALID IF THE MODIFICATION AS DESCRIBED IN THE EQUIPMENT DESCRIPTION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE. IF THE MODIFICATION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE OF THE PERMIT, A WRITTEN REQUEST SHALL BE SUBMITTED TO THE AQMD (ATTENTION: RANDY MATSUYAMA) TO REINSTATE THE PREVIOUSLY INACTIVATED PERMIT TO OPERATE. A NEW APPLICATION SHALL BE FILED IF THERE ARE PLANS TO CONTINUE WITH THE MODIFICATION. FURTHERMORE, THIS CONDITION DOES NOT ALLOW ANY TIME EXTENSIONS TO ANY MODIFICATIONS REQUIRED BY THE CALIFORNIA AIR RESOURCES BOARD OR AQMD.
[RULE 203]
4. EXCEPT FOR DIESEL TRANSFERS, PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS.
[RULE 461, RULE 1303(a)(1)-BACT]
5. EXCEPT FOR DIESEL TRANSFERS, PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES, AS DEFINED IN RULE 461.

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

[RULE 461, RULE 1303(a)(1)-BACT]

6. ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS.
[RULE 461, RULE 1303(a)(1)-BACT]
7. THE DISTRICT AT ITS DISCRETION MAY WISH TO WITNESS THE INSTALLATION AND/OR PERFORMANCE TESTING OF THE HEALY PHASE II EVR SYSTEM NOT INCLUDING ISD. AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO THE INSTALLATION AND PERFORMANCE TESTING OF THE HEALY PHASE II EVR SYSTEM NOT INCLUDING ISD, THE APPLICANT SHALL NOTIFY THE AQMD AT TELEPHONE NUMBER (866) 770-9140.
[RULE 461]
8. NEW EQUIPMENT INSTALLATIONS AND SUBSEQUENT SERVICE AND REPAIRS FOR ANY CERTIFIED COMPONENT FOR WHICH THIS PERMIT WAS ISSUED, SHALL ONLY BE PERFORMED BY A CURRENT AND CERTIFIED PERSON WHO HAS SUCCESSFULLY COMPLETED THE MANUFACTURER'S TRAINING COURSE AND APPROPRIATE INTERNATIONAL CODE COUNCIL (ICC) CERTIFICATION. COMPLETION OF ANY AQMD TRAINING COURSE DOES NOT CONSTITUTE AS A SUBSTITUTE FOR THIS REQUIREMENT. PROOF OF SUCCESSFUL COMPLETION OF ANY MANUFACTURER TRAINING COURSE SHALL BE WITH THE MANUFACTURER.
[RULE 461]
9. AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO BACK-FILLING ANY UNDERGROUND STORAGE TANK OR PIPING, THE SCAQMD SHALL BE NOTIFIED BY E-MAIL AT R461BACKFILL@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTORS; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE BACK-FILLING PROCEDURE. THE BACK-FILLING PROCEDURE SHALL NOT COMMENCE UNTIL INSPECTED BY A DISTRICT REPRESENTATIVE.
[RULE 461]
10. DEPENDING ON THE SYSTEM CONFIGURATION, A LEAK RATE TEST OF DROP TUBE/DRAIN VALVE ASSEMBLY SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF BOTH THE DROP TUBE AND DRAIN VALVE SEAL OR A LEAK RATE TEST OF DROP TUBE OVERFILL PREVENTION DEVICE AND DRAIN VALVE SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF THE DROP TUBE OVERFILL PREVENTION DEVICE AND THE PRESSURE INTEGRITY OF THE SPILL CONTAINER DRAIN VALVE. EITHER TEST SHALL BE CONDUCTED AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH TEST PROCEDURE METHOD TP-201.1C (OCTOBER 8, 2003) OR TP-201.1D (OCTOBER 8, 2003), RESPECTIVELY. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]
11. A LEAK RATE AND CRACKING PRESSURE TEST OF PRESSURE/VACUUM RELIEF VENT VALVES SHALL BE CONDUCTED WITHIN TEN DAYS (10) AFTER THE START OF OPERATION OF THE OPV PHASE I EVR EQUIPMENT AND AT LEAST ONCE EVERY THREE (3) YEARS THEREAFTER TO DETERMINE THE PRESSURE AND VACUUM AT WHICH THE PRESSURE/VACUUM VENT VALVE

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

ACTUATES, AND TO DETERMINE THE VOLUMETRIC LEAK RATE AT A GIVEN PRESSURE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD TP-201.1E (OCTOBER 8, 2003). RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST. THIS TEST RESULT SHALL BE KEPT ON SITE FOR THREE (3) YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

[RULE 461]

12. A STATIC TORQUE TEST OF ROTATABLE PHASE I ADAPTORS SHALL BE CONDUCTED TO QUANTIFY THE AMOUNT OF STATIC TORQUE REQUIRED TO START THE ROTATION OF THE ROTATABLE PHASE I ADAPTORS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD OUTLINED IN TP-201.1B (OCTOBER 8, 2003) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

[RULE 461]

13. THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED, OPERATED, AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE RISER, AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURE DESCRIBED BY THE CALIFORNIA AIR RESOURCES BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED:

NITROGEN FLOWRATES
(CFH)
60

DYNAMIC BACK PRESSURE
(INCHES OF WATER)
0.50

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP-201.4, METHODOLOGY 4 AND 6 (JULY 3, 2002); AS A PERFORMANCE TEST. THIS TEST SHALL BE A ONE-TIME TEST AND THE RESULTS KEPT PERMANENTLY ON SITE. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TESTS.

[RULE 461]

14. A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES, ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.3 (MARCH 17, 1999) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

[RULE 461]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

15. A STATIC PRESSURE PERFORMANCE TEST FOR THE HEALY CLEAN AIR SEPARATOR USING BOTH THE VACUUM DECAY PROCEDURE AND THE POSITIVE PRESSURE PROCEDURE SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TIGHTNESS OF THE TANK PRESSURE MANAGEMENT SYSTEM. THESE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 4 OF CARB EXECUTIVE ORDER VR-201-I AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]
16. A VAPOR TO LIQUID VOLUME RATIO TEST SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TO LIQUID (V/L) VOLUMETRIC RATIO OF THE HEALY CLEAN AIR SEPARATOR SYSTEM. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 5 OF CARB EXECUTIVE ORDER VR-201-I AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]
17. A NOZZLE BAG TEST SHALL BE CONDUCTED ON THE HEALY PHASE II EVR NOZZLES TO VERIFY THE INTEGRITY OF THE VAPOR VALVE. THE TEST SHALL BE CONDUCTED ON ANY NEWLY INSTALLED OR REPLACED HEALY PHASE II EVR NOZZLES AND IN ACCORDANCE WITH EXHIBIT 7 OF CARB EXECUTIVE ORDER VR-201-I. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]
18. THE STATIC PRESSURE LEAK DECAY TEST TP-201.3, SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 8 OF CARB EXECUTIVE ORDER VR-201-I. VERIFICATION OF COMPLETING EACH STEP AS OUTLINED SHALL BE DOCUMENTED BY SUBMITTING A COPY OF EXHIBIT 8 TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]
19. UNLESS AQMD RULE 461 REQUIRES A MORE FREQUENT TESTING OR INSPECTION SCHEDULE, THE OWNER/OPERATOR SHALL BE RESPONSIBLE TO PERFORM THE SCHEDULED WEEKLY, QUARTERLY, AND ANNUAL INSPECTIONS AS OUTLINED IN THE ARB APPROVED INSTALLATION, OPERATION, AND MAINTENANCE MANUAL FOR THE HEALY PHASE II EVR SYSTEMS, AS WELL AS ALL THE REQUIRED VAPOR RECOVERY SYSTEM TESTS AS PER THE CURRENT AND APPROPRIATE ARB EXECUTIVE ORDER.
[RULE 461]
20. A CARB CERTIFIED PHASE II ENHANCED VAPOR RECOVERY SYSTEM SHALL BE FULLY PERMITTED, INSTALLED, AND TESTED BY OCTOBER 1, 2008. FAILURE TO ACHIEVE THIS CONDITION BY OCTOBER 1, 2008, SHALL RESULT IN THE OWNER/OPERATOR TO FILE A DISTRICT APPROVED COMPLIANCE PLAN OUTLINING THE INCREMENTS OF PROGRESS TOWARDS COMPLETING THE INSTALLATION OF A CARB CERTIFIED PHASE II ENHANCED VAPOR RECOVERY SYSTEM BY APRIL 1, 2009.
[RULE 461]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

21. IF THE OWNER/OPERATOR PLANS TO PERMANENTLY CEASE ALL GASOLINE DISPENSING OPERATIONS BEFORE APRIL 1, 2009, A COMPLIANCE PLAN SHALL BE FILED DECLARING TO IRREVOCABLY SURRENDER THEIR PERMIT TO OPERATE.
[RULE 461]
22. THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO ANY OF THE ABOVE MENTIONED TESTING REQUIREMENTS. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE TESTS TO BE PERFORMED.
[RULE 461]
23. THE TESTING FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT.
[RULE 461]
24. ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE FOR FIVE YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.
[RULE 461]
25. SHOULD THE FACILITY DISPENSE MORE THAN 600,000 GALLONS OF GASOLINE PER CALENDAR YEAR AND IF THE FACILITY UNDERGOES A MAJOR MODIFICATION AS DEFINED BY CARB'S ADVISORY LETTER NUMBER 336, "ENHANCED VAPOR RECOVERY IMPLEMENTATION UPDATE" DATED APRIL 15, 2005; THE OPERATOR SHALL IMMEDIATELY CEASE ALL GASOLINE DISPENSING OPERATIONS AND FILE AN APPLICATION FOR A NEW PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM. GASOLINE DISPENSING OPERATIONS SHALL NOT RESUME UNTIL THE ISD SYSTEM HAS BEEN GRANTED A PERMIT TO CONSTRUCT/OPERATE AND HAS BEEN FULLY INSTALLED, TESTED, AND OPERATIVE.
[RULE 461]
26. SHOULD THE FACILITY DISPENSE MORE THAN 600,000 GALLONS OF GASOLINE IN ANY CALENDAR YEAR AND IF THE FACILITY DOES NOT UNDERGO A MAJOR MODIFICATION AS DEFINED BY CARB'S ADVISORY LETTER NUMBER 336, "ENHANCED VAPOR RECOVERY IMPLEMENTATION UPDATE" DATED APRIL 15, 2005; THE OPERATOR SHALL FILE AN APPLICATION FOR A NEW PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM. THE ISD SYSTEM SHALL BE FULLY INSTALLED, TESTED, AND OPERATIVE BASED ON THE FOLLOWING TABLE:

<u>GASOLINE THROUGHPUT PER CALENDAR YEAR</u>	<u>DATE</u>
GREATER THAN 1.8 MILLION GALLONS	SEPTEMBER 1, 2009
BETWEEN 600,000 AND 1.8 MILLION GALLONS	SEPTEMBER 1, 2010

[RULE 461]

Periodic Monitoring:

27. THE OPERATOR SHALL HAVE A PERSON THAT HAS BEEN TRAINED IN ACCORDANCE WITH RULE 461(d)(4) CONDUCT A SEMI-ANNUAL INSPECTION OF THE GASOLINE TRANSFER AND

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

DISPENSING EQUIPMENT. THE FIRST INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT B, THE SECOND INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT C, AND THE SUBSEQUENT INSPECTIONS SHALL ALTERNATE PROTOCOLS. THE OPERATOR SHALL KEEP RECORDS OF THE INSPECTION AND THE REPAIRS IN ACCORDANCE TO RULE 461 AND SECTION K OF THIS PERMIT.

[RULE 3004 (a)(4)]

Emissions And Requirements:

28. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 461
VOC: RULE 1170

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO CONSTRUCT/OPERATE

**Permit No. G3209
A/N 492405**

Equipment Description:

[located at the Performing and Fine Arts Complex]

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6063-HV35, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, 550 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING, AND NO MORE THAN 4.2 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING .
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1470]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

7. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS :

A. EMERGENCY USE

B. MAINTENANCE AND TESTING

C. OTHERS (SPECIFY)

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READINGS (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.

[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG :

A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND

B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

9. ENGINE OPERATION LOGS SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

[RULE 1470]

10. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.

[RULE 1470, RULE 1472]

11. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.

[RULE 1470, RULE 431.2]

12. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST

[RULE 1470, RULE 431.2]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO CONSTRUCT/OPERATE

**Permit No. G3544
A/N 496061**

Equipment Description:

(Located at Bldg. E-9)

BOILER PARKER, WATER TUBE TYPE, MODEL NO. 105-90LR, RATED AT 3,780,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE PARKER PREMIX METAL FIBER LOW NOX BURNER, MODEL NO. PB-36LN.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O₂ ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR .
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
6. THIS BOILER SHALL USE NO MORE THAN 6,900 THERMS (655,000 CU. FT.) OF NATURAL GAS FUEL PER MONTH.
[RULE 1303(b)(2)-OFFSET]
7. A NON-RESETTING TOTALIZING FUEL METER SHALL BE INSTALLED IN THE FUEL SUPPLY LINE TO THIS BOILER AND MAINTAINED IN GOOD OPERATING CONDITION.
[RULE 1303(b)(2)-OFFSET]
8. RECORDS OF MONTHLY NATURAL GAS FUEL USAGE FOR THIS BOILER SHALL BE PREPARED, SHALL BE RETAINED ON SITE FOR FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.
[RULE 1303(b)(2)-OFFSET]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

9. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:
- A. SOURCE TESTING SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.
 - B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NO_x AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.
 - C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE FIRING RATES.
 - D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT.
 - E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE HEATER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:
 - I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
 - II. THE FIRING RATES, IN BTU PER HOUR.
 - III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
 - IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
 - V. THE FUEL FLOW RATE.
 - F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.
 - G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- NO_x: 30 PPMV, RULE 1146.1
 - NO_x: 12 PPMV, RULE 1303(a)(1)-BACT
 - CO: 400 PPMV, RULE 1146.1
 - CO: 100 PPMV, RULE 1303(a)(1)-BACT

**FACILITY PERMIT TO OPERATE
EAST LOS ANGELES COLLEGE**

CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO CONSTRUCT/OPERATE

Permit No.
A/N 501193

Equipment Description:

(Located at the Central Plant)

BOILER NO. 1, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO_x BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O₂ ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR .
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂ AND CORRECTED TO 3% O₂ ON A DRY BASIS, OR 0.011 LB NO_x PER MILLION BTU OF HEAT INPUT.
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:

A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1
NOx: 12 PPMV, RULE 1303(a)(1)-BACT
CO: 400 PPMV, RULE 1146.1
CO: 100 PPMV, RULE 1303(a)(1)-BACT
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO CONSTRUCT/OPERATE

Permit No.
A/N 501194

Equipment Description:

(Located at the Central Plant)

BOILER NO. 2, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO_x BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O₂ ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR .
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂ AND CORRECTED TO 3% O₂ ON A DRY BASIS, OR 0.011 LB NO_x PER MILLION BTU OF HEAT INPUT.
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:
 - A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1
NOx: 12 PPMV, RULE 1303(a)(1)-BACT
CO: 400 PPMV, RULE 1146.1
CO: 100 PPMV, RULE 1303(a)(1)-BACT
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO CONSTRUCT/OPERATE

Permit No.
A/N 501195

Equipment Description:

(Located at the Central Plant)

BOILER NO. 3, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO_x BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O₂ ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR .
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂ AND CORRECTED TO 3% O₂ ON A DRY BASIS, OR 0.011 LB NO_x PER MILLION BTU OF HEAT INPUT.
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:
 - A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1
NOx: 12 PPMV, RULE 1303(a)(1)-BACT
CO: 400 PPMV, RULE 1146.1
CO: 100 PPMV, RULE 1303(a)(1)-BACT
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO CONSTRUCT/OPERATE

Permit No.
A/N 501196

Equipment Description:

(Located at the Central Plant)

BOILER NO. 4, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO_x BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O₂ ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR .
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂ AND CORRECTED TO 3% O₂ ON A DRY BASIS, OR 0.011 LB NO_x PER MILLION BTU OF HEAT INPUT.
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:

A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1
NOx: 12 PPMV, RULE 1303(a)(1)-BACT
CO: 400 PPMV, RULE 1146.1
CO: 100 PPMV, RULE 1303(a)(1)-BACT
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO CONSTRUCT/OPERATE

Permit No.
A/N 501197

Equipment Description:

(Located at the Central Plant)

BOILER NO. 5, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO_x BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O₂ ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR .
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂ AND CORRECTED TO 3% O₂ ON A DRY BASIS, OR 0.011 LB NO_x PER MILLION BTU OF HEAT INPUT.
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:
 - A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1
NOx: 12 PPMV, RULE 1303(a)(1)-BACT
CO: 400 PPMV, RULE 1146.1
CO: 100 PPMV, RULE 1303(a)(1)-BACT
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO CONSTRUCT/OPERATE

Permit No.
A/N 501198

Equipment Description:

(Located at the Central Plant)

BOILER NO. 6, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO_x BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O₂ ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR .
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂ AND CORRECTED TO 3% O₂ ON A DRY BASIS, OR 0.011 LB NO_x PER MILLION BTU OF HEAT INPUT.
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:
 - A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1
NOx: 12 PPMV, RULE 1303(a)(1)-BACT
CO: 400 PPMV, RULE 1146.1
CO: 100 PPMV, RULE 1303(a)(1)-BACT
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

PERMIT TO CONSTRUCT/OPERATE

**Permit No.
A/N 501199**

Equipment Description:

(located at the Central Plant)

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. C-9, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, 4-CYCLE, 398 BHP, EQUIPPED WITH A DIESEL PARTICULATE FILTER, CLEAN AIR SYSTEMS, CLEAN AIRPERMIT FILTER, AND A HIBACK DATA LOGGING AND ALARM SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING, AND NO MORE THAN 4.2 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING .
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1470]

7. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS ITS EXHAUST IS VENTED TO A DIESEL PARTICULATE FILTER SYSTEM WHICH IS IN FULL OPERATION AND IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 1470]
8. THE OPERATOR SHALL OPERATE THE DIESEL PARTICULATE FILTER SYSTEM ONLY WITH AN OPERATIONAL HIBACK DATA LOGGING AND ALARM SYSTEM.
[RULE 1470]
9. THE HIBACK LOGGING AND ALARM SYSTEM SHALL BE PROGRAMMED TO INTERFACE WITH THE ENGINE CONTROL SYSTEM TO AUTOMATICALLY SHUT THE ENGINE DOWN OR SWITCH IT TO POWER DE-RATING MODE WHENEVER THE BACKPRESSURE OF THE DIESEL PARTICULATE FILTER SYSTEM EXCEEDS THE MAXIMUM BACKPRESSURE SETTING OF 24 INCHES OF WATER.
[RULE 1470]
10. THE TEMPERATURE OF THE ENGINE EXHAUST GAS AT THE INLET TO THE DIESEL PARTICULATE FILTER SYSTEM SHALL BE GREATER THAN OR EQUAL TO 300 DEGREES CELSIUS (572 DEGREES FAHRENHEIT) FOR 30% OF THE OPERATING TIME.
[RULE 1470]
11. THE OPERATOR SHALL KEEP MONTHLY RECORDS OF TEMPERATURE, PRESSURE, DATE AND TIME FOR THE DUTY CYCLE OF THE ENGINE AS DOWNLOADED FROM THE HIBACK LOGGING SYSTEM. THESE MONTHLY RECORDS SHALL BE KEPT IN A FORMAT APPROVED BY THE EXECUTIVE OFFICER AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS. THE RECORDS SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1470]
12. THE OPERATOR SHALL MANUALLY TEST THE LED ALARM SYSTEM FOLLOWING THE PROCEDURES DESCRIBED IN THE MANUFACTURER'S INSTRUCTION MANUAL "TESTING THE SYSTEM WITH THE OPTIONAL TEST KIT". THE TEST SHALL BE CONDUCTED WITHIN SIX MONTHS FROM THE DATE OF THE ISSUANCE OF THIS PERMIT AND ANNUALLY THEREAFTER. THE TEST RECORDS SHALL BE KEPT ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1470]
13. THE OPERATOR SHALL REGENERATE THE DIESEL PARTICULATE FILTER AFTER EVERY 24 COLD ENGINE START-UPS OR WHENEVER A "YELLOW" WARNING SIGNAL IS RECEIVED FROM THE HIBACK ALARM SYSTEM, WHICHEVER OCCURS FIRST. IN ORDER TO ACHIEVE FILTER REGENERATION, THE OPERATOR SHALL RUN THE ENGINE UNTIL THE EXHAUST TEMPERATURE EXCEEDS 572 DEGREES FAHRENHEIT AND THE BACKPRESSURE MONITORING SYSTEM INDICATES A NORMAL BACKPRESSURE READING.
[RULE 1470]

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

14. AFTER EVERY 5,000 HOURS OF NORMAL ENGINE OPERATION (EXCLUDING IDLING SESSIONS), THE OPERATOR SHALL INSPECT THE INTEGRITY OF THE FILTER AND, IF NECESSARY, REPLACE IT.
[RULE 1470]
15. THE OPERATOR SHALL KEEP RECORDS OF PARTICULATE FILTER INSPECTIONS, REPLACEMENTS AND MANUAL REGENERATIONS. THE OPERATOR SHALL MAINTAIN THESE RECORDS FOR A MINIMUM OF FIVE YEARS AND MAKE THEM AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1470]
16. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS :
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHERS (SPECIFY)

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READINGS (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
17. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG :
 - A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
18. ENGINE OPERATION LOGS SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.
[RULE 1470]
19. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470 AND 1472.
[RULE 1470, RULE 1472]
20. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.
[RULE 1470, RULE 431.2]
21. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

[RULE 1470, RULE 431.2]

Emissions And Requirements:

22. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF:

- A. COATING TYPE,
- B. VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS,
- C. VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF:

- A. COATING TYPE,
- B. VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS,
- C. VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.
[RULE 3004 (a) (4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, HAND WIPING OPERATIONS.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, BOILER, > 1 MMBTU/HR BUT < 2 MMBTU/HR.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409
NOx: 30 PPMV, RULE 1146.2
CO: 400 PPMV, RULE 1146.2
CO: 2000 PPMV, RULE 407

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, AIR CONDITIONING UNITS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
REFRIGERANT: RULE 1415
REFRIGERANT: 40CFR 82 SUBPART F

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERATION UNITS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT:	RULE 1415
REFRIGERANT:	40CFR 82 SUBPART F

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERANT RECOVERY AND/OR RECYCLING UNITS.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT: RULE 1415
REFRIGERANT: 40CFR 82 SUBPART F

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, PRINTING EQUIPMENT, LOW USE OR EMISSIONS, WITH RELATED COATING, LAMINATING AND DRYING EQUIPMENT.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1130, SEE APPENDIX B FOR EMISSION LIMITS

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, SPRAY COATING ENCLOSURES, < 8 FT3 INTERNAL VOLUME.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS