

<b>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</b>  <b>ENGINEERING AND COMPLIANCE DIVISION</b>  <b>PERMIT APPLICATION EVALUATION AND CALCULATIONS</b>	PAGES 1	PAGE 1
	APPL NO 513154	DATE 9/9/2011
	PROCESSED BY AS08	CHECKED BY

### TITLE V PERMIT (REV No. 07) EVALUATION

**Applicant's Name** Eastern Municipal Water District (EMWD)  
Temecula Valley Regional Water Reclamation Facility

**Mailing Address** 2270 Trumble Road  
P.O. Box 8300  
Perris, CA 92580-8300

**Equipment Location** 42565 Avenida Alvarado  
Temecula, CA 92590

**FACILITY ID 001703**  
**APPLICATION 513154- Title V Minor Permit Revision**  
**Background**

Eastern Municipal Water District (EMWD) A/N 513154 was submitted for Title V permit revision (07). Application 522637 was submitted for the installation of an emergency diesel engine used for electrical generation. The proposed equipment will be located at Eastern Municipal Water District Temecula Valley Regional Water Reclamation Facility (EMWD-TVRWRF) in Temecula. For additional information please refer to the attached evaluation prepared for the EPA review.

Note: Title V Revision 06 (A/N 508844) was issued June 21, 2011.

**Rules Evaluation**

Reg. XXX:  
The installation of a stationary emergency diesel fueled IC engines is considered a Title V Significant permit revision under Rule 3000(b)(31), since it results in new or additional NSPS or NESHAP requirements and will be subject to an EPA review (Rule 3003 (j)), even though the proposed cumulative emission increases of non-RECLAIM pollutants do not exceed the emissions in Table 5-4 of the Draft Title V TDG March 2005. A public notice is required. An EPA 45 day review and a public notice will be imposed. Compliance is expected.

**Conclusions and Recommendations**

A Permit to Construct is recommended for application 522637. A revised Title V permit is recommended after the completion of EPA review and public notice.