

FACILITY PERMIT TO OPERATE EASTERN MUNICIPAL WATER DISTRICT

PERMIT TO CONSTRUCT/OPERATE

Permit No. TBD
A/N 556766

Equipment Description:

FUEL STORAGE AND DISPENSING FACILITY CONSISTING OF:

1. 1 - GASOLINE NOZZLE DISPENSING 1 PRODUCT, EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM, BALANCE RETRACTOR.
2. 1 - DUAL COMPARTMENT ABOVEGROUND GASOLINE/DIESEL STORAGE TANK, CONVAULT AST (VR-301-E), RECTANGULAR, 11' - 3" L. X 8' - 0" W. X 5' - 6" H., 2,000 GALLON CAPACITY, CONSISTING OF:
 - A. ONE 1,000 GALLON GASOLINE COMPARTMENT, EQUIPPED WITH A HUSKY 5885 PRESSURE/VACUUM RELIEF VALVE (VR-301) OR SUBSEQUENT ARB APPROVED P/V RELIEF VALVE, AND A MORRISON BROTHERS PHASE I ENHANCED VAPOR RECOVERY (EVR) SYSTEM (VR-402-B OR SUBSEQUENT ARB APPROVED VR-402).
 - B. ONE 1,000 GALLON DIESEL COMPARTMENT, NOT EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM.

Conditions:

SECTION I: GENERAL CONDITIONS

1. OPERATION OF THIS EQUIPMENT SHALL BE IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT WAS ISSUED, UNLESS OTHERWISE NOTED BELOW.
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.

SECTION II: PHASE I VAPOR RECOVERY SYSTEM AND TESTING REQUIREMENTS

3. EXCEPT FOR DIESEL TRANSFERS, PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS.
4. IF ROTATABLE VAPOR ADAPTORS ARE INSTALLED, A STATIC TORQUE TEST OF ROTATABLE PHASE I ADAPTORS SHALL BE CONDUCTED TO QUANTIFY THE AMOUNT OF STATIC TORQUE REQUIRED TO START THE ROTATION OF THE ROTATABLE PHASE I ADAPTORS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD OUTLINED IN TP-201.1B (OCTOBER 8, 2003) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE SCAQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

FACILITY PERMIT TO OPERATE EASTERN MUNICIPAL WATER DISTRICT

5. A LEAK RATE AND CRACKING PRESSURE TEST OF PRESSURE/VACUUM RELIEF VENT VALVES SHALL BE CONDUCTED WITHIN TEN DAYS (10) AFTER THE START OF OPERATION OF THE PHASE I EVR EQUIPMENT AND AT LEAST ONCE EVERY THREE (3) YEARS THEREAFTER TO DETERMINE THE PRESSURE AND VACUUM AT WHICH THE PRESSURE/VACUUM VENT VALVE ACTUATES, AND TO DETERMINE THE VOLUMETRIC LEAK RATE AT A GIVEN PRESSURE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD TP-201.1E (OCTOBER 8, 2003). RESULTS SHALL BE SUBMITTED TO THE SCAQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST. THIS TEST RESULT SHALL BE KEPT ON SITE FOR THREE (3) YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

SECTION III: PHASE II VAPOR RECOVERY SYSTEM AND TESTING REQUIREMENTS

6. EXCEPT FOR DIESEL TRANSFERS, PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES, AS DEFINED IN RULE 461.
7. A STATIC PRESSURE PERFORMANCE TEST SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TIGHTNESS OF THE ABOVEGROUND STORAGE TANK. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE LATEST VERSION OF EXHIBIT 4 OF CARB EXECUTIVE ORDER VR-402, AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE SCAQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.
8. THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED, OPERATED, AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE SYSTEM INCLUDING NOZZLE, VAPOR HOSE, SWIVELS, AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURES DESCRIBED BY THE CALIFORNIA AIR RESOURCES BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED:

NITROGEN FLOWRATES (CFH)	DYNAMIC BACK PRESSURE (INCHES OF WATER)
60	0.35
80	0.62

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP-201.4 (JULY 3, 2002), METHODOLOGY 1 AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE SCAQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TESTS.

9. IF THE CARB EXECUTIVE ORDER REQUIRES THE INSTALLATION OF A LIQUID REMOVAL DEVICE, A LIQUID REMOVAL RATE TEST SHALL BE CONDUCTED TO DEMONSTRATE THE REMOVAL OF GASOLINE FROM THE VAPOR PASSAGE OF THE COAXIAL HOSE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.6 (APRIL 28, 2000) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE SCAQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

FACILITY PERMIT TO OPERATE EASTERN MUNICIPAL WATER DISTRICT

SECTION V: GENERAL REQUIREMENTS

10. ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS.
11. ALL PERMIT CONDITIONS APPLICABLE TO THE EQUIPMENT DESCRIBED IN THE PREVIOUS PERMIT TO OPERATE F41973 SHALL REMAIN IN EFFECT UNTIL THE NEW OR MODIFIED EQUIPMENT IS CONSTRUCTED AND OPERATED AS DESCRIBED IN THIS NEW PERMIT. THIS PERMIT TO CONSTRUCT/OPERATE SHALL BECOME INVALID IF THE MODIFICATION AS DESCRIBED IN THE EQUIPMENT DESCRIPTION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE. IF THE MODIFICATION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE OF THE PERMIT, A WRITTEN REQUEST SHALL BE SUBMITTED TO THE SCAQMD (ATTENTION: RANDY MATSUYAMA) TO REINSTATE THE PREVIOUSLY INACTIVATED PERMIT TO OPERATE. A NEW APPLICATION SHALL BE FILED IF THERE ARE PLANS TO CONTINUE WITH THE MODIFICATION. FURTHERMORE, THIS CONDITION DOES NOT ALLOW ANY TIME EXTENSIONS TO ANY MODIFICATIONS REQUIRED BY THE CALIFORNIA AIR RESOURCES BOARD OR SCAQMD.
12. NEW EQUIPMENT INSTALLATIONS AND SUBSEQUENT SERVICE AND REPAIRS FOR ANY CERTIFIED ENHANCED VAPOR RECOVERY COMPONENT FOR WHICH THIS PERMIT WAS ISSUED, SHALL ONLY BE PERFORMED BY A CURRENT AND CERTIFIED PERSON WHO HAS SUCCESSFULLY COMPLETED THE MANUFACTURER'S TRAINING COURSE AND APPROPRIATE INTERNATIONAL CODE COUNCIL (ICC) CERTIFICATION. COMPLETION OF ANY SCAQMD TRAINING COURSE DOES NOT CONSTITUTE AS A SUBSTITUTE FOR THIS REQUIREMENT. PROOF OF SUCCESSFUL COMPLETION OF ANY MANUFACTURER TRAINING COURSE SHALL BE WITH THE MANUFACTURER.
13. THE DISTRICT AT ITS DISCRETION MAY WISH TO WITNESS THE INSTALLATION AND/OR PERFORMANCE TESTING OF THE NEW VAPOR RECOVERY EQUIPMENT. AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO THE INSTALLATION OF THE EQUIPMENT AND ANY OF THE MENTIONED TESTING REQUIREMENTS IN THIS PERMIT, THE APPLICANT SHALL NOTIFY THE SCAQMD BY E-MAIL AT R461TESTING@AQMD.GOV. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE TESTS OR WORK TO BE PERFORMED.
14. UNLESS SCAQMD RULE 461 REQUIRES A MORE FREQUENT TESTING OR INSPECTION SCHEDULE, THE OWNER/OPERATOR SHALL BE RESPONSIBLE TO PERFORM THE INSPECTION SCHEDULE OUTLINED IN THE ARB APPROVED INSTALLATION, OPERATION, AND MAINTENANCE MANUAL FOR THE MORRISON BROS. PHASE I EVR SYSTEM, AS WELL AS ALL THE REQUIRED VAPOR RECOVERY SYSTEM TESTS AS PER THE CURRENT AND APPROPRIATE ARB EXECUTIVE ORDER.
15. AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO BACK-FILLING ANY UNDERGROUND PIPING, THE SCAQMD SHALL BE NOTIFIED BY E-MAIL AT R461BACKFILL@AQMD.GOV. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTORS; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE BACK-FILLING PROCEDURE. THE BACK-FILLING PROCEDURE SHALL NOT COMMENCE UNTIL INSPECTED BY A DISTRICT REPRESENTATIVE.

FACILITY PERMIT TO OPERATE EASTERN MUNICIPAL WATER DISTRICT

16. THE SCAQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO ANY OF THE ABOVE MENTIONED TESTING REQUIREMENTS. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE TESTS TO BE PERFORMED.
17. THE TESTING FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT.
18. A COPY OF THE PASS/FAIL TEST RESULTS SHALL BE SENT ELECTRONICALLY TO R461RESULTS72HOURS@AQMD.GOV WITHIN SEVENTY-TWO (72) HOURS AFTER EACH TEST IS CONDUCTED. FURTHERMORE, THE FINAL TEST RESULTS DEMONSTRATING COMPLIANCE SHALL BE SUBMITTED ELECTRONICALLY TO R461RESULTSWORKSHEETS@AQMD.GOV WITHIN FOURTEEN (14) CALENDAR DAYS FROM THE DATE WHEN ALL TESTS WERE PASSED. THE TEST REPORT SHALL INCLUDE AT A MINIMUM ALL THE REQUIRED RECORDS OF ALL TESTS PERFORMED, TEST DATA, CURRENT AQMD FACILITY ID NUMBER OF THE LOCATION BEING TESTED, THE EQUIPMENT PERMIT TO OPERATE OR APPLICATION NUMBER, THE SCAQMD ID NUMBER OF THE COMPANY PERFORMING THE TESTS, A STATEMENT WHETHER THE SYSTEM OR COMPONENT TESTED MEETS THE REQUIRED STANDARDS, AND THE NAME, SCAQMD TESTER ID NUMBER AND SIGNATURE OF THE PERSON RESPONSIBLE FOR CONDUCTING THE TESTS.
19. ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.
20. THE OPERATOR SHALL HAVE A PERSON THAT HAS BEEN TRAINED IN ACCORDANCE WITH RULE (461)(d)(5) CONDUCT AN ANNUAL INSPECTION IN ACCORDANCE WITH RULE 461(d)(1)(B) OF THE GASOLINE TRANSFER AND DISPENSING EQUIPMENT. THE INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT C. THE OPERATOR SHALL KEEP RECORDS OF THE INSPECTION AND THE REPAIRS IN ACCORDANCE WITH RULE 461 AND SECTION K OF THIS PERMIT.

SECTION VI: GASOLINE THROUGHPUT REQUIREMENTS

21. THE MAXIMUM QUANTITY OF GASOLINE DISPENSED FROM THE STORAGE TANKS AT THIS FACILITY SHALL NOT EXCEED 5,000 GALLONS IN ANY ONE CALENDAR MONTH NOR 60,000 GALLONS IN ANY ONE CALENDAR YEAR.
22. RECORDS OF MONTHLY AND ANNUAL FUEL DISPENSED SHALL BE RETAINED ON SITE FOR TWO YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.
23. THE OWNER/OPERATOR SHALL SUBMIT THE FACILITY'S MONTHLY GASOLINE THROUGHPUT DATA FOR THE PREVIOUS CALENDAR YEAR TO THE EXECUTIVE OFFICER ON OR BEFORE MARCH 1 FOLLOWING EACH CALENDAR YEAR.