



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

May 21, 2009
Via Electronic Submittal

Mr. Gerardo Rios
U.S. EPA, Region IX
Mail Stop A-5-2
75 Hawthorne Street
San Francisco, CA 94105

Re: Proposed Minor Revision to Title V Permit (A/N 496458) for MM Prima Deshecha Energy, LLC (ID# 117297)

Dear Mr. Rios:

Enclosed for your 45-day review are the proposed revisions to the Title V Permit for MM Prima Deshecha Energy, LLC, located at 32250 La Pata Road, San Juan Capistrano, CA 92675. This revision is considered to be a minor revision and a public notice is not required. As agreed, only the relevant portions of the revised permit are enclosed as shown below. Additional information will be provided upon request.

SECTION D: PERMITS TO OPERATE (Change of permit conditions)

Appl. Nos.	Description
496445 and 496457	Conditions #7 and 8 for revised maximum heat input rate for engines. Condition #23 to clarify that NOx and ROG concentration in exhaust is based on Efficiency Correction Factor (ECF) =1.

The initial Title V permit for this facility was effective April 7, 2008. Since then, the facility has requested for change in conditions and filed the above applications. The proposed change will not result in emission increases.

This request is being made via electronic submittal in order to facilitate your review. If you have any questions or need additional information, please contact Mr. Gaurang Rawal at (909) 396-2543 or by email at grawal@aqmd.gov.

Sincerely,

Jay Chen, P.E.
Senior Engineering Manager
Refinery & Waste Management Permitting

JC: CDT: GCR
Enclosures

cc: Anthony Falbo, VP and General Manager, FORTISTAR Methane Group, MM Lopez Energy, LLC.
A/N 496458- TV permit revision (01)