



NOV 18 2014

Mr. Brent Winn
Aera Energy LLC
PO Box 11164
Bakersfield, CA 93389

**Re: Notice of Minor Title V Permit Modification
District Facility # S-1547
Project # 1144136**

Dear Mr. Winn:

Enclosed is the District's analysis of your application for minor Title V permit modification for the facility identified above. You proposed a Title V minor permit modification to incorporate recently issued S-1547-1335-0 and '-1336-0 into the Title V operating permit. The ATCs authorized replacement of steam generator S-1547-118 (with S-1547-1335) and S-1547-355 (with S-1547-1336) for compliance with Rule 4320 Section 5.3.2 Table 2 with a NO_x limit of 5 ppmv @ 3% O₂ (Final Enhanced Limit). The project also added provisions addressing an initial commissioning period and periodic refractory curing activities and lowered the sulfur limit to 1 gr S/100 scf, the District standard for natural gas.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued S-1547-1335-0 and '-1336-0, emission increases, application, and previous Title V permit. This project will be subject to a 45-day EPA commenting period prior to the District taking final action.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

NOV 18 2014

Mr. Brent Winn
Page 2

Thank you for your cooperation in this matter.

Sincerely,


Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Gerardo C. Rios, EPA (w/enclosure) via email

TITLE V APPLICATION REVIEW

Minor Modification
Project #: S-1144136

Engineer: Richard Edgehill
Date: November 13, 2014

Facility Number: S-1547
Facility Name: Aera Energy LLC
Mailing Address: PO Box 11164
Bakersfield, CA 93389

Reviewed by APS/WR AAE

NOV 13 2014

Contact Name: Brent Winn
btwinn@aeraenergy.com
Phone: (661) 665-4363, (661) 747-8963 (cell)
Responsible Official: B. P. Kachelhoffer
Title: Manager of Operations

I. PROPOSAL

Aera Energy LLC (Aera) is proposing a Title V minor permit modification to incorporate the recently issued Authorities to Construct (ATC) S-1547-1335-0 and '-1336-0 into the Title V permit. The ATCs authorized replacement of steam generator S-1547-118 (with S-1547-1335) and S-1547-355 (with S-1547-1336) for compliance with Rule 4320 Section 5.3.2 Table 2 with a NOx limit of 5 ppmv @ 3% O₂ (Final Enhanced Limit). The project also added provisions addressing an initial commissioning period and periodic refractory curing activities and lowered the sulfur limit to 1 gr S/100 scf, the District standard for natural gas.

The purpose of this evaluation is to identify all applicable requirements, determine if the facility will comply with the applicable requirements and to provide the legal and factual basis for the proposed revisions.

II. FACILITY LOCATION

The replacement steam generators S-1547-1335 and '-1336 will be operated at various specified locations listed on PTOs S-1547-118-20 and '-355-10 in Aera's heavy oil western stationary source.

III. EQUIPMENT DESCRIPTION

S-1547-1335-1: 62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#121, GEN SITE 3363) WITH NORTH AMERICAN ULTRA-LOX NOX MAGNA-FLAME GLE BURNER AND FLUE GAS RECIRCULATION APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

S-1547-1336-1: 62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#158, GEN SITE 3363) WITH NORTH AMERICAN ULTRA-LOX NOX MAGNA-FLAME GLE BURNER AND FLUE GAS RECIRCULATION APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

IV. SCOPE OF EPA AND PUBLIC REVIEW

This change to a Title V permit is considered to be a minor modification and, as such, requires no public review.

V. APPLICABLE REQUIREMENTS

District Rule 2520, Federally Mandated Operating Permits (Adopted June 21, 2001)

VI. DESCRIPTION OF PROPOSED MODIFICATIONS

As the permit units are new, there are no existing Title V PTOs being modified. The draft PTOs include all of the ATC conditions with the exception of the following which are no longer applicable (The PTO cancellation conditions below will be satisfied before issuance of the final PTO) :

S-1547-1335-1

- ~~1. {1829} The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Y~~
- ~~4. The initial commissioning period is the time required to complete the necessary safety checks, curing of refractory material and the performance tuning of the burner and attendant systems to achieve compliance with the emission limits required by this permit. The commissioning period begins upon first firing of the unit and shall not extend beyond the first 135 hours of actual burner operation. [District Rule 2201] Y~~

- ~~5. The refractory curing period is the time required to gradually increase the firing rate and internal temperature of a unit to thermally temper and set the optimal properties of new refractory material that has been installed as part of a unit's initial commissioning or has been replaced as part of a subsequent maintenance or repair procedure. The refractory curing period following the replacement of material as part of a maintenance or repair procedure shall not exceed 30 hours total of actual burner operation per occurrence. [District Rule 2201] Y~~
- ~~6. During the initial commissioning period and any refractory curing period, operator shall limit emissions to the extent possible by optimizing the performance of the low NOx burner and flue gas recirculation system as can be accommodated by individual initial commissioning and refractory curing activities, by following good work practices and fuel conserving measures and by completing all work in an expeditious manner. Operator shall keep a record of the specific activities undertaken as part of the initial commissioning period and all refractory curing periods and the duration of each activity and shall make the records available for District inspection upon request. [District Rule 2201] Y~~
- ~~30. PTO S 1547-118-20 shall be cancelled upon implementation of ATC. [District Rule 2201] Y~~

S-1547-1336-1

- ~~1. {1829} The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Y~~
- ~~4. The initial commissioning period is the time required to complete the necessary safety checks, curing of refractory material and the performance tuning of the burner and attendant systems to achieve compliance with the emission limits required by this permit. The commissioning period begins upon first firing of the unit and shall not extend beyond the first 135 hours of actual burner operation. [District Rule 2201] Y~~
- ~~5. The refractory curing period is the time required to gradually increase the firing rate and internal temperature of a unit to thermally temper and set the optimal properties of new refractory material that has been installed as part of a unit's initial commissioning or has been replaced as part of a subsequent maintenance or repair procedure. The refractory curing period following the replacement of material as part of a maintenance or repair procedure shall not exceed 30 hours total of actual burner operation per occurrence. [District Rule 2201] Y~~

- ~~6. During the initial commissioning period and any refractory curing period, operator shall limit emissions to the extent possible by optimizing the performance of the low NOx burner and flue gas recirculation system as can be accommodated by individual initial commissioning and refractory curing activities, by following good work practices and fuel conserving measures and by completing all work in an expeditious manner. Operator shall keep a record of the specific activities undertaken as part of the initial commissioning period and all refractory curing periods and the duration of each activity and shall make the records available for District inspection upon request. [District Rule 2201] Y~~
- ~~31. PTO S-1547-355-19 shall be cancelled upon implementation of ATC. [District Rule 2201] Y~~

VII. COMPLIANCE

In accordance with Rule 2520, 3.20, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;
2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;
3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;
4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include:
 - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
 - b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
6. Do not seek to consolidate overlapping applicable requirements.

In accordance with Rule 2520, the application meets the procedural requirements of section 11.4 by including:

1. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
2. The source's suggested draft permit; and
3. Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used.

VIII. ATTACHMENTS

- I. Proposed Modified Title V Operating Permits No. S-1547-1335-1 and S-1547-1336-1
- II. Authorities to Construct No. S-1547-1335-0 and S-1547-1336-0
- III. Emissions Increases
- IV. Application
- V. Previous Title V Operating Permit Nos S-1547-118-20 and S-1547-355-19

ATTACHMENT A

Proposed Modified Title V Operating Permit No.
(S-1547-1335-1 and S-1547-1336-1)

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-1335-1

EXPIRATION DATE: 05/31/2016
DRAFT

SECTION: VAR TOWNSHIP: VAR RANGE: VAR

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#121, GEN SITE 3363) WITH NORTH AMERICAN ULTRA-LOX NOX MAGNA-FLAME GLE BURNER AND FLUE GAS RECIRCULATION APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. Approved locations for steam generator are: SW/4 SEC 20, T28S, R21E, SE/4 SEC 28, T28S, R21E, NE/4 SEC 29, T28S, R21E, NE/4 SEC 33, T28S, R21E, SE/4 SEC 33, T28S, R21E, and SE/4 SEC 34 , T28S, R21E. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. {565} Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. Natural gas fuel sulfur content shall not exceed 1.0 gr S/100 scf. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
9. Emission rates, except during startup and shutdown, shall not exceed any of the following: PM10: 0.008 lb/MMBtu, VOC: 0.006 lb/MMBtu, NOx (as NO2): 0.0061 lb/MMBtu or 5 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 4405, 4406, and 4801, 3.1] Federally Enforceable Through Title V Permit
11. Emission rates shall not exceed any of the following: PM10: 12.0 lb/day, SOx (as SO2): 3.2 lb/day, VOC: 9.0 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 52.5 lb/day or 16,425 lb/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Duration of startup and shutdown shall not exceed 2 hours each per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 43405, 4306, and 4320] Federally Enforceable Through Title V Permit
14. If the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H2S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rule 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-1336-1

EXPIRATION DATE: 05/31/2016

SECTION: VAR TOWNSHIP: VAR RANGE: VAR

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#158, GEN SITE 3363) WITH NORTH AMERICAN ULTRA-LOX NOX MAGNA-FLAME GLE BURNER AND FLUE GAS RECIRCULATION APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. Approved locations for steam generator are: SW/4 SEC 20, T28S, R21E, SE/4 SEC 28, T28S, R21E, NE/4 SEC 29, T28S, R21E, NE/4 SEC 33, T28S, R21E, SE/4 SEC 33, T28S, R21E, and SE/4 SEC 34 , T28S, R21E. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Permittee shall notify the District at least 48 hours prior to transfer between approved locations. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), 4301 (Amended December 17, 1992), 4406 (Amended December 17, 1992, and Rule 4801 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
9. {565} Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
10. Natural gas fuel sulfur content shall not exceed 1.1 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Emission rates, except during startup and shutdown, shall not exceed any of the following PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.0061 lb/MMBtu or 5 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 4405, 4406, and 4801] Federally Enforceable Through Title V Permit
13. Emission rates shall not exceed any of the following: PM10: 12.0 lb/day, SOx (as SO2): 4.5 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of startup and shutdown shall not exceed 2 hours each per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

18. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

ATTACHMENT B
Authorities to Construct Nos.
(S-1547-1335-0 and S-1547-1336-0)



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-1335-0

ISSUANCE DATE: 07/01/2013

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: VAR **TOWNSHIP:** VAR **RANGE:** VAR

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#121, GEN SITE 3363) WITH NORTH AMERICAN ULTRA-LOX NOX MAGNA-FLAME GLE BURNER AND FLUE GAS RECIRCULATION APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS


CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. Approved locations for steam generator are: SW/4 SEC 20, T28S, R21E, SE/4 SEC 28, T28S, R21E, NE/4 SEC 29, T28S, R21E, NE/4 SEC 33, T28S, R21E, SE/4 SEC 33, T28S, R21E, and SE/4 SEC 34 , T28S, R21E. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Permittee shall notify the District at least 48 hours prior to transfer between approved locations. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The initial commissioning period is the time required to complete the necessary safety checks, curing of refractory material and the performance tuning of the burner and attendant systems to achieve compliance with the emission limits required by this permit. The commissioning period begins upon first firing of the unit and shall not extend beyond the first 135 hours of actual burner operation. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO


DAVID WARNER, Director of Permit Services

1547-1335-0 : Jul 2 2013 9:44AM - EDGEHLR : Joint Inspection NOT Required

5. The refractory curing period is the time required to gradually increase the firing rate and internal temperature of a unit to thermally temper and set the optimal properties of new refractory material that has been installed as part of a unit's initial commissioning or has been replaced as part of a subsequent maintenance or repair procedure. The refractory curing period following the replacement of material as part of a maintenance or repair procedure shall not exceed 30 hours total of actual burner operation per occurrence. [District Rule 2201] Federally Enforceable Through Title V Permit
6. During the initial commissioning period and any refractory curing period, operator shall limit emissions to the extent possible by optimizing the performance of the low NOx burner and flue gas recirculation system as can be accommodated by individual initial commissioning and refractory curing activities, by following good work practices and fuel conserving measures and by completing all work in an expeditious manner. Operator shall keep a record of the specific activities undertaken as part of the initial commissioning period and all refractory curing periods and the duration of each activity and shall make the records available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. Natural gas fuel sulfur content shall not exceed 1.0 gr S/100 scf. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
14. Emission rates, except during startup, shutdown, initial commissioning and refractory curing, curing shall not exceed any of the following: PM10: 0.008 lb/MMBtu, VOC: 0.006 lb/MMBtu, NOx (as NO2): 0.0061 lb/MMBtu or 5 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

15. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 4405, 4406, and 4801, 3.1] Federally Enforceable Through Title V Permit
16. Emission rates shall not exceed any of the following: PM₁₀: 12.0 lb/day, SO_x (as SO₂): 3.2 lb/day, VOC: 9.0 lb/day, NO_x (as NO₂): 54.0 lb/day or 9855 lb/year, or CO: 52.5 lb/day or 16,425 lb/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of startup and shutdown shall not exceed 2 hours each per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 43405, 4306, and 4320] Federally Enforceable Through Title V Permit
19. If the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

24. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rule 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. PTO S-1547-118-20 shall be cancelled upon implementation of ATC. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-1336-0

ISSUANCE DATE: 07/01/2013

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: VAR **TOWNSHIP:** VAR **RANGE:** VAR

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#158, GEN SITE 3363) WITH NORTH AMERICAN ULTRA-LOX NOX MAGNA-FLAME GLE BURNER AND FLUE GAS RECIRCULATION APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. Approved locations for steam generator are: SW/4 SEC 20, T28S, R21E, SE/4 SEC 28, T28S, R21E, NE/4 SEC 29, T28S, R21E, NE/4 SEC 33, T28S, R21E, SE/4 SEC 33, T28S, R21E, and SE/4 SEC 34 ; T28S, R21E. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Permittee shall notify the District at least 48 hours prior to transfer between approved locations. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The initial commissioning period is the time required to complete the necessary safety checks, curing of refractory material and the performance tuning of the burner and attendant systems to achieve compliance with the emission limits required by this permit. The commissioning period begins upon first firing of the unit and shall not extend beyond the first 135 hours of actual burner operation. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO


DAVID WARNER, Director of Permit Services

S-1547-1336-0 : Jul 2 2013 9:44AM - EDGEHILL : Joint Inspection NOT Required

5. The refractory curing period is the time required to gradually increase the firing rate and internal temperature of a unit to thermally temper and set the optimal properties of new refractory material that has been installed as part of a unit's initial commissioning or has been replaced as part of a subsequent maintenance or repair procedure. The refractory curing period following the replacement of material as part of a maintenance or repair procedure shall not exceed 30 hours total of actual burner operation per occurrence. [District Rule 2201] Federally Enforceable Through Title V Permit
6. During the initial commissioning period and any refractory curing period, operator shall limit emissions to the extent possible by optimizing the performance of the low NOx burner and flue gas recirculation system as can be accommodated by individual initial commissioning and refractory curing activities, by following good work practices and fuel conserving measures and by completing all work in an expeditious manner. Operator shall keep a record of the specific activities undertaken as part of the initial commissioning period and all refractory curing periods and the duration of each activity and shall make the records available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), 4301 (Amended December 17, 1992), 4406 (Amended December 17, 1992, and Rule 4801 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Natural gas fuel sulfur content shall not exceed 1.1 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Emission rates, except during startup, shutdown, initial commissioning and refractory curing, shall not exceed any of the following PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.0061 lb/MMBtu or 5 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

16. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 4405, 4406, and 4801] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following: PM₁₀: 12.0 lb/day, SO_x (as SO₂): 4.5 lb/day, VOC: 4.5 lb/day, NO_x (as NO₂): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
18. Duration of startup and shutdown shall not exceed 2 hours each per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

25. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
31. PTO S-1547-355-19 shall be cancelled upon implementation of ATC. [District Rule 2201] Federally Enforceable Through Title V Permit

ATTACHMENT C

Emissions Increases

	SSIPE (lb/yr)				
	NOx	SOx	PM10	CO	VOC
S-1547-1335-0	3,340	1,560	4,380	16,425	3,285
S-1547-1336-0	3,340	1,643	4,380	16,425	1,643

ATTACHMENT D

Application

5-1547-1335-1, 1-1336-1

San Joaquin Valley Air Pollution Control District

APPLICATION FOR TITLE V MODIFICATION:

RECEIVED

OCT 29 2014

SJVAPCD
Southern Region

- ADMINISTRATIVE AMENDMENT
- MINOR MODIFICATION
- SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: AERA ENERGY LLC	
2. MAILING ADDRESS: STREET/P.O. BOX: CITY: P.O. BOX 11164 STATE: CA 9-DIGIT ZIP CODE: 93389-1164	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED: STREET: Belridge Oilfield, Heavy Oil Western Source (S-1547) CITY: _____ 1/4 SECTION Variou TOWNSHIP Various RANGE Various	INSTALLATION DATE:
4. GENERAL NATURE OF BUSINESS: Oil and Gas Production	
5. EQUIPMENT FOR WHICH APPLICATION IS MADE (Include Permit Nos.): Convert ATC S-1547-1335-0 (62.5 MMBTU/hr Steam Generator with Lo-NOx burner and FGR) to Title V Permit to Operate. This replaces PTO S-1547-118 for Rule 4320 compliance. <small>(Use additional sheets if necessary)</small>	
6. DO YOU REQUEST A CERTIFICATE OF CONFORMITY WITH THIS ACTION? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
7. IS THIS APPLICATION SUBMITTED AS A RESULT OF A NOV/NTC? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO NOV/NTC No.: _____	
8. SIGNATURE OF APPLICANT/CONTACT PERSON: 	TYPE OR PRINT TITLE OF APPLICANT: Environmental Engineer
9. TYPE OR PRINT NAME OF APPLICANT/CONTACT: Brent Winn	DATE: 10/28/14
10. FAX NUMBER: (661) 665-7437	TELEPHONE NUMBER: (661) 665-4363

FOR APCD USE ONLY:

DATE STAMP	FILING FEE RECEIVED: \$ _____ / DATE PAID: _____ PROJECT NO.: S-1144136 FACILITY REGION & ID: S-1547
------------	--

**San Joaquin Valley
Unified Air Pollution Control District**

TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

RECEIVED

OCT 29 2014

SJVAPCD
Southern Region

I. TYPE OF PERMIT ACTION (Check appropriate box)

- SIGNIFICANT PERMIT MODIFICATION ADMINISTRATIVE
 MINOR PERMIT MODIFICATION AMENDMENT

**Replacement Unit - Rule 4320 Compliance
62.5 MMBTU/hr Steam Generator SG 121 at 3363 Setting**

COMPANY NAME: AERA ENERGY LLC	FACILITY ID: S - 1547
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: AERA ENERGY LLC	
3. Agent to the Owner: N/A	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the source identified in this application will continue to comply with the applicable federal requirement(s) which the source is in compliance.
- Based on information and belief formed after reasonable inquiry, the source identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true, accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

Brian Kachelhoffer

Signature of Responsible Official

10/29/14

Date

B.P. Kachelhoffer

Name of Responsible Official (please print)

Manager of Operations

Title of Responsible Official (please print)

San Joaquin Valley Air Pollution Control District


APPLICATION FOR TITLE V MODIFICATION:

RECEIVED

OCT 29 2014

SJVAPCD
Southern Region

- ADMINISTRATIVE AMENDMENT
- MINOR MODIFICATION
- SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: AERA ENERGY LLC	
2. MAILING ADDRESS: STREET/P.O. BOX: CITY: P.O. BOX 11164 STATE: CA 9-DIGIT ZIP CODE: 93389-1164	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED: STREET: Belridge Oilfield, Heavy Oil Western Source (S-1547) CITY: _____ 1/4 SECTION Variou TOWNSHIP Various RANGE Various	INSTALLATION DATE:
4. GENERAL NATURE OF BUSINESS: Oil and Gas Production	
5. EQUIPMENT FOR WHICH APPLICATION IS MADE (Include Permit Nos.): Convert ATC S-1547-1336-0 (62.5 MMBTU/hr Steam Generator with Lo-NOx burner and FGR) to Title V Permit to Operate. This replaces PTO S-1547-355 for Rule 4320 compliance. (Use additional sheets if necessary)	
6. DO YOU REQUEST A CERTIFICATE OF CONFORMITY WITH THIS ACTION? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
7. IS THIS APPLICATION SUBMITTED AS A RESULT OF A NOV/NTC? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO NOV/NTC No.: _____	
8. SIGNATURE OF APPLICANT/CONTACT PERSON: 	TYPE OR PRINT TITLE OF APPLICANT: Environmental Engineer
9. TYPE OR PRINT NAME OF APPLICANT/CONTACT: Brent Winn	DATE: 10/28/14
10. FAX NUMBER: (661) 665-7437	TELEPHONE NUMBER: (661) 665-4363

FOR APCD USE ONLY:

DATE STAMP	FILING FEE RECEIVED: \$ _____ / DATE PAID: _____ PROJECT NO.: _____ FACILITY REGION & ID: _____
------------	---

**San Joaquin Valley
Unified Air Pollution Control District**

TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

RECEIVED

OCT 29 2014

SJVAPCD
Southern Region

I. TYPE OF PERMIT ACTION (Check appropriate box)

- SIGNIFICANT PERMIT MODIFICATION ADMINISTRATIVE
 MINOR PERMIT MODIFICATION AMENDMENT

**Replacement Unit - Rule 4320 Compliance
62.5 MMBTU/hr Steam Generator SG 158 at 3363 Setting**

COMPANY NAME: AERA ENERGY LLC	FACILITY ID: S-1547
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: AERA ENERGY LLC	
3. Agent to the Owner: N/A	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the source identified in this application will continue to comply with the applicable federal requirement(s) which the source is in compliance.
- Based on information and belief formed after reasonable inquiry, the source identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true, accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

Brian Kachelhoffer

Signature of Responsible Official

10/29/14

Date

B. P. Kachelhoffer

Name of Responsible Official (please print)

Manager of Operations

Title of Responsible Official (please print)

ATTACHMENT E

Previous Title V Operating Permit Nos.
S-1547-118-20 and S-1548-355-19

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-118-20

EXPIRATION DATE: 05/31/2016

SECTION: V TOWNSHIP: V RANGE: V

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM (#121 DIS# 27575-81) (GEN SITE 2886) WITH A COEN MODEL #QLN-ULN 3.2 BURNER WITH FLUE GAS RECIRCULATION (FGR) AND JOHN ZINK/TODD COOL FUEL SYSTEM

PERMIT UNIT REQUIREMENTS

1. Approved locations for steam generator are: SW/4 SEC 20, T28S, R21E, SE/4 SEC 28, T28S, R21E, NE/4 SEC 29, T28S, R21E, NE/4 SEC 33, T28S, R21E, SE/4 SEC 33, T28S, R21E, and SE/4 SEC 34 , T28S, R21E. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Permittee shall notify the District at least 48 hours prior to transfer between approved locations. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2, and 4306, 6.2] Federally Enforceable Through Title V Permit
7. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2; and 4306, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
9. Natural gas fuel sulfur content shall not exceed 0.75 gr S/100 scf. [District Rules 2201] Federally Enforceable Through Title V Permit
10. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: PM10: 0.008 lb/MMBtu, VOC: 0.006 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1; and 4306, 5.1] Federally Enforceable Through Title V Permit
11. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
12. Emission rates shall not exceed any of the following: PM10: 12.0 lb/day, SOx (as SO2): 3.2 lb/day, VOC: 9.0 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 52.5 lb/day or 16,425 lb/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5, & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
14. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.5] Federally Enforceable Through Title V Permit
15. If the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
16. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

17. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
18. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
19. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
20. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
21. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
22. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2 and 4305, 6.2] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
24. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
25. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
26. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-355-19

EXPIRATION DATE: 05/31/2016

SECTION: NE33 **TOWNSHIP:** 28S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH A COEN MODEL QLN-ULN LOW NOX BURNER AND FLUE GAS RECIRCULATION, APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS (#158, DIS# 39603-88)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct (ATC) for such modifications, except for changes specified in the conditions below. [District Rule 2201]
2. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
8. Approved locations for steam generator are: SW/4 SEC 20, T28S, R21E, SE/4 SEC 28, T28S, R21E, NE/4 SEC 29, T28S, R21E, NE/4 SEC 33, T28S, R21E, SE/4 SEC 33, T28S, R21E, and SE/4 SEC 34 , T28S, R21E. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Permittee shall notify the District at least 48 hours prior to transfer between approved locations. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2, and 4306, 6.2] Federally Enforceable Through Title V Permit
14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), 4301 (Amended December 17, 1992), 4406 (Amended December 17, 1992, and Rule 4801 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Natural gas fuel sulfur content shall not exceed 1.1 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
19. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
20. Emission rates shall not exceed any of the following: PM10: 12.0 lb/day, SOx (as SO2): 4.5 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
21. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
22. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
24. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
27. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
29. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
32. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
34. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.