



OCT 13 2014

Mr. Shamim Reza
Berry Petroleum Company
5201 Truxtun Ave, Suite 100
Bakersfield, CA 93309

**Re: Notice of Minor Title V Permit Modification
District Facility # S-1246
Project # 1143236**

Dear Mr. Reza:

Enclosed is the District's analysis of your application for minor Title V permit modification for the facility identified above. You proposed a Title V minor permit modification to incorporate recently issued Authority to Construct (ATC) S-1246-182-5 into the Title V operating permit. The project upgraded the Phase I vapor recovery system from two-point to Morrison Brothers EVR (VR-402).

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued Authority to Construct (ATC) S-1246-182-5, application, and previous Title V permit. This project will be subject to a 45-day EPA commenting period prior to the District taking final action.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,



Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061
www.valleyair.org www.healthyliving.com

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

TITLE V APPLICATION REVIEW

Minor Modification
Project #: S-1143236

Engineer: Richard Edgehill
Date: October 7, 2014

Facility Number: S-1246
Facility Name: Berry Petroleum Company, LLC.
Mailing Address: 5201 Truxtun Ave, Suite 100
Bakersfield, CA 93309

Contact Name: Shamim Reza
Phone: (661) 661-3889
Title: Environmental Specialist
Lead Engineer: Allan Phillips *AP SURE ADZE* OCT 07 2014
Responsible Official: Robert Boston

Title: Manager of EHS

I. PROPOSAL

Berry Petroleum Company LLC (Berry) is proposing a Title V minor permit modification to incorporate the recently issued Authority to Construct S-1246-182-5 into the Title V operating permit. The project authorized upgrade of an above ground gasoline dispensing facility from two point Phase I vapor control to Morrison Brothers EVR (VR-412B).

The purpose of this evaluation is to identify all applicable requirements, determine if the facility will comply with the applicable requirements and to provide the legal and factual basis for the proposed revisions.

II. FACILITY LOCATION

The tank is located the BE Lease, North Midway Sunset, Section 31 T32S R24E.

III. EQUIPMENT DESCRIPTION

PTO S-1246-182-6: GASOLINE DISPENSING OPERATION WITH ONE 2,000 GALLON TRUCSO SUPERVAULT ABOVEGROUND STORAGE TANK SERVED BY MORRISON BROS EVR PHASE I VAPOR RECOVERY SYSTEM (VR-402-B), STANDING LOSS CONTROL (VR-301), AND 1 FUELING

POINT WITH 1 GASOLINE DISPENSING NOZZLE
SERVED BY BALANCE PHASE II VAPOR RECOVERY
SYSTEM (G-70-142-B)

IV. SCOPE OF EPA AND PUBLIC REVIEW

This change to a Title V permit is considered to be a minor modification and, as such, requires no public review.

V. APPLICABLE REQUIREMENTS

District Rule 2520, Federally Mandated Operating Permits (Adopted June 21, 2001)

VI. DESCRIPTION OF PROPOSED MODIFICATIONS

S-1246-182-6

The permit conditions are the standard PTO conditions for VR-402 Morrison Bros, Phase I, VR-301 (Existing Tanks Not Required Painting), Balance Phase II, Non-Retail.

VII. COMPLIANCE

In accordance with Rule 2520, 3.20, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;
2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;
3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;
4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include:
 - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and

- b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
 5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
 6. Do not seek to consolidate overlapping applicable requirements.
- In accordance with Rule 2520, the application meets the procedural requirements of section 11.4 by including;
1. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
 2. The source's suggested draft permit; and
 3. Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used.

VIII. ATTACHMENTS

- A. Proposed Title V PTO S-1246-182-6
- B. Authority to Construct S-1246-182-5
- C. Permit Application
- D. Current Title V PTO S-1246-182-4

Berry Petroleum Company LLC
S-1246, 1143236

ATTACHMENT A

Proposed Title V PTO
S-1246-182-6

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1246-182-6

EXPIRATION DATE: 03/31/2016

SECTION: 31 TOWNSHIP: 32S RANGE: 24E

EQUIPMENT DESCRIPTION:

GASOLINE DISPENSING OPERATION WITH ONE 2,000 GALLON TRUCSO SUPERVAULT ABOVEGROUND STORAGE TANK SERVED BY MORRISON BROS EVR PHASE I VAPOR RECOVERY SYSTEM (VR-402-B), STANDING LOSS CONTROL (VR-301), AND 1 FUELING POINT WITH 1 GASOLINE DISPENSING NOZZLE SERVED BY BALANCE PHASE II VAPOR RECOVERY SYSTEM (G-70-142-B)

PERMIT UNIT REQUIREMENTS

1. The Phase I, Phase II, and Standing Loss Control Vapor recovery systems shall be installed and maintained in accordance with the manufacturer specifications and the ARB Executive Orders specified in this permit, including applicable rules and regulations of the Division of Measurement Standards of the Department of Food and Agriculture, the Office of the State Fire Marshal of the Department of Forestry and Fire Protection, the Division of Occupational Safety and Health of the Department of Industrial Relations, and the Division of Water Quality of the State Water Resources Control Board that have been made conditions of the certification. [District Rules 4621 and 4622 and CH&SC 41950] Federally Enforceable Through Title V Permit
2. This gasoline storage and dispensing equipment shall not be used in retail sales, where gasoline dispensed by the unit is subject to payment of California sales tax on gasoline sales. [District Rule 4622] Federally Enforceable Through Title V Permit
3. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. The storage container(s) shall be installed, maintained, and operated such that they are leak-free. [District Rule 4621] Federally Enforceable Through Title V Permit
5. The Phase I and Phase II vapor recovery systems and gasoline dispensing equipment shall be maintained without leaks as determined in accordance with the test method specified in this permit. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
6. A leak is defined as the dripping of VOC-containing liquid at a rate of more than three (3) drops per minute, or the detection of any gaseous or vapor emissions with a concentration of total organic compound greater than 10,000 ppmv, as methane, above background when measured in accordance with EPA Test Method 21. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
7. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo container, which attest to the vapor integrity of the container. [District Rule 4621] Federally Enforceable Through Title V Permit
8. No person shall operate any ARB certified Phase II vapor recovery system or any portion thereof that has a major defect or an equipment defect that is identified in any applicable ARB Executive Order until the following conditions have been met: 1) the defect has been repaired, replaced, or adjusted as necessary to correct the defect; 2) the District has been notified, and the District has reinspected the system or authorized the system for use (such authorization shall not include the authority to operate the equipment prior to the correction of the defective components); and 3) all major defects, after repair, are duly entered into the Operations and Maintenance (O&M) manual. [District Rule 4622] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. Upon identification of any major defects, the permittee shall tag "Out-of-Order" all dispensing equipment for which vapor recovery has been impaired. Tagged equipment shall be rendered inoperable and the tag(s) shall not be removed until the defective equipment has been repaired, replaced, or adjusted, as necessary. In the case of defects identified by the District, tagged equipment shall be rendered inoperable, and the tag shall not be removed until the District has been notified of the repairs, and the District has either reinspected the system or authorized the tagged equipment for use. [District Rule 4622] Federally Enforceable Through Title V Permit
10. The permittee shall implement a periodic maintenance inspection program for the certified Phase II vapor recovery system consistent with the requirements of this permit. The program shall be documented in an operation and maintenance (O&M) manual and shall at a minimum contain the following information: 1) copies of all vapor recovery performance tests; 2) all applicable ARB Executive Orders, Approval Letters, and District Permits; 3) the manufacturer's specifications and instructions for installation, operation, repair, and maintenance required pursuant to ARB Certification Procedure CP-201, and any additional instruction provided by the manufacturer; 4) system and/or component testing requirements, including test schedules and passing criteria for each of the standard tests required by this permit (the owner/operator may include any non-ARB required diagnostic and other tests as part of the testing requirements), and 5) additional O&M instructions, if any, that are designed to ensure compliance with the applicable rules, regulations, ARB Executive Orders, and District permit conditions, including replacement schedules for failure or wear prone components. [District Rule 4622] Federally Enforceable Through Title V Permit
11. The permittee shall conduct periodic maintenance inspections based on the greatest monthly throughput of gasoline dispensed by the facility in the previous year as follows: A) less than 2,500 gallons - one day per month; B) 2,500 to less than 25,000 gallons - one day per week; or C) 25,000 gallons or greater - five days per week. All inspections shall be documented within the O & M Manual. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
12. Periodic maintenance inspections of the Phase I vapor recovery system shall include, at a minimum, verification that 1) the fill caps and vapor caps are not missing, damaged, or loose; 2) the fill cap gasket and vapor cap gaskets are not missing or damaged; 3) the fill adapter and vapor adapter are securely attached to the risers; 4) where applicable, the spring-loaded submerged fill tube seals properly against the coaxial tubing; 5) the dry break (poppet-valve) is not missing or damaged; and 6) the submerged fill tube is not missing or damaged. [District Rule 4621] Federally Enforceable Through Title V Permit
13. Periodic maintenance inspections of the Phase II vapor recovery system shall include, at a minimum, verification that 1) the following nozzle components are in place and in good condition as specified in ARB Executive Order as applicable: faceplate/facecone, bellows, latching device spring, vapor check valve, spout (proper diameter/vapor collection holes), insertion interlock mechanism, automatic shut-off mechanism, and hold open latch (unless prohibited by law or the local fire control authority); 2) the hoses are not torn, flattened or crimped; 3) the vapor path of the coaxial hoses associated with bellows equipped nozzles does not contain more than 100 ml of liquid if applicable; and 4) the vapor processing unit is functioning properly, for operations that are required to have or possess such a unit. [District Rule 4622] Federally Enforceable Through Title V Permit
14. In the event of a separation due to a drive off, the permittee shall, unless otherwise specified in the applicable ARB Executive Order, conduct a visual inspection of the affected equipment and either 1) perform qualified repairs on any damaged components and conduct applicable re-verification tests pursuant to the requirements of this permit, or 2) replace the affected nozzles, coaxial hoses, breakaway couplings, and any other damaged components with new or certified rebuilt components that are ARB certified. The activities shall be documented in accordance with the requirements of this permit before placing the affected equipment back in service. [District Rule 4622] Federally Enforceable Through Title V Permit
15. The gasoline throughput for this permit unit shall not exceed 657,000 gallons in any one calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
16. The permittee shall conduct all periodic vapor recovery system performance tests specified in this permit, no more than 30 days before or after the required compliance testing date, unless otherwise required under the applicable ARB Executive Order. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

17. The permittee shall perform and pass a Static Leak Test "Determination of Static Pressure Performance of Vapor Recovery Systems at Gasoline Dispensing Facilities with Aboveground Tanks" in accordance with the Executive Order specified in this permit for the Phase I Vapor Recovery System at least once every 12 months. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
18. For certified Phase II vapor recovery systems with liquid removal devices, the permittee shall perform and pass an ARB TP-201.6C Liquid Removal Test whenever the liquid in the vapor path exceeds 100 ml of liquid, or as required by the applicable ARB Executive Order. The amount of liquid in the vapor path shall be measured by lowering the gasoline dispensing nozzle into a container until such time that no more liquid drains from the nozzle. The amount of liquid drained into the container shall be measured using a graduated cylinder or graduated beaker. The vapor path shall be inspected according to the monitoring frequency as determined by monthly gasoline throughput. [District Rule 4622] Federally Enforceable Through Title V Permit
19. If a Liquid Condensate Trap is installed, the permittee shall perform and pass a Liquid Condensate Trap Compliance Test using the test procedure defined in the Executive Order specified in this permit for the Phase II Vapor Recovery System at least once every 12 months. [District Rule 4622] Federally Enforceable Through Title V Permit
20. If a Liquid Condensate Trap is installed it shall be (1) maintained without leaks; (2) accessible for inspection upon request; (3) capable of automatic evacuation of liquid; and (4) equipped with an alarm system in case of failure of the evacuation system. [District Rule 4622] Federally Enforceable Through Title V Permit
21. A person conducting testing of, or repairs to, a certified vapor recovery system shall be in compliance with District Rule 1177 (Gasoline Dispensing Facility Tester Certification). [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
22. A person performing installation of, or maintenance on, a certified Phase I or Phase II vapor recovery system shall be certified by the ICC for Vapor Recovery System Installation and Repair, or work under the direct and personal supervision of an individual physically present at the work site who is certified. The ICC certification shall be renewed every 24 months. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
23. Proof of the ICC certification and all other certifications required by the Executive Order and installation and operation manual shall be made available onsite. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
24. The permittee shall notify the District at least 7 days prior to each performance test. The test results shall be submitted to the District no later than 30 days after the completion of each test. [District Rule 4621] Federally Enforceable Through Title V Permit
25. The permittee shall maintain a copy of all test results. The test results shall be dated and shall contain the name, address, and telephone number of the company responsible for system installation and testing. [District Rule 4622] Federally Enforceable Through Title V Permit
26. The permittee shall maintain on the premises a log of any repairs made to the certified Phase I or Phase II vapor recovery system. The repair log shall include the following: 1) date and time of each repair; 2) the name and applicable certification numbers of the person(s) who performed the repair, and if applicable, the name, address and phone number of the person's employer; 3) description of service performed; 4) each component that was repaired, serviced, or removed; 5) each component that was installed as replacement, if applicable; and 6) receipts or other documents for parts used in the repair and, if applicable, work orders which shall include the name and signature of the person responsible for performing the repairs. [District Rule 4622] Federally Enforceable Through Title V Permit
27. The O&M manual shall be kept at the dispensing operation and made available to any person who operates, inspects, maintains, repairs, or tests the equipment at the operation as well as to District personnel upon request. [District Rule 4622] Federally Enforceable Through Title V Permit
28. Only white paint, listed in the Executive Order specified in this permit for the Standing Loss Control System, shall be applied to the tank. The surface of the tank shall be prepared and the white paint shall be applied per manufacturer's specification. [District Rule 4621] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

29. The permittee shall maintain the following records: 1) receipt of sale that demonstrates the purchase date and amount of white paint purchased, 2) record of the name of personnel applying white paint to include the date of application, surface preparation description (i.e. scraping, sanding, abrasive blasting, primer etc.), method of application (i.e. brush, roller, air/airless sprayer), average ambient temperature (øF) during application, and atmospheric observations during application (i.e. sunny, cloudy, rain, etc.), 3) record of the name of personnel that installed the P/V vent valve, and 4) Technical Data Sheet and/or Material Safety Data Sheet of the white paint that describes the surface preparation, application, and material safety of the white paint. [District Rule 4621] Federally Enforceable Through Title V Permit
30. The permittee shall maintain monthly and annual gasoline throughput records. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
31. All records required by this permit shall be retained on-site for a period of at least five years and shall be made available for District inspection upon request. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

ATTACHMENT B

Authority to Construct
S-1246-182-5

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1246-182-5

ISSUANCE DATE: 02/05/2014

LEGAL OWNER OR OPERATOR: BERRY PETROLEUM COMPANY
MAILING ADDRESS: APD ACCOUNTS PAYABLE
5201 TRUXTUN AVE
BAKERSFIELD, CA 93309

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: 31 TOWNSHIP: 32S RANGE: 24E

EQUIPMENT DESCRIPTION:

MODIFICATION OF GASOLINE DISPENSING OPERATION WITH ONE 2,000 GALLON TRUSCO SUPERVAULT ABOVEGROUND STORAGE TANK SERVED BY TWO-POINT PHASE I VAPOR RECOVERY SYSTEM, AND 1 FUELING POINT WITH 1 GASOLINE DISPENSING NOZZLE SERVED BY BALANCE PHASE II VAPOR RECOVERY SYSTEM (G-70-142-B);UPGRADE PHASE I VAPOR RECOVERY SYSTEM FROM TWO-POINT TO MORISON BROTHERS EVR (VR-402-B)

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. The Phase I, Phase II, and Standing Loss Control Vapor recovery systems shall be installed and maintained in accordance with the manufacturer specifications and the ARB Executive Orders specified in this permit, including applicable rules and regulations of the Division of Measurement Standards of the Department of Food and Agriculture, the Office of the State Fire Marshal of the Department of Forestry and Fire Protection, the Division of Occupational Safety and Health of the Department of Industrial Relations, and the Division of Water Quality of the State Water Resources Control Board that have been made conditions of the certification. [District Rules 4621 and 4622 and CH&SC 41950] Federally Enforceable Through Title V Permit
3. This gasoline storage and dispensing equipment shall not be used in retail sales, where gasoline dispensed by the unit is subject to payment of California sales tax on gasoline sales. [District Rule 4622] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

COPY

Arnaud Marjollet, Director of Permit Services

S-1246-182-5 Oct 6 2014 1:51PM -- EDGEHILR Joint Inspection NOT Required

5. The storage container(s) shall be installed, maintained, and operated such that they are leak-free. [District Rule 4621] Federally Enforceable Through Title V Permit
6. The Phase I and Phase II vapor recovery systems and gasoline dispensing equipment shall be maintained without leaks as determined in accordance with the test method specified in this permit. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
7. A leak is defined as the dripping of VOC-containing liquid at a rate of more than three (3) drops per minute, or the detection of any gaseous or vapor emissions with a concentration of total organic compound greater than 10,000 ppmv, as methane, above background when measured in accordance with EPA Test Method 21. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
8. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo container, which attest to the vapor integrity of the container. [District Rule 4621] Federally Enforceable Through Title V Permit
9. No person shall operate any ARB certified Phase II vapor recovery system or any portion thereof that has a major defect or an equipment defect that is identified in any applicable ARB Executive Order until the following conditions have been met: 1) the defect has been repaired, replaced, or adjusted as necessary to correct the defect; 2) the District has been notified, and the District has reinspected the system or authorized the system for use (such authorization shall not include the authority to operate the equipment prior to the correction of the defective components); and 3) all major defects, after repair, are duly entered into the Operations and Maintenance (O&M) manual. [District Rule 4622] Federally Enforceable Through Title V Permit
10. Upon identification of any major defects, the permittee shall tag "Out-of-Order" all dispensing equipment for which vapor recovery has been impaired. Tagged equipment shall be rendered inoperable and the tag(s) shall not be removed until the defective equipment has been repaired, replaced, or adjusted, as necessary. In the case of defects identified by the District, tagged equipment shall be rendered inoperable, and the tag shall not be removed until the District has been notified of the repairs, and the District has either reinspected the system or authorized the tagged equipment for use. [District Rule 4622] Federally Enforceable Through Title V Permit
11. The permittee shall implement a periodic maintenance inspection program for the certified Phase II vapor recovery system consistent with the requirements of this permit. The program shall be documented in an operation and maintenance (O&M) manual and shall at a minimum contain the following information: 1) copies of all vapor recovery performance tests; 2) all applicable ARB Executive Orders, Approval Letters, and District Permits; 3) the manufacturer's specifications and instructions for installation, operation, repair, and maintenance required pursuant to ARB Certification Procedure CP-201, and any additional instruction provided by the manufacturer; 4) system and/or component testing requirements, including test schedules and passing criteria for each of the standard tests required by this permit (the owner/operator may include any non-ARB required diagnostic and other tests as part of the testing requirements), and 5) additional O&M instructions, if any, that are designed to ensure compliance with the applicable rules, regulations, ARB Executive Orders, and District permit conditions, including replacement schedules for failure or wear prone components. [District Rule 4622] Federally Enforceable Through Title V Permit
12. The permittee shall conduct periodic maintenance inspections based on the greatest monthly throughput of gasoline dispensed by the facility in the previous year as follows: A) less than 2,500 gallons - one day per month; B) 2,500 to less than 25,000 gallons - one day per week; or C) 25,000 gallons or greater - five days per week. All inspections shall be documented within the O & M Manual. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
13. Periodic maintenance inspections of the Phase I vapor recovery system shall include, at a minimum, verification that 1) the fill caps and vapor caps are not missing, damaged, or loose; 2) the fill cap gasket and vapor cap gaskets are not missing or damaged; 3) the fill adapter and vapor adapter are securely attached to the risers; 4) where applicable, the spring-loaded submerged fill tube seals properly against the coaxial tubing; 5) the dry break (poppet-valve) is not missing or damaged; and 6) the submerged fill tube is not missing or damaged. [District Rule 4621] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

14. Periodic maintenance inspections of the Phase II vapor recovery system shall include, at a minimum, verification that 1) the following nozzle components are in place and in good condition as specified in ARB Executive Order as applicable: faceplate/facecone, bellows, latching device spring, vapor check valve, spout (proper diameter/vapor collection holes), insertion interlock mechanism, automatic shut-off mechanism, and hold open latch (unless prohibited by law or the local fire control authority); 2) the hoses are not torn, flattened or crimped; 3) the vapor path of the coaxial hoses associated with bellows equipped nozzles does not contain more than 100 ml of liquid if applicable; and 4) the vapor processing unit is functioning properly, for operations that are required to have or possess such a unit. [District Rule 4622] Federally Enforceable Through Title V Permit
15. In the event of a separation due to a drive off, the permittee shall, unless otherwise specified in the applicable ARB Executive Order, conduct a visual inspection of the affected equipment and either 1) perform qualified repairs on any damaged components and conduct applicable re-verification tests pursuant to the requirements of this permit, or 2) replace the affected nozzles, coaxial hoses, breakaway couplings, and any other damaged components with new or certified rebuilt components that are ARB certified. The activities shall be documented in accordance with the requirements of this permit before placing the affected equipment back in service. [District Rule 4622] Federally Enforceable Through Title V Permit
16. The gasoline throughput for this permit unit shall not exceed 657,000 gallons in any one calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
17. The permittee shall conduct all periodic vapor recovery system performance tests specified in this permit, no more than 30 days before or after the required compliance testing date, unless otherwise required under the applicable ARB Executive Order. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
18. The permittee shall perform and pass a Static Leak Test "Determination of Static Pressure Performance of Vapor Recovery Systems at Gasoline Dispensing Facilities with Aboveground Tanks" in accordance with the Executive Order specified in this permit for the Phase I Vapor Recovery System within 60 days after initial start-up and at least once every 12 months thereafter. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
19. If a rotatable Phase I vapor adaptor is installed, the permittee shall perform and pass a Static Torque of Rotatable Phase I Adaptors test using ARB procedure TP-201.1B within 60 days after initial start-up and at least once every 36 months thereafter. [District Rule 4621] Federally Enforceable Through Title V Permit
20. For certified Phase II vapor recovery systems with liquid removal devices, the permittee shall perform and pass an ARB TP-201.6C Liquid Removal Test whenever the liquid in the vapor path exceeds 100 ml of liquid, or as required by the applicable ARB Executive Order. The amount of liquid in the vapor path shall be measured by lowering the gasoline dispensing nozzle into a container until such time that no more liquid drains from the nozzle. The amount of liquid drained into the container shall be measured using a graduated cylinder or graduated beaker. The vapor path shall be inspected according to the monitoring frequency as determined by monthly gasoline throughput. [District Rule 4622] Federally Enforceable Through Title V Permit
21. If a Liquid Condensate Trap is installed, the permittee shall perform and pass a Liquid Condensate Trap Compliance Test using the test procedure defined in the Executive Order specified in this permit for the Phase II Vapor Recovery System within 60 days after initial startup and at least once every 12 months thereafter. [District Rule 4622] Federally Enforceable Through Title V Permit
22. If a Liquid Condensate Trap is installed it shall be (1) maintained without leaks; (2) accessible for inspection upon request; (3) capable of automatic evacuation of liquid; and (4) equipped with an alarm system in case of failure of the evacuation system. [District Rule 4622] Federally Enforceable Through Title V Permit
23. A person conducting testing of, or repairs to, a certified vapor recovery system shall be in compliance with District Rule 1177 (Gasoline Dispensing Facility Tester Certification). [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
24. A person performing installation of, or maintenance on, a certified Phase I or Phase II vapor recovery system shall be certified by the ICC for Vapor Recovery System Installation and Repair, or work under the direct and personal supervision of an individual physically present at the work site who is certified. The ICC certification shall be renewed every 24 months. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
25. Proof of the ICC certification and all other certifications required by the Executive Order and installation and operation manual shall be made available onsite. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

26. The permittee shall notify the District at least 7 days prior to each performance test. The test results shall be submitted to the District no later than 30 days after the completion of each test. [District Rule 4621] Federally Enforceable Through Title V Permit
27. The permittee shall maintain a copy of all test results. The test results shall be dated and shall contain the name, address, and telephone number of the company responsible for system installation and testing. [District Rule 4622] Federally Enforceable Through Title V Permit
28. The permittee shall maintain on the premises a log of any repairs made to the certified Phase I or Phase II vapor recovery system. The repair log shall include the following: 1) date and time of each repair; 2) the name and applicable certification numbers of the person(s) who performed the repair, and if applicable, the name, address and phone number of the person's employer; 3) description of service performed; 4) each component that was repaired, serviced, or removed; 5) each component that was installed as replacement, if applicable; and 6) receipts or other documents for parts used in the repair and, if applicable, work orders which shall include the name and signature of the person responsible for performing the repairs. [District Rule 4622] Federally Enforceable Through Title V Permit
29. The O&M manual shall be kept at the dispensing operation and made available to any person who operates, inspects, maintains, repairs, or tests the equipment at the operation as well as to District personnel upon request. [District Rule 4622] Federally Enforceable Through Title V Permit
30. The permittee shall maintain monthly and annual gasoline throughput records. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
31. All records required by this permit shall be retained on-site for a period of at least five years and shall be made available for District inspection upon request. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit

ATTACHMENT C

Permit Application

San Joaquin Valley Air Pollution Control District

www.valleyair.org

RECEIVED

JUL 24 2014

Permit Application For:

SJVAPCD
Southern Region

ADMINISTRATIVE AMENDMENT MINOR MODIFICATION SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: Berry Petroleum Company, LLC	
2. MAILING ADDRESS: STREET/P.O. BOX: 5201 Truxtun Ave., Suite 100	
CITY: Bakersfield	STATE: CA 9-DIGIT ZIP CODE: 93309
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED: STREET: SMWSS CITY: _____ _____ ¼ SECTION _____ TOWNSHIP _____ RANGE _____	INSTALLATION DATE:
4. GENERAL NATURE OF BUSINESS: Oil and gas production	
5. DESCRIPTION OF EQUIPMENT OR MODIFICATION FOR WHICH APPLICATION IS MADE (include Permit #'s if known, and use additional sheets if necessary) Implement 1 Authority to Construct for an aboveground gasoline tank S-1246-182-5	
6. TYPE OR PRINT NAME OF APPLICANT: Shamim Reza	TITLE OF APPLICANT: Environmental Specialist
7. SIGNATURE OF APPLICANT: 	DATE: 7/24/14 PHONE: (661) 616-3889 FAX: EMAIL: sreza@linnenergy.com

For APCD Use Only:

DATE STAMP	FILING FEE RECEIVED: \$ _____ CHECK#: _____
	DATE PAID: _____
	PROJECT NO: S-1143236 FACILITY ID: S-1246

San Joaquin Valley Unified Air Pollution Control District

TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)


- SIGNIFICANT PERMIT MODIFICATION ADMINISTRATIVE
 MINOR PERMIT MODIFICATION AMENDMENT

COMPANY NAME: Berry Petroleum Company, LLC.	FACILITY ID: S-1246
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: Berry Petroleum Company, LLC.	
3. Agent to the Owner: Tim Crawford	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:



Signature of Responsible Official



Date

Robert Boston

Name of Responsible Official (please print)

Manager of EHS

Title of Responsible Official (please print)

ATTACHMENT D

Current Title V PTO

S-1246-182-4

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1246-182-4

EXPIRATION DATE: 03/31/2016

SECTION: 31 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:

GASOLINE DISPENSING OPERATION WITH ONE 2,000 GALLON TRUSCO SUPERVAULT ABOVEGROUND STORAGE TANK SERVED BY TWO-POINT PHASE I VAPOR RECOVERY SYSTEM, AND 1 FUELING POINT WITH 1 GASOLINE DISPENSING NOZZLE SERVED BY BALANCE PHASE II VAPOR RECOVERY SYSTEM (G-70-142-B)

PERMIT UNIT REQUIREMENTS

1. The Phase I and Phase II vapor recovery systems shall be installed and maintained in accordance with the manufacturer specifications and the ARB Executive Orders specified in this permit, including applicable rules and regulations of the Division of Measurement Standards of the Department of Food and Agriculture, the Office of the State Fire Marshal of the Department of Forestry and Fire Protection, the Division of Occupational Safety and Health of the Department of Industrial Relations, and the Division of Water Quality of the State Water Resources Control Board that have been made conditions of the certification. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
2. This gasoline storage and dispensing equipment shall not be used in retail sales, where gasoline dispensed by the unit is subject to payment of California sales tax on gasoline sales. [District Rule 4622] Federally Enforceable Through Title V Permit
3. The storage container shall be installed, maintained, and operated such that they are leak-free. [District Rule 4621] Federally Enforceable Through Title V Permit
4. The Phase I and Phase II vapor recovery systems and gasoline dispensing equipment shall be maintained without leaks as determined in accordance with the test method specified in this permit. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
5. A leak is defined as the dripping of VOC-containing liquid at a rate of more than three (3) drops per minute, or the detection of any gaseous or vapor emissions with a concentration of total organic compound greater than 10,000 ppmv, as methane, above background when measured in accordance with EPA Test Method 21. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
6. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo container, which attest to the vapor integrity of the container. [District Rule 4621] Federally Enforceable Through Title V Permit
7. No person shall operate any ARB certified Phase II vapor recovery system or any portion thereof that has a major defect or an equipment defect that is identified in any applicable ARB Executive Order until the following conditions have been met: 1) the defect has been repaired, replaced, or adjusted as necessary to correct the defect; 2) the District has been notified, and the District has reinspected the system or authorized the system for use (such authorization shall not include the authority to operate the equipment prior to the correction of the defective components); and 3) all major defects, after repair, are duly entered into the Operations and Maintenance (O&M) manual. [District Rule 4622] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

8. Upon identification of any major defects, the permittee shall tag "Out-of-Order" all dispensing equipment for which vapor recovery has been impaired. Tagged equipment shall be rendered inoperable and the tag(s) shall not be removed until the defective equipment has been repaired, replaced, or adjusted, as necessary. In the case of defects identified by the District, tagged equipment shall be rendered inoperable, and the tag shall not be removed until the District has been notified of the repairs, and the District has either reinspected the system or authorized the tagged equipment for use. [District Rule 4622] Federally Enforceable Through Title V Permit
9. The permittee shall implement a periodic maintenance inspection program for the certified Phase II vapor recovery system consistent with the requirements of this permit. The program shall be documented in an operation and maintenance (O&M) manual and shall at a minimum contain the following information: 1) copies of all vapor recovery performance tests; 2) all applicable ARB Executive Orders, Approval Letters, and District Permits; 3) the manufacturer's specifications and instructions for installation, operation, repair, and maintenance required pursuant to ARB Certification Procedure CP-201, and any additional instruction provided by the manufacturer; 4) system and/or component testing requirements, including test schedules and passing criteria for each of the standard tests required by this permit (the owner/operator may include any non-ARB required diagnostic and other tests as part of the testing requirements), and 5) additional O&M instructions, if any, that are designed to ensure compliance with the applicable rules, regulations, ARB Executive Orders, and District permit conditions, including replacement schedules for failure or wear prone components. [District Rule 4622] Federally Enforceable Through Title V Permit
10. The permittee shall conduct periodic maintenance inspections based on the greatest monthly throughput of gasoline dispensed by the facility in the previous year as follows: A) less than 2,500 gallons - one day per month; B) 2,500 to less than 25,000 gallons - one day per week; or C) 25,000 gallons or greater - five days per week. All inspections shall be documented within the O & M Manual. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
11. Periodic maintenance inspections of the Phase I vapor recovery system shall include, at a minimum, verification that 1) the fill caps and vapor caps are not missing, damaged, or loose; 2) the fill cap gasket and vapor cap gaskets are not missing or damaged; 3) the fill adapter and vapor adapter are securely attached to the risers; 4) where applicable, the spring-loaded submerged fill tube seals properly against the coaxial tubing; 5) the dry break (poppet-valve) is not missing or damaged; and 6) the submerged fill tube is not missing or damaged. [District Rule 4621] Federally Enforceable Through Title V Permit
12. Periodic maintenance inspections of the Phase II vapor recovery system shall include, at a minimum, verification that 1) the fueling instructions required by this permit are clearly displayed with the appropriate toll-free complaint phone number and toxic warning signs; 2) the following nozzle components are in place and in good condition as specified in ARB Executive Order as applicable: faceplate/facecone, bellows, latching device spring, vapor check valve, spout (proper diameter/vapor collection holes), insertion interlock mechanism, automatic shut-off mechanism, and hold open latch (unless prohibited by law or the local fire control authority); 3) the hoses are not torn, flattened or crimped; 4) the vapor path of the coaxial hoses associated with bellows equipped nozzles does not contain more than 100 ml of liquid if applicable; and 5) the vapor processing unit is functioning properly, for operations that are required to have or possess such a unit. [District Rule 4622] Federally Enforceable Through Title V Permit
13. In the event of a separation due to a drive off, the permittee shall, unless otherwise specified in the applicable ARB Executive Order, conduct a visual inspection of the affected equipment and either 1) perform qualified repairs on any damaged components and conduct applicable re-verification tests pursuant to the requirements of this permit, or 2) replace the affected nozzles, coaxial hoses, breakaway couplings, and any other damaged components with new or certified rebuilt components that are ARB certified. The activities shall be documented in accordance with the requirements of this permit before placing the affected equipment back in service. [District Rule 4622] Federally Enforceable Through Title V Permit
14. The permittee shall conduct all periodic vapor recovery system performance tests specified in this permit, no more than 30 days before or after the required compliance testing date, unless otherwise required under the applicable ARB Executive Order. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
15. The permittee shall perform and pass a Static Leak Test for Aboveground Tanks using ARB TP-201.3B or TP-206.3 at least once every 12 months. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

16. A person conducting testing of, or repairs to, a certified vapor recovery system shall be in compliance with District Rule 1177 (Gasoline Dispensing Facility Tester Certification). [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
17. A person performing installation of, or maintenance on, a certified Phase I or Phase II vapor recovery system shall be certified by the ICC for Vapor Recovery System Installation and Repair, or work under the direct and personal supervision of an individual physically present at the work site who is certified. The ICC certification shall be renewed every 24 months. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
18. Proof of the ICC certification and all other certifications required by the Executive Order and installation and operation manual shall be made available onsite. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
19. The permittee shall notify the District at least 7 days prior to each performance test. The test results shall be submitted to the District no later than 30 days after the completion of each test. [District Rule 4621] Federally Enforceable Through Title V Permit
20. The permittee shall maintain a copy of all test results. The test results shall be dated and shall contain the name, address, and telephone number of the company responsible for system installation and testing. [District Rule 4622] Federally Enforceable Through Title V Permit
21. The permittee shall maintain on the premises a log of any repairs made to the certified Phase I or Phase II vapor recovery system. The repair log shall include the following: 1) date and time of each repair; 2) the name and applicable certification numbers of the person(s) who performed the repair, and if applicable, the name, address and phone number of the person's employer; 3) description of service performed; 4) each component that was repaired, serviced, or removed; 5) each component that was installed as replacement, if applicable; and 6) receipts or other documents for parts used in the repair and, if applicable, work orders which shall include the name and signature of the person responsible for performing the repairs. [District Rule 4622] Federally Enforceable Through Title V Permit
22. The O&M manual shall be kept at the dispensing operation and made available to any person who operates, inspects, maintains, repairs, or tests the equipment at the operation as well as to District personnel upon request. [District Rule 4622] Federally Enforceable Through Title V Permit
23. The permittee shall maintain monthly and annual gasoline throughput records. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
24. All records required by this permit shall be retained on-site for a period of at least five years and shall be made available for District inspection upon request. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
25. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVAPCD Rules 4621 except section 5.2.2 (as amended June 18, 1998), 4622 (as amended September 19, 2002), and 4623, section 5.4 (as amended May 19, 2005). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
26. This unit is not equipment used for light crude oil and gas production, natural gas processing, nor organic liquid loading. Therefore, the requirements of Kern County Rule 412.1 and 413 do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
27. This permit unit is not equipment used for light crude oil and gas production, natural gas processing, nor organic liquid loading, and is not an internal or external floating roof tank with a capacity of 19,800 gallons or more. Therefore, the requirements of District Rule 4403 (as amended April 20, 2005), 4623 except section 5.4 (as amended May 19, 2005), and 4624 (as amended December 17, 1992) do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
28. This permit unit is not associated with loading at a bulk gasoline terminal (as defined in 40 CFR \pm 60.501). Therefore, the requirements of 40 CFR 60 Subpart XX do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.