



DEC 17 2009

Gerardo C. Rios, Chief  
Permits Office  
Air Division  
U.S. EPA - Region IX  
75 Hawthorne St  
San Francisco, CA 94105

Re: **Notice of Minor Title V Permit Modification**  
**District Facility # C-311**  
**Project # C-1090255**

Dear Mr. Rios:

Enclosed for you to review is an application for minor Title V permit modification for the facility identified above. Chevron USA Inc. is proposing a Title V minor permit modification to incorporate the recently issued Authorities to Construct C-311-52-14 and -53-15 into the Title V operating permit. The modifications will consist of the installation of new piping and design upgrades to the radiant and convection section on the steam generators.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued Authorities to Construct C-311-52-14 and -53-15, application, and previous Title V permit. Please submit your written comments on this project within the 45-day comment period that begins on the date you receive this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney at (559) 230-5900.

Sincerely,



David Warner  
Director of Permit Services

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



**DEC 17 2009**

Larry Landis  
Chevron USA Inc.  
P.O. Box 1392  
Bakersfield, CA 93302

**Re: Notice of Minor Title V Permit Modification  
District Facility # C-311  
Project # C-1090255**

Dear Mr. Landis:

Enclosed is the District's analysis of your application for minor Title V permit modification for the facility identified above. You proposed a Title V minor permit modification to incorporate recently issued Authorities to Construct C-311-52-14 and -53-15 into the Title V operating permit. The modifications will consist of the installation of new piping and design upgrades to the radiant and convection section on the steam generators.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued Authorities to Construct C-311-52-14 and -53-15, application, and previous Title V permit. This project will be subject to a 45-day EPA commenting period prior to the District taking final action.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney at (559) 230-5900.

Sincerely,

David Warner  
Director of Permit Services

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

# **TITLE V APPLICATION REVIEW**

Minor Modification  
Project #: C-1090255

Engineer: Derek Fukuda  
Date: December 11, 2009

Facility Number: C-311  
Facility Name: Chevron USA Inc.  
Mailing Address: P.O. Box 1392  
Bakersfield, CA 93302

Contact Name: Larry Landis  
Phone: (661) 654-7141

Responsible Official: William Fall  
Title: Health, Environment and Safety Manager

---

## **I. PROPOSAL**

Chevron USA, Inc. is proposing a Title V minor permit modification to incorporate the recently issued Authorities to Construct (ATC) C-311-52-14 and -53-15 into the Title V operating permit. The modifications will consist of the installation of new piping and design upgrades to the radiant and convection section on the steam generators.

The purpose of this evaluation is to identify all applicable requirements, determine if the facility will comply with the applicable requirements and to provide the legal and factual basis for the proposed revisions.

## **II. FACILITY LOCATION**

Heavy Oil Production (Coalinga Oil Field) in Fresno County, CA  
NE/4 Section 6C Township 20S Range 15E

### III. EQUIPMENT DESCRIPTION

**C-311-52-17:** 58.5 MMBTU/HR SG STRUTHERS THERMOFLOOD STEAM GENERATOR #6-32, MODEL OH-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GLE LOW-NOX BURNER, FLUE GAS RECIRCULATION SYSTEM, AND AN OXYGEN CONTROLLER

**C-311-53-18:** 58.5 MMBTU/HR STRUTHERS THERMOFLOOD STEAM GENERATOR #6-33, MODEL OH-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GLE LOW-NOX BURNER, FLUE GAS RECIRCULATION SYSTEM, AND AN OXYGEN CONTROLLER

### IV. SCOPE OF EPA AND PUBLIC REVIEW

This change to a Title V permit is considered to be a minor modification and, as such, requires no public review.

### V. APPLICABLE REQUIREMENTS

District Rule 2520, Federally Mandated Operating Permits (Adopted June 21, 2001)

### VI. DESCRIPTION OF PROPOSED MODIFICATIONS

Chevron USA is proposing to modify their existing permits by installing new piping and design upgrades to the radiant and convection section on the steam generators. The proposed upgrades will not increase or affect the heat input capacity or permitted emissions of the affected steam generators in this project. The exceptions will be listed under the specific permit units below:

C-311-52-17:

Permit conditions #1 through #43 on current PTO C-311-52-13 have been included as permit conditions #1 through #43 on PTO C-311-52-17.

C-311-53-18:

Permit conditions #1 through #43 on current PTO C-311-53-14 have been included as permit conditions #1 through #43 on PTO C-311-53-18.

## VII. COMPLIANCE

In accordance with Rule 2520, 3.20, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;
2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;
3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;
4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include:
  - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
  - b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
6. Do not seek to consolidate overlapping applicable requirements.

In accordance with Rule 2520, the application meets the procedural requirements of section 11.4 by including;

1. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
2. The source's suggested draft permit; and
3. Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used.

## VIII. ATTACHMENTS

- A. Proposed Modified Title V Operating Permit No.'s C-311-52-17 and -53-18
- B. Authorities to Construct No. C-311-52-14 and -53-15
- C. Application
- D. Previous Title V Operating Permit No.'s C-311-52-13 and -53-14

# ATTACHMENT A

Proposed Modified Title V Operating Permit No.'s  
(C-311-52-17 and -53-18)

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** C-311-52-17

**EXPIRATION DATE:** 12/31/2005

**SECTION:** 6 **TOWNSHIP:** 20S **RANGE:** 15E

**EQUIPMENT DESCRIPTION:**

58.5 MMBTU/HR SG STRUTHERS THERMOFLOOD STEAM GENERATOR #6-32, MODEL 0H-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GLE LOW-NOX BURNER, FLUE GAS RECIRCULATION SYSTEM, AND AN OXYGEN CONTROLLER

## PERMIT UNIT REQUIREMENTS

---

1. This unit shall be fired exclusively with natural gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Total gas consumption of this unit shall not exceed either of the following limits: 1,404 MMBtu/day or 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in the fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO<sub>2</sub>, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801] Federally Enforceable Through Title V Permit
6. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO<sub>2</sub>. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. When complying with SO<sub>x</sub> emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SO<sub>x</sub> emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO<sub>x</sub>) emissions shall not exceed 140 lb/hr, calculated as NO<sub>2</sub>. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Emissions from the steam generator shall not exceed any of the following limits: 0.140 lb-SO<sub>x</sub>/MMBtu, 0.005 lb-PM10/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO<sub>x</sub> @ 3% O<sub>2</sub>, equivalent to 0.0182 lb-NO<sub>x</sub>/MMBtu or 50 ppmvd CO @ 3% O<sub>2</sub>, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO<sub>x</sub>/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
17. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO<sub>x</sub>/day, 8,332 lb-NO<sub>x</sub>/yr, 51.9 lb-CO/day, or 16,939 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NO<sub>x</sub> and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit
19. NO<sub>x</sub>, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2520, 9.3.2, 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
22. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The source test plan shall indicate which test method shall be used to demonstrate compliance. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. The results of each source test shall be submitted to the District within 60 days after completion of the test. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
25. NO<sub>x</sub> emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
26. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
27. Stack gas oxygen (O<sub>2</sub>) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. Stack gas moisture content shall be determined using EPA Method 4. [District NSR Rule] Federally Enforceable Through Title V Permit
29. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
30. The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
31. If either the NO<sub>x</sub> or CO concentrations corrected to 3% O<sub>2</sub>, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
32. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
33. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 3% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
34. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
35. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

36. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
37. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
38. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for natural gas used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
40. Permittee shall maintain records of daily natural gas consumption. [District Rule 1070] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
42. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** C-311-53-18

**EXPIRATION DATE:** 12/31/2005

**SECTION:** 6C **TOWNSHIP:** 20S **RANGE:** 15E

**EQUIPMENT DESCRIPTION:**

58.5 MMBTU/HR STRUTHERS THERMOFLOOD STEAM GENERATOR #6-33, MODEL OH-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GLE LOW-NOX BURNER, FLUE GAS RECIRCULATION SYSTEM, AND AN OXYGEN CONTROLLER

## PERMIT UNIT REQUIREMENTS

---

1. This unit shall be fired exclusively with natural gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Total gas consumption of this unit shall not exceed either of the following limits: 1,404 MMBtu/day or 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in the fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO<sub>2</sub>, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801] Federally Enforceable Through Title V Permit
6. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO<sub>2</sub>. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. When complying with SO<sub>x</sub> emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SO<sub>x</sub> emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO<sub>x</sub>) emissions shall not exceed 140 lb/hr, calculated as NO<sub>2</sub>. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Emissions from the steam generator shall not exceed any of the following limits: 0.140 lb-SO<sub>x</sub>/MMBtu, 0.005 lb-PM10/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO<sub>x</sub> @ 3% O<sub>2</sub>, equivalent to 0.0182 lb-NO<sub>x</sub>/MMBtu or 50 ppmvd CO @ 3% O<sub>2</sub>, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO<sub>x</sub>/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
17. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO<sub>x</sub>/day, 8,332 lb-NO<sub>x</sub>/yr, 51.9 lb-CO/day, or 16,939 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NO<sub>x</sub> and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit
19. NO<sub>x</sub>, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2520, 9.3.2, 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
22. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The source test plan shall indicate which test method shall be used to demonstrate compliance. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

23. The results of each source test shall be submitted to the District within 60 days after completion of the test. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
25. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
26. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
27. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. Stack gas moisture content shall be determined using EPA Method 4. [District NSR Rule] Federally Enforceable Through Title V Permit
29. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
30. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
31. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
32. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
33. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
34. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
35. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

36. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
37. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
38. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for natural gas used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
40. Permittee shall maintain records of daily natural gas consumption. [District Rule 1070] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
42. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# **ATTACHMENT B**

**Authorities to Construct No.'s  
(C-311-52-14 and -53-15)**



**San Joaquin Valley**  
**AIR POLLUTION CONTROL DISTRICT**

**AUTHORITY TO CONSTRUCT**

**PERMIT NO:** C-311-52-14

**ISSUANCE DATE:** 06/07/2007

**LEGAL OWNER OR OPERATOR:** CHEVRON USA INC  
**MAILING ADDRESS:** PO BOX 1392  
 BAKERSFIELD, CA 93302

**LOCATION:** HEAVY OIL PRODUCTION  
 FRESNO COUNTY, CA

**SECTION:** 6 **TOWNSHIP:** 20S **RANGE:** 15E

**EQUIPMENT DESCRIPTION:**  
 MODIFICATION OF 58.5 MMBTU/HR SG STRUTHERS THERMOFLOOD STEAM GENERATOR #6-32, MODEL 0H-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GLE LOW-NOX BURNER, FLUE GAS RECIRCULATION SYSTEM, AND AN OXYGEN CONTROLLER: REDESIGN CONVECTION/RADIANT SECTIONS


**CONDITIONS**

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. This Authority to Construct (ATC) cancels and supersedes {replaces} ATC C-0311-52-10. [District Rule 2201] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
5. This unit shall be fired exclusively with natural gas. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Total gas consumption of this unit shall not exceed either of the following limits: 1,404 MMBtu/day or 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
7. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in the fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Sayed Sadredin, Executive Director / APCO

  
 DAVID WARNER, Director of Permit Services

C-311-52-14 - Jun 7 2007 11:27AM - FUKUDAD - Joint Inspection NOT Required

8. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO<sub>2</sub>, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
9. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801] Federally Enforceable Through Title V Permit
10. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO<sub>2</sub>. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
11. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. When complying with SO<sub>x</sub> emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
13. If the unit is fired on noncertified gaseous fuel and compliance with SO<sub>x</sub> emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
14. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
15. Nitrogen oxide (NO<sub>x</sub>) emissions shall not exceed 140 lb/hr, calculated as NO<sub>2</sub>. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
16. Emissions from the steam generator shall not exceed any of the following limits: 0.140 lb-SO<sub>x</sub>/MMBtu, 0.005 lb-PM<sub>10</sub>/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO<sub>x</sub> @ 3% O<sub>2</sub>, equivalent to 0.0182 lb-NO<sub>x</sub>/MMBtu or 50 ppmvd CO @ 3% O<sub>2</sub>, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
18. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO<sub>x</sub>/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
21. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NOx/day, 8,332 lb-NOx/yr, 51.9 lb-CO/day, or 16,939 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit
23. NOx, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2520, 9.3.2, 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
25. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
26. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The source test plan shall indicate which test method shall be used to demonstrate compliance. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The results of each source test shall be submitted to the District within 60 days after completion of the test. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
29. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
30. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
31. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
32. Stack gas moisture content shall be determined using EPA Method 4. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
34. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

35. If either the NO<sub>x</sub> or CO concentrations corrected to 3% O<sub>2</sub>, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
36. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 3% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
38. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
39. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
40. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
41. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
42. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for natural gas used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
44. Permittee shall maintain records of daily natural gas consumption. [District Rule 1070] Federally Enforceable Through Title V Permit
45. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
46. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

47. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit



**San Joaquin Valley**  
AIR POLLUTION CONTROL DISTRICT

**AUTHORITY TO CONSTRUCT**

**PERMIT NO:** C-311-53-15

**ISSUANCE DATE:** 06/07/2007

**LEGAL OWNER OR OPERATOR:** CHEVRON USA INC  
**MAILING ADDRESS:** PO BOX 1392  
BAKERSFIELD, CA 93302

**LOCATION:** HEAVY OIL PRODUCTION  
FRESNO COUNTY, CA

**SECTION:** 6C **TOWNSHIP:** 20S **RANGE:** 15E

**EQUIPMENT DESCRIPTION:**

MODIFICATION OF 58.5 MMBTU/HR STRUTHERS THERMOFLOOD STEAM GENERATOR #6-33, MODEL OH-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GLE LOW-NOX BURNER (OR DISTRICT APPROVED EQUIVALENT), FLUE GAS RECIRCULATION SYSTEM, AND AN OXYGEN CONTROLLER: REDESIGN CONVECTION/RADIANT SECTIONS

**CONDITIONS**

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. This Authority to Construct (ATC) cancels and supersedes {replaces} ATC C-0311-53-11. [District Rule 2201] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
5. This unit shall be fired exclusively with natural gas. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Total gas consumption of this unit shall not exceed either of the following limits: 1,404 MMBtu/day or 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
7. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in the fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadtehdin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

C-311-53-15: Jun 7 2007 11:27AM - FUKUDAD : Joint Inspection NOT Required

Central Regional Office • 1990 E. Gettysburg Ave. • Fresno, CA 93726 • (559) 230-5900 • Fax (559) 230-6061

Printed on recycled paper

8. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO<sub>2</sub>, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
9. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801] Federally Enforceable Through Title V Permit
10. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO<sub>2</sub>. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
11. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. When complying with SO<sub>x</sub> emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084; D 3246 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
13. If the unit is fired on noncertified gaseous fuel and compliance with SO<sub>x</sub> emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
14. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
15. Nitrogen oxide (NO<sub>x</sub>) emissions shall not exceed 140 lb/hr, calculated as NO<sub>2</sub>. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
16. Emissions from the steam generator shall not exceed any of the following limits: 0.140 lb-SO<sub>x</sub>/MMBtu, 0.005 lb-PM<sub>10</sub>/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO<sub>x</sub> @ 3% O<sub>2</sub>, equivalent to 0.0182 lb-NO<sub>x</sub>/MMBtu or 50 ppmvd CO @ 3% O<sub>2</sub>, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
18. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO<sub>x</sub>/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
21. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NOx/day, 8,332 lb-NOx/yr, 51.9 lb-CO/day, or 16,939 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit
23. NOx, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2520, 9.3.2, 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
25. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
26. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The source test plan shall indicate which test method shall be used to demonstrate compliance. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The results of each source test shall be submitted to the District within 60 days after completion of the test. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
29. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
30. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
31. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
32. Stack gas moisture content shall be determined using EPA Method 4. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
34. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

35. If either the NO<sub>x</sub> or CO concentrations corrected to 3% O<sub>2</sub>, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
36. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 3% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
38. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
39. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
40. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
41. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
42. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for natural gas used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
44. Permittee shall maintain records of daily natural gas consumption. [District Rule 1070] Federally Enforceable Through Title V Permit
45. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
46. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

# ATTACHMENT C

Application

# San Joaquin Valley Air Pollution Control District Received

www.valleyair.org

JAN 27 2009

SJVUAPCD

## Permit Application For:

[ ] ADMINISTRATIVE AMENDMENT    X[ ] MINOR MODIFICATION    [ ] SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: <p style="text-align: center;">CHEVRON USA INC.</p>	
2. MAILING ADDRESS:  STREET/P.O. BOX: <u>PO BOX 1392</u>  CITY: <u>BAKERSFIELD</u> STATE: <u>CA</u> 9-DIGIT ZIP CODE: <u>93302</u>	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED:  STREET: <u>COALINGA OIL FIELD</u> CITY: _____  _____ ¼ SECTION <u>6C</u> TOWNSHIP <u>20S</u> RANGE <u>15E</u>	INSTALLATION DATE:
4. GENERAL NATURE OF BUSINESS: CRUDE OIL PRODUCTION	
5. DESCRIPTION OF EQUIPMENT OR MODIFICATION FOR WHICH APPLICATION IS MADE (include Permit #'s if known, and use additional sheets if necessary)  ATC C-311-52-14 and C-311-53-15 Redesign of Convection/Radiant Sections.	
6. TYPE OR PRINT NAME OF APPLICANT: William Fall	TITLE OF APPLICANT: HES Manager
7. SIGNATURE OF APPLICANT:  <i>William A. Landilr for W. Fall</i>	DATE: 1/20/2009  PHONE: ( 661 )654-7141 FAX: ( 661 )654-7606 EMAIL: landilr@chevron.com

**For APCD Use Only:**

DATE STAMP	FILING FEE RECEIVED: \$ <u>0</u> CHECK#: _____  DATE PAID: _____  PROJECT NO: <u>C-1090255</u> FACILITY ID: <u>C-311</u>
------------	--

Received  
JAN 27 2009  
SJVUAPCD

San Joaquin Valley  
Unified Air Pollution Control District

TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)

- SIGNIFICANT PERMIT MODIFICATION                       ADMINISTRATIVE  
 MINOR PERMIT MODIFICATION                                       AMENDMENT

COMPANY NAME: CHEVRON USA INC.	FACILITY ID: C- 311
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name:	
3. Agent to the Owner:	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

William Fall  
Signature of Responsible Official

1/20/09  
Date

William Fall  
Name of Responsible Official (please print)

HES Manager  
Title of Responsible Official (please print)

# ATTACHMENT D

Previous Title V Operating Permit No.'s  
(C-311-52-13 and -53-14)

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-52-13

EXPIRATION DATE: 12/31/2005

SECTION: 6 TOWNSHIP: 20S RANGE: 15E

## EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR SG STRUTHERS THERMOFLOOD STEAM GENERATOR #6-32, MODEL 0H-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GLE LOW-NOX BURNER, FLUE GAS RECIRCULATION SYSTEM, AND AN OXYGEN CONTROLLER

## PERMIT UNIT REQUIREMENTS

---

1. This unit shall be fired exclusively with natural gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Total gas consumption of this unit shall not exceed either of the following limits: 1,404 MMBtu/day or 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in the fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO<sub>2</sub>, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801] Federally Enforceable Through Title V Permit
6. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO<sub>2</sub>. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. When complying with SO<sub>x</sub> emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SO<sub>x</sub> emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO<sub>x</sub>) emissions shall not exceed 140 lb/hr, calculated as NO<sub>2</sub>. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Emissions from the steam generator shall not exceed any of the following limits: 0.140 lb-SO<sub>x</sub>/MMBtu, 0.005 lb-PM<sub>10</sub>/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO<sub>x</sub> @ 3% O<sub>2</sub>, equivalent to 0.0182 lb-NO<sub>x</sub>/MMBtu or 50 ppmvd CO @ 3% O<sub>2</sub>, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO<sub>x</sub>/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
17. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO<sub>x</sub>/day, 8,332 lb-NO<sub>x</sub>/yr, 51.9 lb-CO/day, or 16,939 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NO<sub>x</sub> and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit
19. NO<sub>x</sub>, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2520, 9.3.2, 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
22. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The source test plan shall indicate which test method shall be used to demonstrate compliance. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. The results of each source test shall be submitted to the District within 60 days after completion of the test. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
25. NO<sub>x</sub> emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
26. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
27. Stack gas oxygen (O<sub>2</sub>) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. Stack gas moisture content shall be determined using EPA Method 4. [District NSR Rule] Federally Enforceable Through Title V Permit
29. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
30. The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
31. If either the NO<sub>x</sub> or CO concentrations corrected to 3% O<sub>2</sub>, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
32. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
33. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 3% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
34. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
35. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
37. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
38. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for natural gas used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
40. Permittee shall maintain records of daily natural gas consumption. [District Rule 1070] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
42. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-53-14

EXPIRATION DATE: 12/31/2005

SECTION: 6C TOWNSHIP: 20S RANGE: 15E

## EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR STRUTHERS THERMOFLOOD STEAM GENERATOR #6-33, MODEL OH-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GLE LOW-NOX BURNER (OR DISTRICT APPROVED EQUIVALENT), FLUE GAS RECIRCULATION SYSTEM, AND AN OXYGEN CONTROLLER

## PERMIT UNIT REQUIREMENTS

---

1. This unit shall be fired exclusively with natural gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Total gas consumption of this unit shall not exceed either of the following limits: 1,404 MMBtu/day or 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in the fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO<sub>2</sub>, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801] Federally Enforceable Through Title V Permit
6. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO<sub>2</sub>. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. When complying with SO<sub>x</sub> emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SO<sub>x</sub> emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO<sub>x</sub>) emissions shall not exceed 140 lb/hr, calculated as NO<sub>2</sub>. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Emissions from the steam generator shall not exceed any of the following limits: 0.140 lb-SO<sub>x</sub>/MMBtu, 0.005 lb-PM<sub>10</sub>/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO<sub>x</sub> @ 3% O<sub>2</sub>, equivalent to 0.0182 lb-NO<sub>x</sub>/MMBtu or 50 ppmvd CO @ 3% O<sub>2</sub>, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO<sub>x</sub>/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
17. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO<sub>x</sub>/day, 8,332 lb-NO<sub>x</sub>/yr, 51.9 lb-CO/day, or 16,939 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NO<sub>x</sub> and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit
19. NO<sub>x</sub>, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2520, 9.3.2, 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
22. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The source test plan shall indicate which test method shall be used to demonstrate compliance. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

23. The results of each source test shall be submitted to the District within 60 days after completion of the test. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
25. NO<sub>x</sub> emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
26. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
27. Stack gas oxygen (O<sub>2</sub>) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. Stack gas moisture content shall be determined using EPA Method 4. [District NSR Rule] Federally Enforceable Through Title V Permit
29. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
30. The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
31. If either the NO<sub>x</sub> or CO concentrations corrected to 3% O<sub>2</sub>, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
32. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
33. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 3% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
34. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
35. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
37. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
38. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for natural gas used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
40. Permittee shall maintain records of daily natural gas consumption. [District Rule 1070] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
42. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.