

Effluent Limit Exceedances Report

ID0021997: HARRISON WASTEWATER TREATMENT PLANT, HARRISON, ID 83833

Monitoring Period Date Range: 08/01/2017 to 07/31/2018

Exceedance Details

Monitoring P Outfall	Parameter C	Parameter D	Average Daily	Limit Type	DMR Value
4/30/18	1	310	BOD, 5-day, 20 deg. C	MO AVG	31

dmr_value_c DMR Value L Contains Pot Limit Value Limit Value C Limit Value L % Exceedanc
= mg/L 30 <= mg/L 3

Load Over Lir Number of D Days with Exceedances
30 30