

Hagler, Tom

From: Nichols, Louis
Sent: Thursday, September 19, 2019 5:44 AM
To: Hagler, Tom
Cc: Nguyen, Theresa; Schreifels, Jeremy
Subject: Four Corners
Attachments: 2019-09-18 Annual Hg emissions info between 2016 - 2018 for Four Corner (NM).xlsx

Attached is a spreadsheet with the information you requested. We only have full years Hg emissions data for 2016, 2017, and 2018. We have two quarters of 2019. It is likely that they had an extension of the monitoring and reporting deadline and did not report for 2015. However, you should confirm that with the whoever is in charge of the MATS rule in your region. If you have any further questions, please let me know. Thank you.

Louis P. Nichols
Emissions Monitoring Branch
Clean Air Markets Division
US Environmental Protection Agency
MS 6204M
1200 Pennsylvania Avenue, NW
Washington, DC 20460
202/343-9008

Operating Year	State	Facility Name	Oris Code	Unit Id	Total Op Time	Total Hg Op Time	Heat Input (mmBtu)	Gross Load (MW)	Hg Mass (pounds)	Hg Rate (lb/GWh)
2016	NM	Four Corners Steam Elec Station	2442	4	4,246	4,191	25,578,243	2,800,735	13.73	0.007307269148175
2016	NM	Four Corners Steam Elec Station	2442	5	4,976	4,888	28,192,255	3,123,229	19.1	0.008402893003273
2017	NM	Four Corners Steam Elec Station	2442	4	6,628	6,394	38,599,749	4,230,924	19.98	0.006034311385674
2017	NM	Four Corners Steam Elec Station	2442	5	4,723	4,541	26,072,764	2,844,296	18.51	0.007209284963554
2018	NM	Four Corners Steam Elec Station	2442	4	5,034	3,003	33,852,522	3,470,844	5.31	0.004699934065934
2018	NM	Four Corners Steam Elec Station	2442	5	6,909	6,401	48,352,655	4,679,516	9.35	0.002563391743446