

**Attachment D: Wastewater Flow Schematic**

TITLE	AVG. RATE (MGPD)
RIVER MAKE-UP; COOLING WATER INTAKE	17-28
RECIRCULATED COOLING WATER POND DISCHARGE/BLOW-DOWN	3-14.6
SYSTEM EVAPORATION	13.3
SERVICE & RECIRCULATED COOLING WATER INTAKE*	1000-1726.7
RECIRCULATED COOLING WATER RETURN	1000-1713.6
COMBINED WASTE STREAMS *	13.0
CWTP (L.V.W.) DISCHARGE	13.0
SANITARY SEWAGE	.027-.04
CHEMICAL METAL CLEANING WASTES	.100
FLUE GAS DESULFURIZATION WASTEWATER	0.8-1.4

INCLUDES IN PLANT STORM WATER RUNOFF

