

Exhibit I:

December 11, 2013, Letter from Tetra Tech to MassDEP including Attachment 1 (the “December 11, 2013 Letter”);

January 10, 2014, Letter from Tetra Tech to MassDEP (the “January 10, 2014 Letter”);

January 16, 2014, Letter from Tetra Tech to MassDEP (the “January 16, 2014 Letter”) and

January 21, 2014, Letter from Tetra Tech to MassDEP (the “January 21, 2014 Letter”)



TETRA TECH

December 11, 2013

Mr. James Belsky, Permit Chief
MassDEP Northeast Region
205B Lowell Street
Wilmington, MA 01887

**Re: Major Comprehensive Plan Application No. NE-12-022
Transmittal Number X254064 - Salem Harbor Redevelopment (SHR) Project
Responses to Comments on Draft PSD Permit and Proposed Air Quality Plan
Approval**

Dear Mr. Belsky:

This letter provides responses to comments made by the Environmental Protection Agency Region 1 ("EPA") and the Conservation Law Foundation ("CLF") on the draft PSD permit and proposed Air Quality Plan Approval for the Footprint Power Salem Harbor Development LP ("Footprint" or "Applicant") Salem Harbor Redevelopment Project ("Project"). Additionally, comments made by Healthlink, Inc. in their November 1, 2013 letter related to dispersion modeling and ambient air quality impact analyses are addressed.

Key updated information is contained in Attachment 1 to this letter which contains: 1) updated facility potential-to-emit calculations due primarily to improved emissions guarantees for CO and particulate matter provided by GE, and also as a result of incorporation of a CO catalyst into the design of the auxiliary boiler, 2) revised pollutant-specific PSD applicability based on the updated emissions, and 3) and updated Prevention of Significant Deterioration (PSD) Best Available Control Technology (BACT) analysis.

Listed below are specific comment responses with reference to the attached annotated comment letters by EPA (Attachment 2) and CLF (Attachment 3).

EPA-1: An updated PSD BACT analysis supported with revised potential to emit calculations is contained in Attachment 1.

EPA-2: An updated PSD BACT analysis is contained in Attachment 1. The BACT analysis follows a top-down approach as recommended in the 1990 draft New Source Review Workshop Manual which is available at <http://www.epa.gov/NSR/ttnnsr01/gen/wkshpman.pdf> and MassDEP's June 2011 BACT guidance document which is available at <http://www.mass.gov/dep/air/approvals/bactguid.pdf>

EPA-3: An updated PSD BACT analysis for NO_x emissions is contained in Attachment 1.

EPA-4: The updated PSD BACT analysis contained in Attachment 1 follows the 2011 "top-down" BACT guidance document.

EPA-5: The dispersion modeling analyses are described in Sections 6 and 7 of the December 2012 Comprehensive Plan Approval application. These descriptions are supplemented by analyses described in the April 12, 2013 and June 10, 2013 letters from Tetra Tech to MassDEP. It is our understanding that these materials have been made available to the public.

EPA-6: Pages 3 through 8 of Tetra Tech's April 12, 2013 "First Supplement to Major Comprehensive Plan Application," address the suggestions made by EPA to compile background concentration levels and confirm that the difference between the PM_{2.5} National Ambient Air Quality Standards (NAAQS) and PM_{2.5} background concentrations is greater than the applicable PM_{2.5} significant impact level (SIL). PM_{2.5} is the only pollutant addressed in Tetra Tech's letter because it is the only pollutant addressed in the court decision referenced in EPA's comment. The key text from Tetra Tech's April 12 letter is as follows:

Key examples in the Appeals Court decision supporting the vacature and remand involved cases in which the ambient air quality background is very close to the NAAQS and that is certainly not the case in the Salem region where the PM_{2.5} background is only slightly over half of the NAAQS (see Table 6-10 Revised above). Accordingly, use of the prior PM_{2.5} SILs is appropriate in the case of the ambient air quality impact analysis for the SHR Facility because the background concentrations plus the SILs still leave a significant margin before the NAAQS would come close to being jeopardized.

The following table provides a comparison of the SILs to the difference between the representative background concentrations and the NAAQS for all modeled pollutants and averaging periods.

**Comparison of SILs to the Difference Between Background Concentrations and NAAQS
(All Concentrations in Micrograms per Cubic Meter)**

Pollutant	Averaging Time	Background Concentration	National and Massachusetts Ambient Air Quality Standards	Difference Between Background and NAAQS	Significant Impact Level
PM _{2.5}	24-hr	18.9	35	16.1	1.2
	Annual	7.2	12	4.8	0.3
PM ₁₀	24-hr	41	150	109	5
NO ₂	1-hr	82.3	188	105.7	7.5
	Annual	19.3	100	80.7	1
CO	1-hr	1,030	40,000	38,970	2,000
	8-hr	687	10,000	9,313	500
SO ₂	1-hr	57.6	196	138.4	7.8
	3-hr	60.3	1,300	1,239.7	25
	24-hr	31.4	365	333.6	5
	Annual	5.6	80	74.4	1

As shown on the above table, the difference between the background concentration and NAAQS concentration is significantly greater than the applicable SIL concentration for all pollutants and averaging periods. Therefore, use of the SILs in the dispersion modeling analyses is valid.

CLF-1: The updated PSD BACT analysis contained in Attachment 1 strictly follows federal BACT analysis guidance.

CLF-2: The revised potential to emit calculations demonstrate that updated potential CO emissions are less than 100 tons per year and thus are not subject to federal PSD BACT.

CLF-3: According to GE, the reason the CO emission limit of 2.0 ppmvd is not increased with duct firing but the VOC limit of 1.0 ppmvd is increased to 1.7 ppmvd with duct firing is that duct firing increases the mass emission rate and concentration prior to control more for VOC than for CO. Additionally, the oxidation catalyst is less efficient for controlling VOC emissions than for CO emissions. The result is a higher VOC concentration when duct firing. Neither of these pollutants is subject to federal PSD BACT as shown in Section 3 of Attachment 1.

CLF-4: In addition to emissions reductions for particulates and CO described in Section 2 of Attachment 1 to this letter, Footprint believes that the following changes should be made to the lb/hr emissions limits for no duct firing cases listed in Table 2 of the draft PSD permit:

For NO_x change 18.1 lb/hr to 17.0 lb/hr

For SO₂ change 3.7 lb/hr to 3.5 lb/hr

For H₂SO₄ change 2.3 lb/hr to 2.2 lb/hr

For NH₃ change 6.6 lb/hr to 6.2 lb/hr

For these pollutants, the same maximum lb/hr emissions for both duct firing and unfired (i.e., no duct firing) conditions were used for the draft approvals. We recommend that Footnote 2 to Table 2 be changed to the following:

2. Emission rates are based on burning natural gas in any one combustion turbine at a maximum natural gas firing rate of 2,300 MMBtu/hr, HHV (no duct firing) and 2,449 MMBtu/hr, HHV (duct firing), at 90 degrees F ambient temperature, 14.7 psia ambient pressure, and 60% ambient relative humidity. These constitute worst case emissions.

CLF-5: Page 2 of Tetra Tech's August 6, 2013 letter to MassDEP presents a comparison of the most recent relevant GE and Siemens NO_x start-up and shutdown data. This illustrates that the start-up and shutdown NO_x emissions are lower for the proposed GE turbine than the comparable quick start turbine offered by Siemens (5000F) for the combined cold start-up and shutdown cycle as well as the warm and hot start emissions. The following is the relevant text from the August 6th letter:

The more recent data for the same basic "quick start" Siemens machine (5000F) now has 83 lbs NO_x over 45 minutes. Attachment 2 provides a comparison of this GE and Siemens NO_x startup/shutdown data. For a combined cold start and shutdown, GE now has (89 +10 = 99) lbs NO_x while Siemens has (83 + 20 = 103) lbs NO_x. GE has lower NO_x emissions for both the

warm and hot start. So, based on the latest information, there is no advantage to selecting Siemens over GE for NO_x startup/shutdown emissions.

We were unable to verify the 12 minute start-up cited by CLF for the El Segundo Power project permitted in 2008, and in fact were told by a plant representative that the current Title V Operating Permit for the facility allows for a 1-hour start-up with NO_x emissions of 112 lbs. Siemens also offered no such shortened (12 minute) start-up for the Salem "quick start" project but rather offered a 45 minute cold and warm start comparable to GE's but resulting in the higher overall startup/shutdown cycle emissions as noted above.

CLF-6: The updated PSD BACT analysis for NO_x emissions contained in Attachment 1 addresses start-up and shutdown emissions.

CLF-7, CLF-8, and CLF-9: As described in Attachment 1, neither CO nor VOC emissions are subject to federal PSD BACT. A detailed top down BACT analysis for NO_x emissions from the auxiliary boiler is presented in the updated PSD BACT analysis contained in Attachment 1.

CLF-10: A PM CEMS on a combined cycle plant firing exclusively natural gas is unnecessary and may be of questionable accuracy due to the inherently low emissions from natural gas firing. The requirement of a PM CEMS for this type of source would be unprecedented. The generating units cited by CLF with PM CEMS in the Commonwealth have much higher PM emissions because they fire solid fuels (coal or solid waste).

CLF-11: The updated PSD BACT analysis contained in Attachment 1 includes a case by case top down BACT analysis for PM emissions.

CLF-12: The fuel monitoring requirement for sulfur content in the draft permit is consistent with the requirement in other similar permits such as the permit for Pioneer Valley Energy Center and is compliant with the requirements in the relevant federal New Source Performance Standard of 40 CFR Part 60 Subpart KKKK.

CLF-13 (also related HealthLink comments under sections "NO₂ 1 Hour Ambient Air Modeling Errors" and "NAAQS"): The maximum cumulative 1-hour NO₂ concentration of 166 micrograms per cubic meter listed in the PSD Fact Sheet is a more accurate characterization of the maximum cumulative NO₂ concentration than the concentration listed in the June 2013 Tetra Tech letter to MassDEP. That letter presented the maximum cumulative 1-hour concentration as less than 188 micrograms per cubic meter. There were no changes in the modeling inputs or results from the June letter to the September PSD Fact Sheet. However the 166 micrograms per cubic meter concentration is based on a more refined evaluation of the modeling results to eliminate all cumulative 1-hour NO₂ concentrations to which the Salem Harbor Redevelopment Project had an insignificant impact. Tetra Tech determined that the maximum cumulative 1-hour NO₂ concentration to which the Project contributed significantly (i.e., had a contribution of 7.5 micrograms per cubic meter or greater) is only 166 micrograms per cubic meter, which includes the contribution of the Project. Previously, the review of concentration results had been conducted only to the extent needed to determine that the

maximum concentration to which the Project had a significant impact was less than the NAAQS of 188 micrograms per cubic meter. Elimination of concentrations to which the project has no significant impact is a commonly used and acceptable additional refinement in cumulative modeling compliance assessments (see for example Chapter C, The Air Quality Analysis, Section IV.E, The Compliance Demonstration, of the 1990 NSR Workshop Manual).

CLF-14 and CLF-15: The updated PSD BACT analysis for GHG emissions addresses the projects referenced in the April 17, 2012 letter from Steven Riva of EPA Region 2 to Francis Steitz of the NJ DEP as well as CLF's comment to translate the limits into a thermal efficiency requirement.

CLF-16: Emissions of methane and nitrous oxide are accounted for in the PSD permit in the definition of CO_{2e} in the key to Table 2 and in recordkeeping requirements of Table 4 (items 12 and 22) and reporting requirements of Table 5 (item 19). However, footnotes 11 and 16 to Table 2 should include a reference to a combined CO_{2e} emission factor of 119.0 lb/MMBtu rather than just the 40 CFR Part 75 default 118.9 lb/MMBtu emission factor for CO₂ to account for these additional GHG pollutants. The 119.0 lb/MMBtu factor was used in the emission calculations.

CLF-17: MassDEP provided a thorough and appropriate level of review of all of the proponent's analyses consistent with other PSD permit applications.

CLF-18: As noted in the response to EPA-6 above, pages 3 through 8 of the April 12, 2012 letter from Tetra Tech to MassDEP include a detailed justification that the use of Lynn and Harrison Avenue monitoring data in lieu of site specific preconstruction monitoring data for background concentrations is appropriate and conservative. The response to CLF-13 above addresses the question regarding the reported maximum 1-hour NO₂ concentrations.

CLF-19: Logan Airport meteorological data is representative of the Salem site. The Boston Logan surface station is the closest first order National Weather Service station to the Salem site, located approximately 13 miles southwest. In addition, the Boston Logan surface station is located near the coast and thus is influenced by a similar coastal meteorological regime to that found at the Salem site. The meteorological data set used in the analysis was provided by MassDEP.

CLF-20 (also related HealthLink comments under section "NO₂ 1 Hour Ambient Air Modeling Errors"): Standard modeling procedures were used to determine and justify the use of rural dispersion coefficients and the AERSURFACE data. These were approved by MassDEP prior to their use. Section 6.0 of the December 21, 2012 permit application provides the Air Quality Impact Analysis for the project. The introductory paragraph is as follows:

The dispersion modeling analyses for this project were conducted in accordance with the USEPA's *Guideline on Air Quality Models* (USEPA, November, 2005) and MassDEP's *Modeling Guidance of Significant Stationary Sources of Air Pollution* (MassDEP, June 2011), and as described in the Air Quality Modeling Protocol for the Footprint Power Salem Harbor

Redevelopment Project (submitted to the MassDEP on August 29, 2012). MassDEP concurrence with Protocol methodologies was provided on September 20, 2012.

HealthLink also had a comment that the modeling analysis used an outdated methodology for the determination of rural dispersion coefficients and that surface conditions surrounding the meteorological data anemometer should instead be used. In fact, both techniques must be used today and were used in this analysis. These different techniques are used to develop different model inputs. The 3 km Auer land use technique is used to determine the appropriate model dispersion coefficients and the AERSURFACE techniques are used in the meteorological data preprocessing.

CLF-21: This comment relates to the proposed Air Quality Plan Approval rather than the draft PSD permit. The semi-annual reporting requirements contained in the proposed Air Quality Plan Approval are consistent with the requirements in other similar Plan Approvals such as the permit for Pioneer Valley Energy Center. There are no federal or state requirements for more frequent reporting as recommended by CLF.

CLF-22: Footprint assumes that MassDEP will clarify the venue and procedure for appeals of its final PSD permit Decision as recommended by CLF.

If you have additional questions on these responses or attached updated material, please contact either me at (617) 803-7809 or George Lipka at (617) 443-7545.

Sincerely,



Keith H. Kennedy
Senior Consultant – Energy Programs

Attachments

Attachment 1

Emissions Update and Prevention of Significant Deterioration Best Available Control Technology Report

Salem Harbor Redevelopment Project Salem, Massachusetts



Submitted to:

Massachusetts Department of Environmental Protection
Northeast Region
205B Lowell Street
Wilmington, MA 01887

Prepared on Behalf of:

Footprint Power Salem Harbor Development LP
1140 Route 22 East, Suite 303
Bridgewater, NJ 08807

Prepared by:

Tetra Tech
160 Federal Street
Boston, MA 02110

December 2013

TABLE OF CONTENTS

1.0	INTRODUCTION	1-1
2.0	COMBUSTION TURBINE AND FACILITY EMISSIONS	2-1
2.1	Short-Term Turbine Emissions.....	2-1
2.2	Long-Term Project Emissions.....	2-2
3.0	PREVENTION OF SIGNIFICANT DETERIORATION (PSD) REVIEW APPLICABILITY	3-1
4.0	CONTROL TECHNOLOGY ANALYSIS	4-1
4.1	Combined Cycle Combustion Turbines.....	4-2
4.1.1	Fuel Selection.....	4-2
4.1.2	PSD Best Available Control Technology Assessment for NO _x	4-3
4.1.3	PSD Best Available Control Technology Assessment for PM/PM ₁₀ /PM _{2.5}	4-5
4.1.4	PSD Best Available Control Technology Assessment for Sulfuric Acid Mist (H ₂ SO ₄).....	4-10
4.1.5	Best Available Control Technology Assessment for Greenhouse Gases.....	4-14
4.1.6	Combustion Turbine Startup and Shutdown BACT.....	4-24
4.2	Auxiliary Boiler.....	4-29
4.2.1	Fuel Selection.....	4-29
4.2.2	NO _x	4-32
4.2.3	PM/PM ₁₀ /PM _{2.5}	4-34
4.2.4	H ₂ SO ₄	4-34
4.2.5	GHG.....	4-34
4.3	Emergency Diesel Generator.....	4-35
4.3.1	Fuel Selection.....	4-38
4.3.2	NO _x	4-38
4.3.3	PM/PM ₁₀ /PM _{2.5}	4-39
4.3.4	H ₂ SO ₄	4-42
4.3.5	GHG.....	4-42
4.4	Emergency Fire Pump.....	4-43
4.4.1	Fuel Selection.....	4-46
4.4.2	NO _x	4-46
4.4.3	PM/PM ₁₀ /PM _{2.5}	4-47
4.4.4	H ₂ SO ₄	4-50
4.4.5	GHG.....	4-50
4.5	Auxiliary Cooling Tower.....	4-51

TABLES

Table 2-1.	Short-Term Emission Rates for Combustion Turbine Combined Cycle Units.....	2-1
Table 2-2.	Emission Rates for Auxiliary Boiler.....	2-2
Table 2-3.	Facility-Wide Annual Potential Emissions.....	2-3
Table 2-4.	Combustion Turbine Operating Scenario for Annual CO Emissions.....	2-3
Table 3-1.	Prevention of Significant Deterioration Regulatory Threshold Evaluation.....	3-1
Table 4-1.	Summary of Recent Particulate PSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants.....	4-6
Table 4-2.	Summary Of Recent H ₂ SO ₄ PSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants.....	4-12

Table 4-3.	Summary Of Recent GHG PSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants	4-21
Table 4-4.	Combustion Turbine NO _x SUSD PSD BACT Limits	4-25
Table 4-5.	Summary Of Recent NO _x SUSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants	4-26
Table 4-6.	Auxiliary Boiler Proposed PSD BACT Limits	4-29
Table 4-7.	Summary Of Recent PSD BACT Determinations for Natural Gas Auxiliary Boilers at Large (>100MW) Gas Fired Combined-Cycle Generating Plants for NO _x , PM, H ₂ SO ₄ , GHG	4-30
Table 4-8.	Summary of Auxiliary Boiler Top-Down BACT Analysis for NO _x	4-33
Table 4-9.	Emergency Diesel Generator Proposed PSD BACT Limits	4-35
Table 4-10.	Summary Of Recent PSD BACT Determinations for Emergency Generators at Large (>100MW) Gas Fired Combined-Cycle Generating Plants for NO _x , PM, H ₂ SO ₄ , GHG	4-36
Table 4-11.	750 kW Emergency Generator - Economic Analysis - Selective Catalytic Reduction	4-40
Table 4-12.	750 kW Emergency Generator - Economic Analysis – Active Diesel Particulate Filter.....	4-41
Table 4-13.	Emergency Diesel Fire Pump Proposed PSD BACT Limits	4-43
Table 4-14.	Summary of Recent PSD BACT Determinations for Reciprocating Fire Pump Engines at Large (>100MW) Gas Fired Combined-Cycle Generating Plants for NO _x , PM, H ₂ SO ₄ , GHG	4-44
Table 4-15.	371 hp Emergency Fire Pump - Economic Analysis - Selective Catalytic Reduction ..	4-48
Table 4-16.	371 hp Emergency Fire Pump - Economic Analysis – Active Diesel Particulate Filter.....	4-49
Table 4-17.	Summary of Recent Cooling Tower Particulate BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants	4-53

FIGURES

Figure 4-1.	CO ₂ Pipelines in the United States.....	4-17
-------------	---	------

1.0 INTRODUCTION

This document presents updated information for the Salem Harbor Redevelopment Project (the "Project"). Certain Project emissions have been reduced based on improved performance data obtained from General Electric (GE), in response to various public comments submitted on draft permit documents issued by MassDEP on September 9, 2013. The Prevention of Significant Deterioration (PSD) Best Available Control Technology (BACT) analysis has also been documented in greater detail.

This document includes:

- Updated combustion turbine and facility emissions (Sections 2.0)
- Updated PSD review applicability (Section 3.0)
- Updated PSD BACT analysis (Section 4.0)

The updated emissions presented in this document reflect recent updates to information General Electric (GE) has provided regarding emissions from the equipment selected for the Project, which is the General Electric Model 7FA Series 5 turbine (the "turbine"). That is, the updated information results in significant reductions to proposed emissions of CO and PM for the Project.

CO Emissions. The Applicant has obtained new performance data from GE which indicates not only that that CO will be controlled to within 2.0 ppmvdc at loads \geq MECL (minimum emission compliance load), (as reflected in the public review documents), but also that CO emissions at loads \geq MECL will also not exceed 8.0 lbs/hr, with and without duct firing. This emission cap of 8.0 lb/hr is achievable since the combustion turbines operate very efficiently at high load conditions. Actual CO emissions will be less than 2.0 ppmvdc at high operating loads, which allows for maximum lb/hr emission of CO to remain \leq 8.0 lb/hr.

The Applicant is also now proposing to install a CO oxidation catalyst on the auxiliary boiler. This reduces the auxiliary boiler potential-to-emit for CO from 9.2 to 0.9 tons per year. There is, however, a small collateral increase in H₂SO₄ potential emissions from the auxiliary boiler due to this oxidation catalyst.

In addition, the Applicant has identified and corrected an error in the calculation of annual CO emissions. This error occurred in the assumptions used to calculate the startup/shutdown annual scenario originally presented in Appendix B (Calculation Sheet 2) of the December 21, 2012 Application. In these calculations, the Applicant had mistakenly assumed that startups occurring on a Monday morning (after being offline over the weekend) would be "cold starts" rather than "warm starts". However, as recently pointed out by GE, GE defines a cold start as when the turbine has been offline for *more than 72* hours. In contrast, the modeled Monday morning startups at the Project will occur when the turbines have been down less than 60 hours after shutting down on Friday evening. Accordingly, these Monday morning startups will be "warm starts" rather than cold starts. Since warm starts have lower CO emissions than cold starts, the CO emissions from the turbines during the corrected start-up scenario will be less than originally calculated.

The annual CO emissions have been revised incorporating the updates described above, and the resulting proposed maximum annual emissions for the Project are now *reduced* to 88.0 tons per year. The Project maximum annual CO emissions are reduced from 106.3 tpy, a 17% reduction. Emissions totals for the turbines will be verified through the CO CEMS monitoring and reporting as specified in the draft permits.

PM Emissions. The other recent emission update included in this document is the reduction to the combustion turbine particulate emissions. This update is due to lower particulate emission guarantees provided by GE, as described in the Applicant's comment letter to MassDEP dated November 1, 2013. GE has been collecting new PM test data for combustion turbine combined cycle units using strict quality control methods for EPA test procedures, and based on this latest data GE is confident the new lower limits can be achieved. The project maximum annual emissions for PM are reduced by 25%.

Other Updates. As noted above, the addition of the oxidation catalyst to the auxiliary boiler results in a small collateral increase in H₂SO₄ emissions, due to the additional oxidation of SO₂ to SO₃ in the auxiliary boiler exhaust. In addition, the lb/hr emission rates for the combustion turbines for NO_x, SO₂, NH₃ and H₂SO₄ for unfired conditions (i.e., no duct firing) have been reduced, in response to one of the CLF comments on the draft permit documents. The lb/hr rates for all these pollutants in the draft permit documents dated September 9, 2013 were based on the worst case emissions for duct firing, using a firing rate of 2449 MMBtu/hr/combined cycle unit. We have included the (lower) maximum lb/hr rates for unfired conditions (maximum firing rate of 2300 MMBtu/hr/turbine) in this document.

In all other respects, the turbine emissions are the same as presented in the draft permit documents issued by MassDEP on September 9, 2013.

2.0 COMBUSTION TURBINE AND FACILITY EMISSIONS

2.1 Short-Term Turbine Emissions

Short-term potential emission rates for each combined cycle unit, including the combustion turbine and associated duct burner, are presented in Table 2-1. The updated rates shown in Table 2-1 reflect both (1) GE's recent commitment that CO emissions at loads \geq MECL will not exceed 8.0 lbs/hr, with and without duct firing, (2) GE's revised guaranty of reduced PM, and (3) the other updates as noted at the end of section 1.0 above. The lb/hr rates shown for duct firing are based on the following assumptions, which are the same as in the draft permit documents: peak load operation at 90 °F, with duct burner firing and evaporative cooling, and represent the worst case hourly emissions. Worst-case hourly emissions without duct firing are also shown, and are based on 100% (base) load operation at 0 °F. Potential emission rates are presented in: parts per million by volume, dry basis (ppmvd), corrected to 15% O₂; pounds per million British thermal units (lb/MMBtu) on a high heating value (HHV) basis; pounds per hour (lb/hr); and lb/MWhr. The lb/MWhr values for unfired conditions (i.e., no duct firing) are based on an initial compliance test at 100% (base) load. The lb/MWhr values for duct firing conditions are based on an initial compliance test at peak load (approximately 102% load) with 100% duct firing.

Table 2-1. Short-Term Emission Rates for Combustion Turbine Combined Cycle Units

Pollutant	ppmvd at 15% O ₂	lb/MMBtu	lb/hr (per Unit)	lb/MWhr
NO _x , unfired	2.0	0.0074	17.0	0.051
NO _x , duct-fired	2.0	0.0074	18.1	0.055
CO, unfired	2.0	0.0045	Not to exceed 8.0	0.025
CO, duct fired	2.0	0.0045		0.027
VOC, unfired	1.0	0.0013	3.0	0.009
VOC, duct-fired	1.7	0.0022	5.4	0.016
SO ₂ , unfired	0.3	0.0015	3.5	0.010
SO ₂ , duct-fired	0.3	0.0015	3.7	0.011
PM/PM ₁₀ /PM _{2.5} , unfired	N/A	0.0071	8.8	0.029
PM/PM ₁₀ /PM _{2.5} , duct-fired	N/A	0.0062	13.0	0.041
NH ₃ , unfired	2.0	0.0027	6.2	0.019
NH ₃ , duct-fired	2.0	0.0027	6.6	0.020
H ₂ SO ₄ , unfired	0.1	0.0010	2.2	0.007
H ₂ SO ₄ duct-fired	0.1	0.0010	2.3	0.008

Emissions changes from the draft permit documents issued by MassDEP are highlighted

Table 2-2 provides updated emission rates for the auxiliary boiler. The updated values reflect the addition of the oxidation catalyst which reduces CO but causes a collateral increase in H₂SO₄ emissions.

Table 2-2 Emission Rates for Auxiliary Boiler

Pollutant	Auxiliary Boiler		
	lb/MMBtu	lb/hr	tpy
NO _x	0.011	0.88	2.9
CO	0.0035	0.28	0.9
VOC	0.005	0.40	1.3
SO ₂	0.0015	0.12	0.4
PM	0.005	0.40	1.3
PM ₁₀	0.005	0.40	1.3
PM _{2.5}	0.005	0.40	1.3
H ₂ SO ₄	0.0009	0.072	0.24

Emissions changed from the draft permit documents issued by MassDEP are highlighted.

The increase in H₂SO₄ emissions from the auxiliary boiler does result in an increase in the H₂SO₄ impacts as presented in Table 6-13 of Attachment 1 of the Second Supplement to the Air Plans Application, dated June 10, 2013. This same information is also presented in Table 3 of MassDEP's proposed Air Quality Plan Approval (page 15 of 59), dated September 9, 2013. The maximum 24-hr (TEL) impact for H₂SO₄ increases from 0.053184 to 0.084823 micrograms per cubic meter (ug/m³). This represents an increase from 1.955% to 3.119% of the TEL. The maximum annual (AAL) impact for H₂SO₄ increases from 0.001841 to 0.005963 (ug/m³). This represents an increase from 0.068% to 0.219% of the AAL. The resulting concentrations still remain far below the applicable criteria.

It should also be recognized that we have conservatively not documented the various reductions in ambient air quality impacts resulting from the reduced emissions for PM₁₀, PM_{2.5} and CO that are now incorporated into the Project.

2.2 Long-Term Project Emissions

The proposed annual potential emissions from the Project are summarized in Table 2-3. These limits have been updated to account for the reductions in CO and PM emissions rates, described above. The limits are also based on the following assumptions, which are the same as stated in the draft permit documents:

- For the combustion turbines, 8,040 hours at 100% load, operating at 50 °F, with no duct burner firing, and 720 hours at 100% load, operating at 90 °F, with duct burner firing and evaporative cooling (except for CO as described below);
- For the auxiliary boiler, 6,570 hours at 100% load (full load equivalent);
- For the emergency generator and fire pump engine, 300 hours each at the maximum rated power output;
- The ACC will have no particulate emissions; and
- The auxiliary cooling tower will operate 8,760 hours at full capacity.

Table 2-3. Facility-Wide Annual Potential Emissions

Pollutant	CT Unit 1 (tpy)	CT Unit 2 (tpy)	Auxiliary Boiler (tpy)	Emergency Generator (tpy)	Fire Pump (tpy)	Auxiliary Cooling Tower (tpy)	Facility Total (tpy)
NO _x	69.9	69.9	2.9	1.7	0.4	0	144.8
CO	42.9	42.9	0.9	1.0	0.3	0	88.0
VOC	13.1	13.1	1.3	0.35	0.12	0	28.0
SO ₂	14.2	14.2	0.4	0.0017	0.0006	0	28.8
PM	40.1	40.1	1.3	0.06	0.02	0.43	82.0
PM ₁₀	40.1	40.1	1.3	0.06	0.02	0.43	82.0
PM _{2.5}	40.1	40.1	1.3	0.06	0.02	0.17	81.8
NH ₃	25.5	25.5	0	0	0	0	51.0
H ₂ SO ₄ mist	9.4	9.4	0.24	0.00013	0.00005	0	19.0
Lead	0	0	0.00013	0.000001	0.0000003	0	0.00013
Formaldehyde	3.3	3.3	0.019	0.00009	0.0005	0	6.6
Total HAP	6.3	6.3	0.5	0.0018	0.0016	0	13.1
CO ₂	1,122,920	1,122,920	31,247	180	66	0	2,277,333
CO ₂ e	1,124,003	1,124,003	31,277	181	66	0	2,279,530

Emissions changes from the draft permit documents issued by MassDEP are highlighted

The combustion turbines have higher hourly mass emissions of CO during startup and shutdown than during full-load operation. Therefore, the annual potential emissions of CO in Table 2-3 are based on a simulated operating year that includes a conservative number of startup and shutdown cycles. Table 2-4 below presents the revised operating scenario used to calculate annual potential emissions for CO. Table 2-4 includes the corrections to the assumptions discussed in Section 1.0 above. The number of operating hours and startup/shutdown cycles shown are per combustion turbine.

Appendix A presents an update to the supporting calculation sheets originally provided in Appendix B of the December 21, 2012 Application.

Table 2-4 Combustion Turbine Operating Scenario for Annual CO Emissions

Season	Conditions	Annual Hours at Full Load	Annual Cold Startup/Shutdown Cycles	Annual Warm Startup/Shutdown Cycles	Annual Hot Startup/Shutdown Cycles
Spring/Fall	100% load at 50 °F, no evaporative cooling, no duct burner	1,200	5	95	0
Summer	100% load at 90 °F, no evaporative cooling, no duct burner	376	0	54	0
Summer	100% load at 90 °F with evaporative cooling and duct burner	720	0	0	0
Winter	100% load at 20 °F, no evaporative cooling, no duct burner	976	2	40	0
N/A	Planned outage	N/A	6	0	0
N/A	Unplanned outage	N/A	0	0	4
Annual Totals		3,272	13	189	4

3.0 PREVENTION OF SIGNIFICANT DETERIORATION (PSD) REVIEW APPLICABILITY

The PSD Air Quality Program is a federally-mandated program review of major new sources of criteria pollutants designed to maintain the NAAQS and prevent degradation of air quality in attainment/unclassifiable areas. The PSD program, which is now implemented by the MassDEP, applies to new major sources and major modifications of existing sources of air pollution.

For PSD purposes, a combustion turbine combined-cycle generation facility is considered a major source if emissions of any criteria pollutant are greater than 100 tons/year or if emissions of greenhouse gases (“GHG”) expressed as carbon dioxide (CO₂) equivalent (or CO₂e) are greater than 100,000 tons per year. The Project will have potential emissions greater than 100 tons/year for one or more attainment criteria pollutants and potential emissions greater than 100,000 tons/year of CO₂e. Therefore, the proposed facility will be a major PSD source.

For a major PSD source, PSD regulations also apply to each criteria pollutant that is emitted in excess of a defined significant emission rate. Table 3-1 presents a PSD major source threshold analysis for the Project for those pollutants with applicable PSD emission criteria. As shown in Table 3-1, the Project is now subject to PSD review (i.e., exceeds significant emissions rates) for particulates (PM/PM₁₀/PM_{2.5}), NO_x, sulfuric acid mist (H₂SO₄), and GHGs.

The only PSD review *applicability* change from the draft permit documents is that, based on the new and corrected information described above, CO is no longer subject to PSD review. That is, the proposed project annual emissions of CO (88.0 tpy) are now below the significant emission rate for CO (100 tpy). In addition, the proposed project annual emissions for PM/PM_{2.5}/PM₁₀ are now reduced based on the recent guarantees from GE, as described in section 1.0, above.

Table 3-1. Prevention of Significant Deterioration Regulatory Threshold Evaluation

Pollutant	Project Annual Emissions (tons)	PSD Major Source Threshold (tons)	PSD Significant Emission Rate (tons)	PSD Review Applies
CO	88.0	100	100	No
NO _x	144.8	100	40	Yes
SO ₂	28.8	100	40	No
PM	82.0	100	25	Yes
PM ₁₀	82.0	100	15	Yes
PM _{2.5}	81.8	100	10	Yes
VOC (ozone precursor)	28.0	100	40	No
Lead	0.00013	100	0.6	No
Fluorides	Negligible.	100	3	No
Sulfuric Acid Mist (H ₂ SO ₄)	19.0	100	7	Yes
Hydrogen Sulfide (H ₂ S)	none expected	100	10	No
Total Reduced Sulfur (including H ₂ S)	none expected	100	10	No
Reduced Sulfur Compounds	none expected	100	10	No
GHGs (as CO ₂ e)	2,279,530	100,000	75,000	Yes

Changes from the draft permit documents issued by MassDEP are highlighted.

4.0 CONTROL TECHNOLOGY ANALYSIS

This section presents an updated PSD BACT analysis for the Project. This updated analysis addresses comments made on the draft permit and reflects the additional information and corrections described in sections 1, 2, and 3 above. As discussed above, the Project exceeds PSD significant emission thresholds for NO_x, PM/PM₁₀/PM_{2.5}, H₂SO₄, and GHG, and thus is subject to PSD BACT for these pollutants. The Project does not exceed PSD significant emissions thresholds for CO.

The Project remains subject to MassDEP BACT for all pollutants. The MassDEP BACT analysis as reflected in the prior application materials and the MassDEP draft permit documents remains valid and is not addressed here. This section specifically addresses PSD BACT requirements.

PSD BACT is defined in 40 CFR 52.21 means “an emissions limitation (including a visible emission standard) based on the maximum degree of reduction for each pollutant subject to regulation under Act which would be emitted from any proposed major stationary source or major modification which the Administrator, on a case-by-case basis, taking into account energy, environmental, and economic impacts and other costs, determines is achievable for such source or modification through application of production processes or available methods, systems, and techniques, including fuel cleaning or treatment or innovative fuel combustion techniques for control of such pollutant. In no event shall application of best available control technology result in emissions of any pollutant which would exceed the emissions allowed by any applicable standard under 40 CFR Parts 60 and 61. If the Administrator determines that technological or economic limitations on the application of measurement methodology to a particular emissions unit would make the imposition of an emissions standard infeasible, a design, equipment, work practice, operational standard, or combination thereof, may be prescribed instead to satisfy the requirement for the application of best available control technology. Such standard shall, to the degree possible, set forth the emissions reduction achievable by implementation of such design, equipment, work practice or operation, and shall provide for compliance by means which achieve equivalent results.”

Typically, PSD BACT follows a five step “top-down” approach: (1) identify all control technologies; (2) eliminate technically infeasible options; (3) rank remaining control technologies by control effectiveness; (4) evaluate most effective controls and documents results; and (5) select BACT.

However, a key exception to the strict, five-step “top-down” approach is described in page B-8 of the EPA’s October 1990 draft New Source Review Workshop Manual (the “NSR Manual,” as cited in the EPA comment letter):

If the applicant accepts the top alternative in the listing as BACT, the applicant proceeds to consider whether impacts of unregulated air pollutants or impacts in other media would justify selection of an alternative control option. If there are no outstanding issues regarding collateral environmental impacts, the analysis is ended and the results proposed as BACT. In the event that the top candidate is shown to be inappropriate, due to energy, environmental, or economic impacts, the rationale for this finding should be documented for the public record. Then the next most stringent alternative in the listing becomes the new control candidate and is similarly evaluated. This process continues until the technology under consideration cannot be eliminated by any source-specific environmental, energy, or economic impacts which demonstrate that alternative to be inappropriate as BACT.

4.1 Combined Cycle Combustion Turbines

4.1.1 Fuel Selection

Fuel selection is an important consideration with respect to all pollutants subject to PSD review for the facility (NO_x, PM/PM₁₀/PM_{2.5}, H₂SO₄, and GHG). Therefore, fuel selection for the combustion turbine combined cycle units is initially discussed here, prior to the PSD BACT evaluation for the individual PSD pollutants, instead of repeating this under the evaluation for each pollutant.

The Applicant proposes to use natural gas only for the combined cycle turbines.

Step 1: Identify all control technologies (fuel types).

Identified control technologies (fuel types) for combustion turbine combined cycle units are:

1. Use of natural gas only.
2. Primarily natural gas with liquid fuel as a backup fuel. Liquid fuel could be ultra-low sulfur distillate (ULSD), biodiesel or a mixture of these.

Step 2: Eliminate technically infeasible options

Both above fuel options are technically feasible. An acceptable mixture for ULSD/biodiesel is subject to confirmation by turbine suppliers.

Step 3: Rank remaining control technologies by control effectiveness.

Natural gas is the lowest emitting commercially available fuel for combustion turbine combined cycle units. ULSD and biodiesel have higher emissions than natural gas for NO_x, PM/PM₁₀/PM_{2.5} and GHG. H₂SO₄ emissions depend on the maximum sulfur content of the fuel. ULSD and biodiesel are normally specified at 15 ppm sulfur by weight, and pipeline natural gas is defined by USEPA in 40 CFR 72.2 to have a maximum sulfur content of 0.5 grains/100 scf. These values are effectively identical in the amount of sulfur per MMBtu of fuel. However, natural gas as delivered is likely to have a lower actual sulfur content per MMBtu of fuel compared to ULSD or biodiesel.

Since natural gas is a lower emitting fuel than ULSD or biodiesel, it ranks higher in terms of control effectiveness and is considered the top BACT alternative.

Step 4: Evaluation of Collateral Impacts

Energy Impacts

Within the past decade, natural gas has become increasingly abundant in the New England, due to increased availability of domestic sources of gas. However, concerns have been raised regarding the lack of regional fuel diversity and potential overreliance on natural gas for energy supplies. In particular, pipeline infrastructure to deliver gas into New England can become constrained during cold weather as space heating and electric production compete for available gas supplies. These issues have resulted in considerations for more energy diversity and backup liquid fuel supplies for electric generation facilities.

Since the Applicant has committed to use natural gas exclusively in the combustion turbine combined cycle units, potential energy concerns with exclusive natural gas use are an important consideration. The Project will obtain natural gas from its direct connection to Algonquin's HubLine interstate natural gas pipeline near HubLine's interconnection with the Maritimes & Northeast Pipeline. This unique interconnection point permits the Project to access supplies of natural gas from both Canadian sources as

well as from domestic sources the south and west. The Maritimes & Northeast Pipeline has not had the same physical delivery constraints as the heavily relied-upon pipelines delivering natural gas into New England exclusively from the south and west. Therefore, energy concerns due to exclusive natural gas use are not problematic for this Project.

Economic Impacts

Natural gas is currently a much more favorable economically compared to liquid fuels, and this situation is expected retain this current pattern into the foreseeable future. With Footprint's access to Canadian Maritime gas, potential short-term price spikes due to physical supply constraints are not expected to be problematic. Therefore, there are no economic considerations that would dictate that backup provisions for liquid fuel are necessary.

Environmental Impacts

In addition to being a higher emitting fuel for air emissions, liquid fuel has other significant collateral impacts compared to natural gas. The most significant collateral impact is associated with the truck delivery of liquid fuel to the site. Although liquid fuel could be delivered by barge as well, the local community has expressed its strong opposition to the continued storage and combustion of liquid fuel on the site for power generation. These impacts are of significant concern to the local Salem community, and in fact have led to a commitment by the Applicant not to use liquid fuel for the combustion turbine combined cycle units at the site.

The other collateral environmental impact of note is the fact that NO_x control for liquid fuel requires the use of water or steam injection to the turbine combustor. The use of water/steam injection would result in a significant consumptive water use and an associated discharge of water that is not needed for dry low-NO_x combustors, which are available for natural gas.

Step 5: Select BACT

Use of natural gas as the exclusive fuel for the combustion turbine combined cycle units is clearly justified as PSD BACT. Natural gas is lower emitting, has significantly lower collateral environmental impacts, and collateral energy and economy impacts have been determined to be acceptable.

4.1.2 PSD Best Available Control Technology Assessment for NO_x

Step 1: Identify Candidate Technologies

NO_x control technologies identified for new large > 100 MW combined cycle turbines are as follows:

- Dry-low NO_x (DLN) Combustion: Turbine vendors offer what is known as lean pre-mix combustors for natural gas firing which limit NO_x formation by reducing peak flame temperatures.
- Water or Steam Injection: Water or steam injection has been historically used for both gas and oil fire turbines, but for new turbines is generally only used for liquid fuel firing.
- Catalytic Combustors: A form of catalytic combustion to limit firing temperature has been under development using the trade name XONON.
- SCONOX: This is an oxidation/absorption technology using hydrogen or methane as a reactant. This technology is currently marketed as EMx.

-
- SCR: This is a catalytic reduction technology using ammonia as a reactant that has been in widespread use on new combined cycle turbines for over 20 years.

Step 2: Eliminate Infeasible Technologies

Catalytic combustors are not currently technically feasible for large turbines. The only known application is on a 1.4 MW test turbine. The largest turbine to which SCONox has been successfully demonstrated is a 43 MW turbine in California. There are significant SCONox scale up questions for a new turbine larger than 100 MW, but for the sake of argument SCONox will be assumed to be technically feasible here. The other technologies are all technically feasible.

Step 3: Rank Control Technologies by Control Effectiveness

The ranking of these technologies is as follows:

1. SCR: Widely demonstrated to have achieved 2.0 ppmvd NO_x at 15% O₂ for gas firing. This is documented in the LAER analysis presented in the December 21, 2012 Application and First Application Supplement (April 12, 2013).
2. SCONox: Demonstrated to have achieved 2.5 ppmvd NO_x at 15% O₂ at the 43 MW California unit.
3. DLN: Generally recognized to achieve 9 ppmvd NO_x at 15% O₂. Commonly used in conjunction with SCR to achieve 2.0 ppmvd NO_x at 15% O₂.
4. Steam/Water Injection: Less effective than DLN.

Step 4: Evaluate Controls

Since Footprint is proposing the “top” level for NO_x BACT (SCR), the BACT analysis can proceed to the consideration of whether any collateral energy or environment impacts would indicate other than the top demonstrated technology be selected.

The one collateral impact that has been identified for SCR is due to the use of ammonia as a reagent, and the resulting emissions of ammonia “slip” that can occur. SCONox does not require the use of ammonia. While SCONox will eliminate the use of ammonia, the lower NO_x emissions demonstrated in practice with SCR (2.0 ppmvdc vs. 2.5 ppmvdc for SCONox) and the very high additional cost documented with SCONox does not justify a finding that SCONox is BACT. This same conclusion is found in the EPA Analysis for the Pioneer Valley Energy Center (PVEC), in the Fact Sheet published in December 2011. SCONox is not justified as BACT. In addition, as documented in the Application and supplements, the predicted ambient air quality impacts for ammonia are well below the MassDEP air toxics guidelines. Aqueous ammonia will be stored in a 34,000 gallon above ground tank located within a concrete dike designed to contain 110% of the total tank volume. Passive evaporative controls will be used inside the dike to control evaporation in the event of a release, and the tank and dike will be in a fully enclosed and sealed structure except for roof vents. Evaluation of a hypothetical worst case release indicates that ammonia concentrations at and outside the Project perimeter will be less than the ERPG-1 level. ERPG-1 is defined as the maximum airborne concentration below which nearly all individuals could be exposed for up to one hour without experiencing other than mild transient adverse health effects or perceiving a clearly defined, objectionable odor.

Step 5: Select BACT

The Footprint Project will meet the same 2.0 ppmvdc NO_x limit as determined to be BACT for PVEC. The Project will also meet a stringent emission limit for ammonia slip (2.0 ppmvdc on a 1-hour basis), which is the most stringent ammonia limit achieved in practice for facilities of this type. This stringent ammonia limit assures that collateral impacts are adequately minimized for the use of SCR for the Footprint Project, and that this represents BACT for NO_x.

4.1.3 PSD Best Available Control Technology Assessment for PM/PM₁₀/PM_{2.5}

Emissions of particulate matter result from trace quantities of ash (non-combustibles) in the fuel as well as products of incomplete combustion. Conservatively, all particulate matter (PM) emissions for the combustion turbines are assumed to be less than 2.5 microns in size (PM_{2.5}).

Pursuant to identifying candidate control technologies under the “top-down” procedure, Footprint has compiled all the PSD BACT determinations in the last five years for new large (> 100 MW) combustion turbine combined cycle project. This compilation is based on the USEPA RBLC (RACT/BACT/LAER Clearinghouse). Several recent projects not included in RBLC have also been included in this compilation. The Brockton Energy Center Project in Brockton MA is also included, since it is a similar recent project in Massachusetts, even though it did not receive a PSD permit. This review confirms that the only BACT technology identified for large natural gas fired combined cycle turbines is use of clean fuel (i.e., natural gas) and good combustion practices.

For PM/PM₁₀/PM_{2.5}, this evaluation does not identify and discuss each of the five individual steps of the “top-down” BACT process, since there are no post-combustion control technologies available for PM/PM₁₀/PM_{2.5}. Post-combustion particulate control technologies such as fabric filters (baghouses), electrostatic precipitators, and/or wet scrubbers, which are commonly used on solid fuel boilers, are not available for combustion turbines since the large amount of excess air inherent to combustion turbine technology would create adverse backpressure for turbine operation.

The “top-down” procedure does require selection of BACT emission limits, which is addressed in the following paragraphs.

Table 4-1 presents the results of RBLC compilation for PM/PM₁₀/PM_{2.5}. A review of Table 4-1 indicates that PM/PM₁₀/PM_{2.5} emission limits are expressed strictly in lbs/hr or lb/MMBtu, or in both lb/hr and lb/MMBtu. This review also indicates that different emission limits can be associated with different turbine suppliers. This is illustrated by some projects which have one set of limit for one supplier and another set of limits for another supplier.

It is Footprint’s conclusion based on review of available information that differences in PM/PM₁₀/PM_{2.5} emission limits among various projects are due to different emission guarantee philosophies of the various suppliers, and are not actual differences in the quantity of PM/PM₁₀/PM_{2.5} emissions inherently produced by the supplier of the turbine. The different emission guarantee philosophies are influenced by the overall uncertainties of the PM/PM₁₀/PM_{2.5} test procedures, especially given reported difficulties in achieving test repeatability, and concerns with artifact emissions introduced by the general inclusion of condensable particulate emissions (as measured by impinger based techniques) in permit limits in the last decade.

Table 4-1. Summary of Recent Particulate PSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Turbine ¹	Emission Limits ²
				PM/PM ₁₀ /PM _{2.5}
Carroll County Energy	Washington Twp., OH	11/5/2013	2 GE 7FA 2045 MMBtu/hr/unit plus 566 MMBtu/hr DF	12.4 lb/hr/unit and 0.0108 lb/MMBtu without DF 19.8 lb/hr and 0.0078 lb/MMBtu with DF
Renaissance Power	Carson City, MI	11/1/2013	4 Siemens 501 FD2 units 2147 MMBtu/hr/unit each with 660 MMBtu/hr DF	9.0 lb/hr/unit and 0.0042 lb/MMBtu (with and without DF)
Langley Gulch Power	Payette, ID	08/14/2013	1 - Siemens SGT6-5000F 2134 MMBtu/hr/unit with 241.28 MMBtu/hr DF	12.55 lb/hr (w/ and w/o DF)
Oregon Clean Energy	Oregon, OH	06/18/2013	2 Mitsubishi M501GAC or 2 Siemens SCC6-8000H 2932 MMBtu/hr/unit plus 300 MMBtu/hr DF	Mitsubishi: 11.3 lb/hr/unit and 0.00384 lb/MMBtu without DF Mitsubishi: 10.1 lb/hr and 0.00373 lb/MMBtu with DF Siemens: 14.0 lb/hr/unit and 0.0055 lb/MMBtu without DF Siemens: 13.3 lb/hr and 0.0047 lb/MMBtu with DF
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	2 GE 7FA.05 2230 MMBtu/hr/unit plus 650 MMBtu/hr DF or 2 Siemens SGT6-5000F5 2260 MMBtu/hr/unit plus 450 MMBtu/hr DF	GE: 0.00334 lb/MMBtu at full load (w/ and w/o DF) 9.6 lb/hr/unit without DF 16.2 lb/hr with DF Siemens: 0.00374 lb/MMBtu at full load (w/ and w/o DF) 10.1 lb/hr/unit without DF 14.5 lb/hr with DF
Hickory Run Energy LLC	New Beaver Twp., PA	04/23/2013	GE7FA, Siemens SGT6-5000F, Mitsubishi M501G, or Siemens SGT6-8000H. 2 combined cycle units	11.0 lb/hr/unit without DF 18.5 lb/hr/unit with DF Emissions based on Siemens SGT6-8000H
Sunbury Generation	Sunbury, PA	04/01/2013	"F Class" with DF 2538 MMBtu/hr/unit	0.0088 lb/MMBtu
Brunswick County Power	Freeman, VA	03/12/2013	3 Mitsubishi M501 GAC with DF Combined GT and DF 3442 MMBtu/hr/unit	9.7 lb/hr/unit and 0.0033 lb/MMBtu without DF 16.3 lb/hr and 0.0047 lb/MMBtu with DF
Moxie Patriot LLC	Clinton Twp, PA	01/31/2013	Equipment type not specified 2 - 472 or 458 MW combined cycle blocks with DF	0.0057 lb/MMBtu
Garrison Energy Center	Dover, DE	01/30/2013	GE 7FA 309 MW	32.1 lb/hr
St. Joseph Energy Center	New Carlisle, IN	12/03/2012	4 - "F Class" (GE or Siemens) 1345 MW total	15 lb/hr/unit and 0.0092 lb/MMBtu without DF 18 lb/hr and 0.0078 lb/MMBtu with DF
Hess Newark Energy	Newark, NJ	11/01/2012	2 - GE 7FA.05 2320 MMBtu/hr/unit plus 211 MMBtu/hr DF	11 lb/hr/unit without DF 13.2 lb/hr with DF

Table 4-1. Summary of Recent Particulate PSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Turbine ¹	Emission Limits ²
				PM/PM ₁₀ /PM _{2.5}
Channel Energy Center, LLC	Houston, TX	10/15/2012	2 - Siemens 501F 180 MW plus 425 MMBtu/hr DF	27.0 lb/hr
Moxie Liberty LLC	Asylum Twp., PA	10/10/2012	Siemens "H Class" 2 - 468 or less MW combined cycle blocks GT ≤ 2890 MMBtu/hr/unit DF ≤ 3870 MMBtu/hr/unit	0.0057 lb/MMBtu for 454 MW block 0.0040 lb/MMBtu for 468 MW block
Cricket Valley	Dover, NY	09/27/2012	3 - GE 7FA.05 2061 MMBtu/hr/unit plus 379 MMBtu/hr DF	0.005 lb/MMBtu without DF 0.006 lb/MMBtu with DF
Deer Park Energy Center LLC	Deer Park, TX	09/26/2012	1 - Siemens 501F 180 MW plus 725 MMBtu/hr DF	27.0 lb/hr
ES Joslin Power	Calhoun, TX	09/12/2012	3 - GE 7FA 195 MW per unit No DF	18.0 lb/hr
Pioneer Valley Energy Center (PVEC)	Westfield, MA	04/05/2012	1 Mitsubishi M501GAC 2542 MMBtu/hr/unit; no DF	9.8 lb/hr 0.004 lb/MMBtu
Palmdale Hybrid Power	Palmdale, CA	10/18/2011	2 GE 7FA 154 MW (1736 MMBtu/hr) per unit plus 500 MMBtu/hr DF	8.46 lb/hr/unit and 0.0048 lb/MMBtu without DF 11.3 lb/hr and 0.0049 lb/MMBtu with DF
Thomas C. Ferguson Power	Llano, TX	09/01/2011	2 - GE 7FA 195 MW per unit No DF	18.0 lb/hr
Entergy Ninemile Point Unit 6	Westwego, LA	08/16/2011	Vendor not specified Single unit 550MW	26.23 lb/hr/unit without DF 33.16 lb/hr with DF
Brockton Power	Brockton MA	07/20/2011 (MA Plan Approval)	1 Siemens SGT6-PAC-5000F 2227 MMBtu/hr plus 641 MMBtu/hr DF	17.4 lb/hr 0.007 lb/MMBtu
Avenal Power Center	Avenal, CA	05/27/2011	2 - GE 7FA 1856.3 MMBtu/hr/unit plus 562.26 MMBtu/hr DF	8.91 lb/hr/unit without DF 11.78 lb/hr with DF
Portland Gen. Electric Carty Plant	Morrow, OR	12/29/2010	1 - Mitsubishi M501GAC 2866 MMBtu/hr	0.0083 lb/MMBtu
Dominion Warren County	Front Royal, VA	12/21/2010	3 -Mitsubishi M501 GAC 2996 MMBtu/hr/unit plus 500 MMBtu/hr DF	8.0 lb/hr/unit and 0.0027 lb/MMBtu without DF 14.0 lb/hr and 0.0040 lb/MMBtu with DF

Table 4-1. Summary of Recent Particulate PSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Turbine ¹	Emission Limits ²
				PM/PM ₁₀ /PM _{2.5}
Pondera/King Power Station	Houston, TX	08/05/2010	4 GE 7FA.05 2430 MMBtu/hr/unit GT plus DF or 4 Siemens SGT6-5000F5 2693 MMBtu/hr/unit GT plus DF	GE: 19.80 lb/hr/unit (w/ and w/o DF) Siemens: 11.1 lb/hr/unit (w/ and w/o DF)
Live Oaks Power	Sterling, GA	03/30/2010	Siemens SGT6-5000F	No emission limits specified. PSD BACT for PM ₁₀ /PM _{2.5} use of pipeline quality natural gas
Victorville 2 Hybrid	Victorville, CA	03/11/2010	2 GE 7FA 154 MW per unit plus 424.3 MMBtu/hr DF	12.0 lb/hr/unit without DF 18.0 lb/hr with DF
Stark Power/Wolf Hollow	Granbury, TX	03/03/2010	2 GE 7FA 170 MW/unit plus 570 MMBtu/hr DF or 2 Mitsubishi M501G 254 MW/unit plus 230 MMBtu/hr DF	GE: 12.0 lb/hr/unit (w/ and w/o DF) Mitsubishi: 20.0 lb/hr/unit (w/ and w/o DF)
Panda Sherman Power	Grayson, TX	02/03/2010	2 GE 7FA or 2 Siemens SGT6-5000F with 468 MMBtu/hr/unit DF	GE: 12.0 lb/hr/unit (without DF) 27.0 lb/hr with DF Siemens: 11.0 lb/hr/unit without DF 15.4 lb/hr with DF
Russell City Energy Center	Hayward, CA	02/03/2010	2 - Siemens 501F 2238.6 MMBtu/hr/unit plus 200 MMBtu/hr DF	7.5 lb/hr/unit 0.0036 lb/MMBtu
Lamar Power Partners II LLC	Paris, TX	06/22/2009	4 - GE 7FA with 200 MMBtu/hr DF	18.0 lb/hr/unit without DF 20.3 lb/hr with DF
Pattillo Branch Power LLC	Savoy, TX	06/17/2009	4 - GE 7FA, GE7FB, or Siemens SGT6-5000F With DF	20.8 lb/hr/unit (each option)
Entergy Lewis Creek Plant	The Woodlands, TX	05/19/2009	2 - GE 7FA with 362 MMBtu/hr DF	27.14 lb/hr/unit

¹ DF refers to duct firing

² Includes front (filterable) and back-half (condensable) PM. Limits obtained from agency permitting documents when not available in RBLC. Short-term emission limits only are provided.

GE has historically guaranteed particulate emissions on constant lb/hr basis, regardless of turbine load. Thus, as shown in Table 4-1, many of the GE turbines have PSD BACT limits expressed strictly in lb/hr.

Footprint has calculated lb/MMBtu values inclusive of minimum emission compliance load (MECL). (Note that duct-firing will not occur at MECL, so the MECL-based limit is only for unfired conditions). Footprint has determined that the flexibility to operate at MECL is important to the Project's mission of providing a flexible and quick response to the future system power needs. Footprint's draft PSD permit and Plan Approval also require PM/PM₁₀/PM_{2.5} emission testing at MECL. MECL turbine operation therefore results in Footprint's highest lb/MMBtu rate of 0.0071 lb/MMBtu. It is important to note that a number of the lb/MMBtu emission rates in Table 4-1 correspond to (just) the full load heat input rate. For comparative purposes, the Footprint full load lb/MMBtu/hr PM/PM₁₀/PM_{2.5} emission rate (without duct firing) ranges from 0.0038 to 0.0047 lb/MMBtu.

Table 4-1 lists 34 projects with PSD BACT limits for PM/PM₁₀/PM_{2.5} approved in the last 5 years. Over half of these projects (18) clearly have PM/PM₁₀/PM_{2.5} limits less stringent than the Footprint limits discussed above. Of the remaining 16 projects, most of these are for turbine suppliers other than GE, and generally have lower PM/PM₁₀/PM_{2.5} limits expressed on a lb/MMBtu basis. The lb/MMBtu comparison allows PM/PM₁₀/PM_{2.5} rates for projects of different sizes to be more readily compared. The most stringent lb/MMBtu limit identified is for the Dominion Warren County (VA) project, which is 0.0027 lb/MMBtu without duct firing. The Dominion Warren County project is based on 3 Mitsubishi 501GAC turbines. Mitsubishi in particular has recently taken a more aggressive approach to PM/PM₁₀/PM_{2.5} guarantees, as reflected by the Warren County Project as well as the Brunswick County (VA) project (0.0033 lb/MMBtu without duct firing and 0.0047 lb/MMBtu with duct firing), the Oregon (Ohio) project (0.00384 lb/MMBtu without duct firing and 0.00373 lb/MMBtu with duct firing) and PVEC (0.004 lb/MMBtu without duct firing as noted in the CLF comment letter to MassDEP on the Footprint project).

With respect to the PM/PM₁₀/PM_{2.5} limits achievable for the Mitsubishi 501GAC turbine, it is significant to note that an email from George Pyros of Mitsubishi Power Systems dated October 7, 2013, which was submitted to MassDEP in comments concerning Footprint Power, indicates that Mitsubishi has "not yet conducted stack PM emissions testing for our M501GAC gas turbine in combined cycle. However, we have M501GAC units that will be commissioned next year in combined cycle that will provide such data." (The Mitsubishi 501GAC project that is closest to commissioning is the Dominion Warren County project.) The email from Mitsubishi actually supports Footprint's position, as provided in supplemental material submitted to MassDEP on August 20, 2013, insofar as the fact that ultra-low particulate rates for the 501GAC turbine are not demonstrated in practice. In the August 20, 2013 submission, Footprint questioned whether the 0.004 lb/MMBtu emission rate for the PVEC was achievable in practice. This is based on the fact that four Mitsubishi 501G units at Mystic Station (Everett MA), had tested PM emissions (in 2003) ranging from 0.005 – 0.010 lb/MMBtu. While the 501GAC turbine has a newer generation combustion system, the majority of the tested particulate matter at Mystic was condensable particulates. It is not at all clear how a newer generation combustion system would achieve better control of condensable particles. While careful adherence to particulate testing procedures can minimize testing variability and artifact condensable emissions, Footprint remains convinced that the Mitsubishi's recent 501GAC limits, particularly those for the Warren County project, present undue project risk.

In addition, for Mitsubishi and Siemens projects with PM/PM₁₀/PM_{2.5} lb/MMBtu limits, these limits appear to be approved as constant across the operating load range. This represents a different guarantee philosophy than used by GE. Again, Footprint believes this is a guarantee philosophy difference and does not reflect actual differences in the quantity of PM/PM₁₀/PM_{2.5} emissions due to the type of turbine. As

noted in Footprint's comment letter to MassDEP dated November 1, 2013, at full load unfired conditions, Footprint's lb/MMBtu rates for PM/PM₁₀/PM_{2.5} range from 0.0038 to 0.0047 lb/MMBtu. These full load rates compare favorably to many of the lb/MMBtu rates for Siemens and Mitsubishi in Table 4-1.

Several Siemens "F Class" PM/PM₁₀/PM_{2.5} limits in Table 4-1 (Renaissance, Langley Gulch, Pondera King) have lb/hr limits higher than the Footprint unfired value of 8.8 lb/hr, but do not incorporate higher duct firing limits (as is typically found to be necessary by available duct burner guarantees). Again, Footprint believes this is a guarantee philosophy difference and does not reflect actual differences in the quantity of PM/PM₁₀/PM_{2.5} emissions due to the type of turbine and whether duct firing is present or not.

The Russell City Energy Center Project is based on 2 Siemens 501F turbines, and was approved with PM/PM₁₀/PM_{2.5} limits of 7.5 lb/hr and 0.0038 lb/MMBtu. Again, Footprint believes this is a guarantee philosophy difference and does not reflect actual differences in the quantity of PM/PM₁₀/PM_{2.5} emissions. However, one item of particular note in the Russell City Energy Center PSD Permit is that the permit allows the facility to propose alternate measuring techniques to measure condensable PM, such as the use of a dilution tunnel. A dilution tunnel is expected to result in lower (and more realistic) tested emissions compared to typical stationary source impinger techniques for measuring condensable PM. Therefore, this permit provision may explain in part the rationale for the Russell City Energy Center strategy for accepting lower permit limits. Dilution tunnel based measurements for condensable PM are expected to more accurately simulate the process by which condensable PM forms compared to impinger techniques, which still present concerns with artifact emissions.

There is one other GE 7FA unit noted in Table 4-1 that has PM/PM₁₀/PM_{2.5} limits of comparative note. This is the Green Energy (VA) project. This project is approved for either GE 7FA or Siemens turbines. For GE 7FA, the lb/hr limits are less stringent than Footprint but the lb/MMBtu limits are more stringent. The Green Energy lb/MMBtu limits appear to be incorrectly calculated (too low), even based on the full load firing rates.

In summary, the available evidence clearly indicates that PSD BACT for PM/PM₁₀/PM_{2.5} emissions is to use of state of the art combustion turbines, with good combustion practices and the use of natural gas. The actual guarantees for PM/PM₁₀/PM_{2.5} emissions vary by manufacturer, and permit limits within the range of recently approved projects for a given turbine supplier are justified as PSD BACT limits.

4.1.4 PSD Best Available Control Technology Assessment for Sulfuric Acid Mist (H₂SO₄)

Emissions of H₂SO₄ from natural gas-fired combined cycle units result from oxidation of trace quantities of sulfur in natural gas. Normally, fuel sulfur oxidizes to SO₂. A generally small portion of fuel sulfur may initially oxidize directly to SO₃ rather than SO₂. Also, a portion of the fuel sulfur which initially oxidizes to SO₂ may subsequently oxidize to SO₃ prior to being emitted. For purposes of emission calculations, all SO₃ is assumed to combine with water vapor in the flue gas to form H₂SO₄.

For H₂SO₄, this evaluation does not identify and discuss each of the five individual steps of the "top-down" BACT process, since the only available control for H₂SO₄ is limiting the fuel sulfur content. Based on the selection of natural gas as the BACT fuel, this is the lowest sulfur content fuel available.

Key considerations in the development of a specific H₂SO₄ emission rate for a natural gas-fired combined cycle unit are the sulfur content of natural gas, and the appropriate allowance for oxidation of fuel sulfur and SO₂ to SO₃. For the sulfur content of natural gas, the Project has used the EPA definition of "pipeline natural gas" in 40 CFR 72.2. This definition is that pipeline natural gas has a maximum sulfur content of 0.5 grains of sulfur per 100 standard cubic feet (scf). Based on data from GE, up to 5% of the fuel sulfur

is expected to convert directly to SO₃ in the turbine combustor/duct burners. Then, up to 35% of the (remaining) SO₂ is expected to convert to SO₃ in passing through the oxidation catalyst, and up to an additional 5% of the (remaining) SO₂ is expected to convert to SO₃ in passing through the SCR system. As documented in the Project supplemental data submitted to MassDEP on August 20, 2013, the resulting H₂SO₄ emission rate is 0.0010 lb/MMBtu. This corresponds to a maximum emission rate of 2.3 lb/hr of H₂SO₄ per unit.

Pursuant to identifying candidate control technologies under the “top-down” procedure, the Applicant has compiled all the PSD BACT determinations for H₂SO₄ in the last five years for new large (> 100 MW) combustion turbine combined cycle projects. This compilation is based on the USEPA RBLC (RACT/BACT/LAER Clearinghouse). Several recent projects not included in RBLC have also been included in this compilation. This review confirms that the only H₂SO₄ BACT technology identified for large natural gas fired combined cycle turbines is use of clean fuel (i.e., natural gas). There are no cases where any post combustion controls have been used to control H₂SO₄ emissions from large natural gas fired combined cycle turbines. Therefore, the PSD BACT analysis for H₂SO₄ does not require any evaluation of alternative control technologies.

The “top-down” procedure does require selection of BACT emission limits. Table 4-2 presents the results of RBLC compilation for H₂SO₄. As for PM/PM₁₀/PM_{2.5}, BACT emissions for H₂SO₄ can be expressed either as lb/MMBtu or lb/hr, or both. Table 4-2 lists 22 projects with PSD BACT limits for H₂SO₄ approved in the last 5 years. More than half of these projects (13) have H₂SO₄ limits equal or less stringent than the Footprint limits discussed above. Of the remaining 9 projects, the lower H₂SO₄ rates appear to be due to either unrealistically low assumptions on SO₂ to SO₃ oxidation, low assumed natural gas sulfur contents, or both. One of the projects listed in Table 4-2 (Panda Sherman) was approved without a CO oxidation catalyst, which explains the low H₂SO₄ rate for this project. As noted above, a CO oxidation catalyst oxidizes some of the SO₂ to SO₃/H₂SO₄. However, the other projects in Table 4-2 with lower H₂SO₄ rates appear to have assumed a very stringent natural gas sulfur content and/or did not take into account the unavoidable incremental oxidation of SO₂ to SO₃ from a CO catalyst. Footprint does not believe it is prudent to ignore the SO₂ to SO₃ oxidation from a CO catalyst, or assume a natural gas sulfur content lower than EPA’s definition for “pipeline natural gas” (0.5 grains of S/100 scf).

In summary, the available evidence clearly indicates that PSD BACT for H₂SO₄ for combustion turbines is use of clean low sulfur fuel (e.g., natural gas). The H₂SO₄ emission calculation needs to allow for a reasonable variation in the sulfur content of pipeline natural gas, which is outside the control of a given generation facility, and oxidation of SO₂ to SO₃ oxidation from a CO catalyst. The Applicant proposes a H₂SO₄ limit for the Project (0.0010 lb/MMBtu), which is consistent with recent PSD BACT precedents which properly account for these variables.

Table 4-2. Summary Of Recent H₂SO₄ PSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Turbine ¹	Emission Limits ²
				Sulfuric Acid Mist (H ₂ SO ₄)
Carroll County Energy	Washington Twp., OH	11/5/2013	2 GE 7FA 2045 MMBtu/hr/unit plus 566 MMBtu/hr DF	0.0012 lb/MMBtu without DF 0.0016 lb/MMBtu with DF
Oregon Clean Energy	Oregon, OH	06/18/2013	2 Mitsubishi M501GAC or 2 Siemens SCC6-8000H 2932 MMBtu/hr/unit plus 300 MMBtu/hr DF	Mitsubishi: 0.00041 lb/MMBtu without DF Mitsubishi: 0.00044 lb/MMBtu with DF Siemens: 0.0006 lb/MMBtu without DF Siemens: 0.0007 lb/MMBtu with DF
Hickory Run Energy LLC	New Beaver Twp., PA	04/23/2013	GE7FA, Siemens SGT6-5000F, Mitsubishi M501G, or Siemens SGT6-8000H. 2 combined cycle units	0.92 lb/hr/unit without DF 1.08 lb/hr/unit with DF Emissions based on Siemens SGT6-8000H
Sunbury Generation	Sunbury, PA	04/01/2013	"F Class" with DF 2538 MMBtu/hr/unit	0.0018 lb/MMBtu 4.4 lb/hr/unit without DF 4.7 lb/hr/unit with DF
Brunswick County Power	Freeman, VA	03/12/2013	3 Mitsubishi M501 GAC with DF Combined GT and DF 3442 MMBtu/hr/unit	0.00058 lb/MMBtu without DF 0.00067 lb/MMBtu with DF
Moxie Patriot LLC	Clinton Twp, PA	01/31/2013	Equipment type not specified 2 - 472 or 458 MW combined cycle blocks with DF	0.0005 lb/MMBtu
Garrison Energy Center	Dover, DE	01/30/2013	GE 7FA 309 MW	6.5 lb/hr
St. Joseph Energy Center	New Carlisle, IN	12/03/2012	4 - "F Class" (GE or Siemens) 1345 MW total	0.75 grains S/100 scf of natural gas
Hess Newark Energy	Newark, NJ	11/01/2012	2 - GE 7FA.05 2320 MMBtu/hr/unit plus 211 MMBtu/hr DF	1.36 lb/hr/unit without DF 1.33 lb/hr/unit with DF
Channel Energy Center, LLC	Houston, TX	10/15/2012	2 - Siemens 501F 180 MW plus 425 MMBtu/hr DF	4.8 lb/hr/unit
Moxie Liberty LLC	Asylum Twp., PA	10/10/2012	Equipment type not specified 2 - 468 or less MW combined cycle blocks GT ≤ 2890 MMBtu/hr/unit DF ≤ 3870 MMBtu/hr/unit	0.0002 lb/MMBtu 1.4 lb/hr for 454 MW block 1.5lb/hr for 468 MW block
Cricket Valley	Dover, NY	09/27/2012	3 - GE 7FA.05 2061 MMBtu/hr/unit plus 379 MMBtu/hr DF	0.5 grains S/100 scf of natural gas

Table 4-2. Summary Of Recent H₂SO₄ PSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Turbine ¹	Emission Limits ²
				Sulfuric Acid Mist (H ₂ SO ₄)
Deer Park Energy Center LLC	Deer Park, TX	09/26/2012	1 - Siemens 501F 180 MW plus 725 MMBtu/hr DF	4.89 lb/hr/unit
Pioneer Valley Energy Center (PVEC)	Westfield, MA	04/05/2012	1 Mitsubishi M501GAC 2542 MMBtu/hr/unit; no DF	0.0018 lb/MMBtu 3.6 lb/hr
Thomas C. Ferguson Power	Llano, TX	09/01/2011	2 - GE 7FA 195 MW per unit No DF	13.68 lb/hr
Portland Gen. Electric Carty Plant	Morrow, OR	12/29/2010	1 - Mitsubishi M501GAC 2866 MMBtu/hr	1.5 lb/MMcf (0.0015 lb/MMBtu)
Dominion Warren County	Front Royal, VA	12/21/2010	3 -Mitsubishi M501 GAC 2996 MMBtu/hr/unit plus 500 MMBtu/hr DF	0.00013 lb/MMBtu without DF 0.00025 lb/MMBtu with DF
Pondera/King Power Station	Houston, TX	08/05/2010	4 GE 7FA.05 2430 MMBtu/hr/unit GT plus DF or 4 Siemens SGT6-5000F5 2693 MMBtu/hr/unit GT plus DF	GE: 3.37 lb/hr/unit (w/ and w/o DF) Siemens: 3.77 lb/hr/unit (w/ and w/o DF)
Live Oaks Power	Sterling, GA	03/30/2010	Siemens SGT6-5000F	No emission limits specified. PSD BACT for H ₂ SO ₄ use of pipeline quality natural gas with ≤ 0.5 grains S/100 scf
Panda Sherman Power	Grayson, TX	02/03/2010	2 GE 7FA 170 MW/unit plus 570 MMBtu/hr DF or 2 Mitsubishi M501G 254 MW/unit plus 230 MMBtu/hr DF	GE: 0.56 lb/hr/unit (w/ and w/o DF) Mitsubishi: 0.62 lb/hr/unit (w/ and w/o DF)
Pattillo Branch Power LLC	Savoy, TX	06/17/2009	4 – GE 7FA, GE7FB, or Siemens SGT6-5000F With DF	GE: 1.9 lb/hr/unit (w/ and w/o DF) Mitsubishi: 2.0 lb/hr/unit (w/ and w/o DF)
Entergy Lewis Creek Plant	The Woodlands, TX	05/19/2009	2 - GE 7FA with 362 MMBtu/hr DF	4.03 lb/hr/unit

¹ DF refers to duct firing

² Limits obtained from agency permitting documents when not available in RBLC. Short-term emission limits only are provided.

4.1.5 Best Available Control Technology Assessment for Greenhouse Gases

Step 1: Identify Potentially Feasible GHG Control Options

In Step 1, the applicant must identify all “available” control options which have the potential for practical application to the emission unit and regulated pollutant under evaluation, including lower-emitting process and practices. In assessing available GHG control measures, we reviewed EPA’s RACT/BACT/LAER Clearinghouse, the South Coast Air Quality Management District’s BACT determinations, and the Pioneer Valley Energy Center permit information found on the EPA Region 1 website (Pioneer Valley is a recently permitted 431 MW combined cycle turbine project in Westfield, Massachusetts). EPA stated generally that BACT for the Pioneer Valley project is energy efficient combustion technology and additional energy savings measures at the facility, if possible. Specifically, BACT was cited as installation of a combined cycle turbine and GHG emission limits were developed.

For the proposed Project, potential GHG controls are:

1. Low carbon-emitting fuels;
2. Carbon capture and storage (CCS); and
3. Energy efficiency and heat rate.

Step 2: Technical Feasibility of Potential GHG Control Options

Low Carbon-Emitting Fuels

Natural gas combustion generates significantly lower carbon dioxide emission rates per unit heat than distillate oil (approximately 27% less) or coal (approximately 50% less). Use of biofuels would reduce fossil-based carbon dioxide emissions, since biofuels are produced from recently harvested plant material rather than ancient plant material that has transformed into fossil fuel. However, biofuels are in liquid form, and the Project is not being designed for liquid fuel. In addition, combined cycle turbines have technical issues with biofuels that have yet to be resolved. It is likely that distillate fuel would need to have a limited percentage of biofuel added to be feasible. In this case, natural gas would still have lower fossil-based carbon emissions compared a distillate oil/biofuel mixture. For these reasons, biofuels have been eliminated from consideration. Therefore, natural gas represents the lowest carbon fuel available for the Project.

Energy Efficiency and Heat Rate

EPA’s GHG permitting guidance states,

“Evaluation of [energy efficiency options] need not include an assessment of each and every conceivable improvement that could marginally improve the energy efficiency of [a] new facility as a whole (e.g., installing more efficient light bulbs in the facility’s cafeteria), since the burden of this level of review would likely outweigh any gain in emissions reductions achieved. EPA instead recommends that the BACT analyses for units at a new facility concentrate on the energy efficiency of equipment that uses the largest amounts of energy, since energy efficient options for such units and equipment (e.g., induced draft fans, electric water pumps) will have a larger impact on reducing the facility’s emissions....”

EPA also recommends that permit applicants “propose options that are defined as an overall category or suite of techniques to yield levels of energy utilization that could then be evaluated and judged by the

permitting authority and the public against established benchmarks...which represent a high level of performance within an industry.” With regard to electric generation from combustion sources, the combined cycle combustion turbine is considered to be the most efficient technology available. Below is a discussion of energy efficiency and a comparison to other common combustion-based electric generation technologies.

GHG emissions from electricity production are primarily a function of the amount of fuel burned; therefore, a key factor in minimizing GHG emissions is to maximize the efficiency of electricity production. Another way to refer to maximizing efficiency is minimizing the heat rate. The heat rate of an electric generating unit is the amount of heat needed in BTU (British Thermal Units) to generate a kilowatt of electricity (kW), usually reported in Btu/kW-hr. The more efficient generating units have lower heat rates than less efficient units. Older, more inefficient boilers and turbines consume more fuel to generate the same amount of electricity than newer, more efficient boilers and turbines. This is due to equipment wear and tear, improved design in newer models as well as the use of higher quality metallurgy. In general, a boiler-based steam electric unit is less efficient than a combustion turbine combined cycle unit. This is because the combustion energy from a combustion turbine is directly imparted onto the turbine blades, and a combined cycle unit then uses the waste heat from the combustion turbine exhaust to generate additional power, utilizing a HRSG and subsequent steam cycle.

In addition to the efficiency of the electricity generation cycle itself, there are a number of key plant internal energy sinks (parasitic losses) that can improve a plant’s net heat rate (efficiency) if reduced. Measures to increase energy efficiency are clearly technically feasible and are addressed in more detail in Step 4 of the BACT process.

Carbon Capture and Storage

With regard to CCS, as identified by US EPA, CCS is composed of three main components: CO₂ capture and/or compression, transport, and storage. CCS may be eliminated from a BACT analysis in Step 2 if it can be shown that there are significant differences pertinent to the successful operation for each of these three main components from what has already been applied to a differing source type. For example, the temperature, pressure, pollutant concentration, or volume of the gas stream to be controlled, may differ so significantly from previous applications that it is uncertain the control device will work in the situation currently undergoing review. Furthermore, CCS may be eliminated from a BACT analysis in Step 2 if the three components working together are deemed technically infeasible for the proposed source, taking into account the integration of the CCS components with the base facility and site-specific considerations (e.g., space for CO₂ capture equipment at an existing facility, right-of-ways to build a pipeline or access to an existing pipeline, access to suitable geologic reservoirs for sequestration, or other storage options). While CCS is a promising technology, EPA does not believe that at this time CCS will be a technically feasible BACT option in certain cases.

As identified by the August 2010 Report of the Interagency Task Force on Carbon Capture and Storage (co-chaired by US EPA and the US Department of Energy), while amine- or ammonia-based CO₂ capture technologies are commercially available, they have been implemented either in non-combustion applications (i.e., separating CO₂ from field natural gas) or on relatively small-scale combustion applications (e.g., slip streams from power plants, with volumes on the order of what would correspond to one megawatt). Scaling up these existing processes represents a significant technical challenge and potential barrier to widespread commercial deployment in the near term. It is unclear how transferable the experience with natural gas processing is to separation of power plant flue gases, given the significant

differences in the chemical make-up of the two gas streams. In addition, integration of these technologies with the power cycle at generating plants present significant cost and operating issues that will need to be addressed to facility widespread, cost-effective deployment of CO₂ capture. Current technologies could be used to capture CO₂ from new and existing fossil energy power plants; however, they are not ready for widespread implementation primarily because they have not been demonstrated at the scale necessary to establish confidence for power plant applications.

Regarding pipeline transport for CCS, there is no nearby existing CO₂ pipeline infrastructure (see Figure 4-1); the nearest CO₂ pipelines to Massachusetts are in northern Michigan and southern Mississippi. With regard to storage for CCS, the Interagency Task Force concluded that while there is currently estimated to be a large volume of potential storage sites, “to enable widespread, safe, and effective CCS, CO₂ storage should continue to be field-demonstrated for a variety of geologic reservoir classes” and that “scale-up from a limited number of demonstration projects to widescale commercial deployment may necessitate the consideration of basin-scale factors (e.g., brine displacement, overlap of pressure fronts, spatial variation in depositional environments, etc.)”.

Based on the abovementioned EPA guidance regarding technical feasibility and the conclusions of the Interagency Task Force for the CO₂ capture component alone (let alone a detailed evaluation of the technical feasibility of right-of-ways to build a pipeline or of storage sites), CCS has been determined to not be technically feasible.

Step 3: Ranking of Technically Feasible GHG Control Options by Effectiveness

Based on the results of Step 2, the only option being carried further into the analysis is the evaluation energy efficiency and heat rate. The Project is already using the lowest carbon fuel and carbon capture and storage is not currently feasible.

Step 4: Evaluation of Energy Efficiency and Heat Rate

Improvements to energy efficiency and “heat rate” are important GHG control measures that can be employed to mitigate GHG emissions. Heat rate indicates how efficiently power is generated by combustion of a given amount of fuel. Heat rate is normally expressed in units of British thermal units (Btu) combusted per net kilowatt-hour (kw-hr) of energy produced. A higher value of “heat rate” indicates more fuel (i.e., Btu) is needed to produce a given amount of energy (lower or less favorable efficiency), while a lower value of heat rate indicates less fuel (i.e., Btu) is needed to produce a given amount of energy (higher or more favorable efficiency).

The Proposed Project is using advanced combustion turbine combined cycle technology, which is recognized as the most efficient commercially available technology for producing electric power from fossil fuels. Improvements to the heat rate typically will not change the amount of fuel combusted for a given combustion turbine installation, but it will allow more power to be produced from a given amount of fuel (i.e., improve the heat rate) so that more GHG emissions will be displaced from existing sources.

Key factors addressed in the evaluation of energy efficiency and heat rate are the core efficiency of the selected turbines and the significant factors affecting overall net heat rate in combined cycle operating mode.




Figure 4-1. CO₂ Pipelines in the United States
 From: "Report of the Interagency Task Force on Carbon Capture and Storage," August 2010, Appendix B.

The design basis of the proposed project is to install approximately 630 MW of electric generation which is equivalent to two "F" Class turbines in combined cycle configuration. "G" class turbines are slightly more efficient and thus have a lower heat rate; however, "G" class turbines generate approximately 380 to 400 MW per turbine (or 760 to 800 MW for two turbines). In addition, "G" class turbines generally have a higher low operating limit (the lowest MW output at which the facility can operate in compliance with its permits) than the proposed "F" class turbines. Although "G" class turbines are slightly more energy efficient than the proposed "F" Class turbines, "G" Class turbines would alter the scope of the project due to their size. The "F" Class design size provides the compatible size match to the existing high voltage switchyard and electrical interconnection infrastructure associated with the existing Salem Harbor Generating Station site. The "F" class design also provides greater operational flexibility and therefore lower overall emissions. The expected heat rate or efficiency differential between "F" and "G" combined cycles, comparably configured and equipped is less than 1 percent at ISO conditions, in unfired mode, when both plants are comparably equipped for quick start-up. When site specific conditions are accounted for, this apparent efficiency difference between "F" and "G" class machines is further reduced by the

higher parasitic power consumption of the fuel gas compressors for the “G” machines, which require higher natural gas supply pressures compared to “F” class. For these reasons, “G” class machines have been eliminated from consideration for the Proposed Project.

The advanced generation of “F” class machines have upgraded performance with increased MW output and improved heat rate compared to prior designs. These machines also represent the current state-of-the-art for the evolving “F” class technology that is now been in operation for greater than 20 years with thousands of machines in operation. This provides a conservative and predictable basis to formulate financial plans and to project future reliability and costs. The steam cycle portion of the plant (HRSG, piping, & steam turbine generator) as designed with two smaller units in the “1 on 1” configuration will exhibit superior operational flexibility, ability to deal with rapid thermal transients and exhibit acceptable and foreseeable long term O&M cost impacts.

With regard to energy efficiency considerations in combined cycle combustion turbine facilities, the activity with the greatest effect on overall efficiency is the method of condenser cooling. As with all steam-based electric generation, combined cycle plants can use either dry cooling or wet cooling for condenser cooling. Dry cooling uses large fans to condense steam directly inside a series of piping, similar in concept to the radiator of a car. Wet cooling can either be closed cycle evaporative cooling (using cooling towers), or “once-through” cooling using sea water.

Total fuel heat input to the combined cycle combustion turbine (fuel burned in the combustion turbines and in the HRSG duct burners) and thus total steam flow available to the steam turbine, is fixed. The efficiency of conversion of the fixed steam flow to electrical output of the steam turbine generator is then primarily a function of the backpressure at which the low pressure turbine exhausts. A wet cooling system consisting either of a mechanical draft cooling tower with circulating water pumps and a shell and tube condenser, or a once-through system directly circulating sea water to the condenser, are capable of providing significantly lower condensing pressures compared to an all dry ACC system. Wet cooling performance is superior for efficiency purposes because of the basic thermodynamics of cooling, which allows either the cooling tower or once through system to produce colder water compared to dry cooling. As a result, operation of a dry cooling system requires approximately 1-5% more energy than a wet cooling system depending on ambient conditions (difference between wet and ACC systems gets smaller with lower ambient temperatures).

However, there are significant drawbacks to either a once-through system or wet mechanical draft cooling tower system. Once-through cooling involves use of large quantities of sea water that is returned to the ocean at a higher temperature. The impingement and entrainment associated with intake of the necessary large quantities of sea water, and the thermal impacts of discharges of once-through cooling, have been recognized to have negative environmental impacts and once-through cooling has therefore been eliminated from consideration.

Wet mechanical draft cooling towers also require a significant quantity of water, most of which is lost to evaporation to the atmosphere. Seawater can potentially be used for makeup to a wet evaporative system, but this is a very challenging application. The most likely candidate source for the volumes of cooling tower makeup water required would be the SESD sewage treatment plant. It is technically feasible to use effluent from a public sewerage treatment facility as make-up to a wet, evaporative cooling system. However the presence of typical chemical constituents in the effluent and the likely highly variable concentrations of certain of these constituents would place a burden on the Project. The effluent transferred from SESD would require further treatment to make it suitable and safe to use in the cooling

system. Even after further treatment the concentrations of certain dissolved minerals in the circulating water would impact the design; most likely require a high degree of cooling tower blowdown to maintain acceptable chemistry and requiring the upgrade of the metallurgy of the piping, condenser tube, pumps and other components that would be exposed to the more corrosive action of the treated and concentrate effluent.

An additional burden imposed of wet, evaporative cooling is dealing with the creation of visible fog plume, which discharges from the cooling tower fans. With the typical New England, coastal site weather conditions, a standard mechanical draft cooling tower would produce a very visible and persistent plume for many hours of the year. It is possible to use a so-called “plume abated” mechanical draft tower. But this feature can double the cost of the cooling tower and increase the total fan power consumption and pumping head on the system. Basically the “plume abatement” feature works by using heat from the hot condenser discharge water to preheat additional ambient air admitted above the normal cooling tower wet, evaporative heat exchange zone. This hotter air has a lower relative humidity; such that as it mixes with the wet, almost saturated air discharged from the evaporative cooling surface, the combined air mixture reaches a moisture content below the saturation point. As this hotter, dryer air mixture is discharged by the tower fans it can then mix with the cool, damp ambient air without crossing the saturation line and producing small water droplets which form the visible plume.

The bottom line is that a wet, evaporative mechanical draft cooling tower with plume abatement features has a doubled capital cost, higher fan power consumption and higher pumping head than a standard cooling tower. These latter two factors greatly reduce any potential benefit from reduced parasitic load from the wet cooling system.

Therefore, Footprint has determined that the marginal heat rate improvement that could be achieved with a plume abated mechanical draft tower does not outweigh the drawback of the technical issue associated with use of the SESD sewage effluent, as well as the fact that a visible plume will still be present at times with a plume abated tower. The use of dry cooling has therefore been selected over either wet cooling option.

The Administration Building has been designed to meet the U.S. Green Building Council’s Leadership in Energy and Environmental Design (LEED) at the Platinum level. The Administration Building, as well as the Operations Building, among various energy conservation features, incorporate green roofs, geothermal heat pumps for heating and cooling, building energy management systems, and a 10% reduction in lighting power density.

Step 5: Select BACT

The Project has proposed GHG limits as follows for the combined cycle units:

- Initial test limit of 825 lb CO₂e/MWhr (net to grid), full load, ISO corrected, without duct firing
- Rolling 365-day GHG BACT limit (life of facility) of 895 lb CO₂e/MWhr (net to grid)

For purposes of comparison, the initial test GHG limit of 825 lb CO₂e/MWhr (net to grid) corresponds to a “heat rate” of 6,940 Btu HHV/kWhr (net). On a “gross” energy basis, these values are 795 lb CO₂e/MWhr (gross) and 6,688 Btu HHV/kWhr (gross). The rolling 365-day GHG BACT limit of 895 lb CO₂e/MWhr (net to grid) corresponds to a “heat rate” of 7,521 Btu HHV/kWhr (net). On a “gross” energy basis, these values are 862 lb CO₂e/MWhr (gross) and 7,247 Btu HHV/kWhr (gross).

Note that “gross” energy is based on the full electric energy output of the generation equipment, without consideration of internal plant loads (parasitic losses such as for pumps and fans). Net energy is based on the amount of electric energy after internal plant demand is satisfied, and reflects the amount of energy actually sold to the electric grid.

For purposes of comparison with other projects, Footprint’s design thermal efficiency is 57.9%. This is based on ISO full load operation, without duct firing or evaporative cooling, without any degradation allowance, and reflects gross energy output fuel energy input based on LHV. This is the most typical way that thermal efficiency is reported. This is not as meaningful for purposes of GHG BACT limits compared to measures based on net power production, since those based on net power account for the project internal energy consumption. Footprint considers the proposed rolling 12-month CO₂e limit for the life of the project as the most meaningful limit since it reflects actual long-term emissions, and actual power delivered to the grid.

Pursuant to supporting these proposed limits consistent with the “top-down” procedure, Footprint has compiled PSD BACT determinations for GHG in the last five years for new large (> 100 MW) combustion turbine combined cycle projects. This compilation is based on all entries during this time period listed in the USEPA RBLC (RACT/BACT/LAER Clearinghouse). Several recent projects not included in RBLC have also been included in this compilation. This review confirms that the only BACT technology identified for large natural gas fired combined cycle turbines is use of low carbon fuel (i.e., natural gas) in high efficiency combined cycle units. There are no cases where any post combustion controls (carbon capture and sequestration) have been used to control GHG emissions from large natural gas fired combined cycle turbines.

Table 4-3 presents the results of RBLC compilation for GHG. GHG BACT emissions are expressed in varying units, including mass emission (tons or pounds per unit time), lb CO₂e per MWhr, and/or “heat rate” (Btu/kWhr). The energy-based limits are expressed as either “gross” or “net”. Energy units (MWhr or kWhr) are more meaningful than mass emission limits since they relate directly to the efficiency of the equipment, which is a key available BACT technology (in addition to low carbon fuel). The mass emissions are specific to the fuel firing rate of a given project and the carbon content of the fuel, but do not incorporate the project efficiency.

Table 4-3 lists 15 projects with PSD BACT limits for GHG approved in the last 5 years which have energy based GHG limits. (The mass limit projects are not considered since they are not meaningful for GHG BACT comparison). Accounting for the different units for these limits, the Footprint Project proposed GHG limits are clearly more stringent than most of the energy based limits in Table 4-3. For limits where this comparison is not clear, the following clarifications are made:

- The basis for Oregon (OH) Clean Energy project limits (840 and 833 lb/MWhr gross) is not clear, but the context of this actual permit suggests these limits are intended for ISO conditions without duct firing which makes them less stringent than the Footprint limits.
- The Brunswick County limit of 7,500 Btu/kWhr net *at full load* with duct firing does not directly correspond to either of the Footprint conditions. However, Footprint’s limit of 895 lb CO₂e/MWhr corresponds to a rolling 365-day value of 7,521 Btu/kWhr net which accounts for all operation on an annual basis including starts, stops, and part load in addition to duct firing.
- The Palmdale project limits of 774 lb/MWhr and 7,319 Btu/kWhr (source wide net 365 day average limits) are more stringent than the Footprint limits. However, the Palmdale project is a

Table 4-3. Summary Of Recent GHG PSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Turbine ¹	Emission Limits ²
				Greenhouse Gas (GHG) as CO ₂ e unless otherwise noted
Carroll County Energy	Washington Twp., OH	11/5/2013	2 GE 7FA 2045 MMBtu/hr/unit plus 566 MMBtu/hr DF	859 lb/MW/hr gross at ISO conditions without duct firing
Renaissance Power	Carson City, MI	11/1/2013	4 Siemens 501 FD2 units 2147 MMBtu/hr/unit each with 660 MMBtu/hr DF	1000 lb/MW/hr gross 12-month rolling average
Oregon Clean Energy	Oregon, OH	06/18/2013	2 Mitsubishi M501GAC or 2 Siemens SCC6-8000H 2932 MMBtu/hr/unit plus 300 MMBtu/hr DF	Mitsubishi: 840 lb/MW/hr gross Siemens: 833 lb/MW/hr gross
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	2 GE 7FA.05 2230 MMBtu/hr/unit plus 650 MMBtu/hr DF or 2 Siemens SGT6-5000F5 2260 MMBtu/hr/unit plus 450 MMBtu/hr DF	Heat rate of 7,340 Btu HHV/kW/hr gross without DF Heat rate of 7,780 HHV Btu/kW/hr gross with DF
Hickory Run Energy LLC	New Beaver Twp., PA	04/23/2013	GE7FA, Siemens SGT6-5000F, Mitsubishi M501G, or Siemens SGT6-8000H. 2 combined cycle units	3,665,974 tpy both units Emissions based on Siemens SGT6-8000H
Sunbury Generation	Sunbury, PA	04/01/2013	"F Class" with DF 2538 MMBtu/hr/unit	281,727 lb/hr without DF 298,106 lb/hr with DF
Brunswick County Power	Freeman, VA	03/12/2013	3 Mitsubishi M501 GAC with DF Combined GT and DF 3442 MMBtu/hr/unit	Heat rate of 7,500 Btu(HHV)/kW/hr net; tested at full load and corrected to ISO conditions with DF
Garrison Energy Center	Dover, DE	01/30/2013	GE 7FA with DF 309 MW	Heat rate of 7,717 Btu HHV/kW/hr net 12-month rolling average
St. Joseph Energy center	New Carlisle, IN	12/03/2012	4 - "F Class" (GE or Siemens) 1345 MW total	Heat rate of 7,646 Btu/kW/hr. Further detail not specified
Hess Newark Energy	Newark, NJ	11/01/2012	2 - GE 7FA.05 2320 MMBtu/hr/unit plus 211 MMBtu/hr DF	887 lb/MW/hr gross 12-month rolling average Heat rate of 7,522 Btu(HHV)/kW/hr; net basis at full load and corrected to ISO conditions without DF
Channel Energy Center, LLC	Houston, TX	10/15/2012	2 - Siemens 501F 180 MW plus 425 MMBtu/hr DF	920 lb/MW/hr net
Moxie Liberty LLC	Asylum Twp., PA	10/10/2012	Equipment type not specified 2 - 468 or less MW combined cycle blocks GT ≤ 2890 MMBtu/hr/unit DF ≤ 3870 MMBtu/hr/unit	1,388,540 tpy for 454 MW block 1,480,086 tpy for 468 MW block

Table 4-3. Summary Of Recent GHG PSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Turbine ¹	Emission Limits ²
				Greenhouse Gas (GHG) as CO ₂ e unless otherwise noted
Cricket Valley	Dover, NY	09/27/2012	3 - GE 7FA.05 2061 MMBtu/hr/unit plus 379 MMBtu/hr DF	Heat rate of 7,605 Btu HHV/kWhr ISO without DF 57.4% design thermal efficiency 3,576,943 tpy all 3 units
Deer Park Energy Center LLC	Deer Park, TX	09/26/2012	1 - Siemens 501F 180 MW plus 725 MMBtu/hr DF	920 lb/MWhr net
Pioneer Valley Energy Center (PVEC)	Westfield, MA	04/05/2012	1 Mitsubishi M501GAC 2542 MMBtu/hr/unit; no DF	825 lb/MWhr net (initial full load test corrected to ISO conditions) 895 lb/MWhr net (rolling 365-day average)
Palmdale Hybrid Power	Palmdale, CA	10/18/2011	2 GE 7FA 154 MW (1736 MMBtu/hr) per unit plus 500 MMBtu/hr DF	774 lb/MWhr source wide net 365 day rolling average (CO ₂) Heat rate: 7,319 Btu/kWhr source wide net 365 day rolling average
Thomas C. Ferguson Power	Llano, TX	09/01/2011	2 - GE 7FA 195 MW per unit No DF	908,957.6 lb/hr 30-day rolling average
Brockton Power	Brockton MA	07/20/2011 (MA Plan Approval)	1 Siemens SGT6-PAC-5000F 2227 MMBtu/hr plus 641 MMBtu/hr DF	870 lb CO ₂ e/MWhr monthly average 842 lb/MWhr rolling 12-month average 1,094,900 tpy
Russell City Energy Center	Hayward, CA	02/03/2010	2 - Siemens 501F 2238.6 MMBtu/hr/unit plus 200 MMBtu/hr DF	Heat rate of 7,730 Btu HHV/kWhr 242 metric tons of CO ₂ e/hr/both units 5,802 metric tons of CO ₂ e/day/both units 1,928,102 metric tons of CO ₂ e/year/both units 119 lb CO ₂ e/MMBtu

¹ DF refers to duct firing

² Limits obtained from agency permitting documents when not available in RBLC

hybrid solar/gas turbine project, and the Palmdale GHG limits appear to account for the solar energy production component. The Footprint Project's available land and Massachusetts climate restrictions preclude a solar component which could achieve the Palmdale limits.

- The Brockton (MA) Project was approved for a rolling 12-month CO₂ limit of 842 lb/MWhr, and a monthly maximum of 870 lb/MWhr. The basis for the 842 lb/MWhr limit in the Massachusetts Plan Application for the Brockton Project is stated *to include operation at a variety of loads, ambient temperatures, with and without evaporative cooling, and with and without duct firing, and including starts and stops* (Brockton Power Plan Application at page 4-30). However, there is no mention of any allowance for heat rate (efficiency) degradation over the life of the project or between major turbine overhauls. This is a significant consideration which renders this value of 842 lb CO₂/MWhr as inappropriate as a GHG BACT precedent. Footprint notes that the Brockton Project has not been constructed, and the 842 lb/MWhr value therefore has not been demonstrated in practice. In addition, the Footprint notes that the Brockton Project did not specifically undergo a PSD review for GHG BACT. Footprint also notes that in the Plan Application for the Brockton Project, it is stated that the 842 lb/MWhr value is based on a CO₂ emission factor of 117 lb/MMBtu. Footprint notes its proposed limit of 895 lb/net MWhr is based on a CO₂e emission factor of 119 lb/MMBtu. Adjusting the Brockton value of 842 lb/MWhr by 119/117, the Brockton rate (based on 119 lb CO₂/MMBtu) would be 856 lb/MWhr. In this case, the Footprint Project value (895 lb/MWhr) is only 4.6% higher than the adjusted Brockton value (856 lb/MWhr). In addition, the Brockton Project design is based on wet cooling, while the Footprint Project will use dry cooling. Projects using dry cooling have higher heat rates (are less efficient) than wet cooled projects, particularly during the summer months. Reasonable allowance for heat rate (efficiency) degradation over the life of the project and between major turbine overhauls, as well as the impact of wet vs. dry cooling, explains the proposed GHG BACT for the SHR Project of 895 lb/net MWhr compared to the proposed Brockton limit.

CLF comments dated November 1, 2013 on the Footprint public review documents indicate that the Newark Energy Center has a combined cycle mode heat rate limit of 6005 Btu/kWhr, corresponding to a thermal efficiency of 58.4%. The CLF comments further note that the Russell Energy Center Project in CA has proposed to achieve a thermal efficiency of 56.4%, and the Cricket Valley Project (NY) proposed to achieve 57.4% efficiency. These values are taken from a letter written by Steve Riva dated April 17, 2012.

The Newark Energy Center quoted values of 6005 Btu/kWhr and 58.4% thermal efficiency appear to be preliminary values, since they do not match the actual New Jersey PSD Permit as discussed below. When comparing heat rate and efficiency values, these may be quoted with varying assumptions, and it is important to ensure an "apples to apples" comparison is made. The heat rate used to calculate thermal efficiency is typically specified based on full load ISO operation, no duct firing, gross output, and on an LHV basis. That is why it is commonly a lower value than "real world" rolling 12-month, net, HHV values. These two values (6005 Btu/kWhr and 58.4% thermal efficiency) are actually not consistent with each other, since thermal efficiency is calculated as $3412 \text{ Btu/kW-hr} / 6005 \text{ Btu/kW-hr} = 56.8\%$ thermal efficiency. In any event, the "real" numbers for the Newark Energy Center GHG BACT limits in Table 4-3 are taken from the actual New Jersey PSD permit dated November 1, 2012, so these represent more recent information for the Newark Energy Center Project. The actual Newark Energy Center permit has net "heat" rate limit (without duct firing at base load corrected to ISO conditions) of 7,522 Btu/kWhr based on the Higher Heating Value (HHV) of the fuel. As indicated above, the Footprint Project has a

nearly numerically identical rolling 365-day GHG limit which corresponds to a net heat rate of 7,521 Btu/kWhr, but that reflects *all* annual operation and not just base load without duct firing. The Newark Energy Center also has a direct GHG limit of 887 lb/MWhr, gross basis, rolling 12-month average. The Footprint rolling 365-day GHG limit of 895 lb/MWhr *net basis* is clearly more stringent than the actual Newark Energy Center GHG limit.

The Russell Energy Center PSD Permit has a heat rate limit of 7,730 Btu/kW-hr, with the key assumptions for calculating compliance not specified. In any event, this limit is clearly less stringent than Footprint's rolling 365-day GHG limit which corresponds to a net heat rate of 7,521 Btu/kWhr. Footprint's design thermal efficiency of 57.9% is also better than the quoted Russell proposal of 56.4% (not referenced in the Russell's actual PSD permit).

Cricket Valley's PSD permit does contain the quoted 57.4% thermal efficiency, and well as a heat rate limit of 7,605 Btu/kW-hr. The Cricket Valley PSD permit indicates this heat rate is at ISO conditions, HHV without duct firing. Gross or net electric output is not specified. As with Russell, this limit is clearly less stringent than Footprint's rolling 365-day GHG limit which corresponds to a net heat rate of 7,521 Btu/kWhr. Footprint's design thermal efficiency of 57.9% is also better than the Cricket Valley value 57.4%.

CLF suggests that the GHG limits should also be expressed on a thermal efficiency basis. As stated above, thermal efficiencies for gas turbines are normally based on the lower heating value (LHV) of the fuel, on a gross energy basis. The only PSD Permit we identified containing a thermal efficiency value is the Cricket Valley PSD permit. As MassDEP has done, Footprint concurs it is more appropriate to propose GHG limits directly as CO₂e on a *net* energy basis, accounting for actual emissions of GHG and overall project efficiency including parasitic plant loads.

In summary, the available evidence clearly indicates that PSD BACT for GHG for combustion turbines is use of low carbon fuel (e.g., natural gas) in high efficiency combustion combined cycle turbines. Footprint's proposed GHG limits are as or more stringent than any PSD BACT determinations, except for a hybrid solar facility, and the Brockton Power Project, which has a rolling 12-month limit which does not properly account for degradation over the life of the equipment. It is concluded that Footprint's proposed GHG limits represent PSD BACT.

4.1.6 Combustion Turbine Startup and Shutdown BACT

This section supplements the PSD BACT analysis for the combustion turbine startup and shutdown (SUSD) limits. Combustion turbine combined cycle units require warm up time to achieve proper operation of the dry-low NO_x combustors discussed above, and also to achieve system warm-up to allow proper function of the SCR catalysts. Combustion turbine combined cycle units require higher mass emission limits during SUSD operations for NO_x, CO and VOC. Since CO and VOC are not subject to PSD review, this SUSD BACT assessment only addresses NO_x. The other pollutants subject to PSD review are PM/PM₁₀/PM_{2.5}, H₂SO₄, and GHG, as these pollutants have lower mass emissions than for normal operation and thus are not included in this PSD SUSD BACT evaluation. GHG also has the rolling 12-month limit (lb/MWhr) encompassing all operation including SUSD.

This evaluation does not identify and discuss each of the five individual steps of the "top-down" BACT process, since the only available control for SUSD are procedures to warm up the systems and begin operation of the temperature-dependent emission control systems as quickly as practical, consistent with all system constraints. The Project incorporates new "quick start" technology which minimizes SUSD

emissions significantly compared to prior startup procedures in widespread use. Table 4-4 presents the proposed NO_x SUSD BACT limits for the Project:

Table 4-4. Combustion Turbine NO_x SUSD PSD BACT Limits

Pollutant	Startup (lb/event)	Shutdown (lb/event)
NO _x	89	10

In addition to these limits, the Project has a limit for startup duration of ≤ 45 minutes and for shutdown duration of ≤ 27 minutes. Also, the project is required to begin SCR operation (inject ammonia) as soon as the systems attain the minimum temperatures as specified by the control equipment system vendors, and other system parameters are satisfied for SCR operation.

As part of the review of these proposed NO_x SUSD BACT limits under the “top-down” procedure, Footprint has compiled all the NO_x SUSD PSD BACT determinations in the last five years for new gas-fired large (> 100 MW) combustion turbine combined cycle projects. This compilation is presented in Table 4-5. This compilation is based on the USEPA RBLC (RACT/BACT/LAER Clearinghouse). Several recent projects not included in RBLC have also been included in this compilation. This review confirms that the only SUSD NO_x BACT technologies identified are procedures to warm up the systems and begin operation of the SCR as quickly as practical consistent with other constraints. Table 4-5 contains 28 new large (> 100 MW) combustion turbine combined cycle projects with NO_x SUSD PSD BACT determinations. These limits are generally expressed as either lb/hr or lb/event. Some units do not have numerical SUSD limits for NO_x, but only requirements to minimize SUSD emissions.

For purposes of comparing the Project limits to determinations only expressed in lb/hr, Footprint’s worst case lb/hr is calculated as 45 minutes for a cold start (at 89 pounds) plus 15 minutes at full load ($18.1 \text{ lb/hr}/4 = 93.5 \text{ lb/hr}$). Also, while the Project’s proposed NO_x SUSD limits for a start are only for a worst-case cold start, for comparison purposes the Project’s values for a warm and hot start, as provided in the August 6, 2013 Application Supplement, are 54 and 28 pounds, respectively.

All the NO_x SUSD BACT limits in Table 4-5 are less stringent than the Footprint limits, except for the warm start limits at two CA projects (Palmdale and Victorville), and startup/shutdown limits for the Brockton MA Project. Palmdale and Victorville each have the same limit for a warm and hot start of 40 lbs/event, while the Footprint values are 54 lbs for a warm start and 28 lbs for a hot start. It is logical that a warm start would have higher emissions than a hot start, and the average of the two Footprint values (54 lbs and 28 lbs) is 41 lbs/event, effectively identical to the Palmdale and Victorville value.

The Brockton project is based on a “quick start” Siemens SGT6-PAC-5000F combined cycle installation, and has approved SUSD limits of 31.6 lb/hr (startup) and 29.8 lb/hr (shutdown). The startup time is stated as 0.47 hours and the shutdown time is 0.40 hours. Thus, the lb/event values are calculated as 14.9 pounds for a start and 11.9 pounds for a shutdown. Footprint did consider a very similar Siemens turbine subsequent to the approval data of the Brockton permit, and this more recent data for the same basic “quick start” Siemens machine (5000F) now has 83 lbs NO_x over 45 minutes. For a combined cold start and shutdown, Footprint now has $(89 + 10 = 99)$ lbs NO_x while the Siemens data provided to Footprint reflects $(83 + 20 = 103)$ lbs NO_x. GE has lower NO_x emissions for both the warm and hot start. So, based on the latest information, there is no advantage to selecting Siemens over GE for NO_x startup/shutdown emissions based on more recent data.

Table 4-5. Summary Of Recent NOx SUSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Turbine ¹	Emission Limits ²
				SUSD NOx (values are for a single unit at multiple unit facilities)
Carroll County Energy	Washington Twp., OH	11/5/2013	2 GE 7FA 2045 MMBtu/hr/unit plus 566 MMBtu/hr DF	Cold Start: 476 lbs/event Warm Start: 290 lbs/event Hot Start: 160 lbs/event Shutdown: 77 lbs/event Values calculated from approved lb/hr and event durations
Renaissance Power	Carson City, MI	11/1/2013	4 Siemens 501 FD2 units 2147 MMBtu/hr/unit each with 660 MMBtu/hr DF	176.9 lb/hr SU and 147.3 lb/hr SD
Langley Gulch Power	Payette, ID	08/14/2013	1 - Siemens SGT6-5000F 2134 MMBtu/hr/unit with 241.28 MMBtu/hr DF	96 ppm; 3 hr rolling average <i>(for the amount of fuel firing during SUSD for a GE 7FA, 96 ppm corresponds to approximately 450 lbs over a 45 minute quick start)</i>
Oregon Clean Energy	Oregon, OH	06/18/2013	2 Mitsubishi M501GAC or 2 Siemens SCC6-8000H 2932 MMBtu/hr/unit plus 300 MMBtu/hr DF	Mitsubishi: Cold Start: 108.9 lbs/event Warm Start: 86 lbs/event Hot Start: 47.2 lbs/event Shutdown: 35 lbs/event Siemens: – Cold Start: 188 lbs/event Warm Start: 126 lbs/event Hot Start: 108 lbs/event Shutdown: 46 lbs/event Values calculated from approved lb/hr and event durations
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	2 GE 7FA.05 2230 MMBtu/hr/unit plus 650 MMBtu/hr DF or 2 Siemens SGT6-5000F5 2260 MMBtu/hr/unit plus 450 MMBtu/hr DF	Minimize emissions, No numeric limits
Brunswick County Power	Freeman, VA	03/12/2013	3 Mitsubishi M501 GAC with DF Combined GT and DF 3442 MMBtu/hr/unit	Minimize emissions, No numeric limits
Garrison Energy Center	Dover, DE	01/30/2013	GE 7FA 309 MW	Cold Start/: 500 lbs/event Warm/Hot Start/: 200 lbs/event Shutdown: 23 lbs/event
St. Joseph Energy Center	New Carlisle, IN	12/03/2012	4 - "F Class" (GE or Siemens) 1345 MW total	443 lb/event

Table 4-5. Summary Of Recent NO_x SUSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Turbine ¹	Emission Limits ²
				SUSD NO _x (values are for a single unit at multiple unit facilities)
Hess Newark Energy Center	Newark, NJ	11/01/2012	2 - GE 7FA.05 2320 MMBtu/hr/unit plus 211 MMBtu/hr DF	Cold Start: 140.6 lbs/event Warm Start: 96.8 lbs/event Hot Start: 95.2 lbs/event Shutdown: 25 lbs/event
Channel Energy Center, LLC	Houston, TX	10/15/2012	2 - Siemens 501F 180 MW plus 425 MMBtu/hr DF	350 lb/hr
Moxie Liberty LLC	Asylum Twp., PA	10/10/2012	Siemens "H Class" 2 - 468 or less MW combined cycle blocks GT ≤ 2890 MMBtu/hr/unit DF ≤ 3870 MMBtu/hr/unit	No SUSD listed in RBLC
Deer Park Energy Center LLC	Deer Park, TX	09/26/2012	1 - Siemens 501F 180 MW plus 725 MMBtu/hr DF	350 lb/hr
ES Joslin Power	Calhoun, TX	09/12/2012	3 - GE 7FA 195 MW per unit No DF	99.9 lb/hr
Pioneer Valley Energy Center (PVEC)	Westfield, MA	04/05/2012	1 Mitsubishi M501GAC 2542 MMBtu/hr/unit; no DF	62 lb/hr (310 lbs/event for cold start) (124 lbs/event for warm start) (62 lbs/event for shutdown)
Palmdale Hybrid Power	Palmdale, CA	10/18/2011	2 GE 7FA 154 MW (1736 MMBtu/hr) per unit plus 500 MMBtu/hr DF	Cold Start: 96 lbs/event Warm/Hot Start: 40 lbs/event Shutdown: 57 lbs/event
Thomas C. Ferguson Power	Llano, TX	09/01/2011	2 - GE 7FA 195 MW per unit No DF	111.56 lb/hr
Entergy Ninemile Point Unit 6	Westwego, LA	08/16/2011	Vendor not specified Single unit 550MW	No SUSD in RBLC
Brockton Power	Brockton MA	07/20/2011 (MA Plan Approval)	1 Siemens SGT6-PAC-5000F 2227 MMBtu/hr plus 641 MMBtu/hr DF	Start: 31.6 lb/hr Shutdown: 29.8 lb/hr
Avenal Power Center	Avenal, CA	05/27/2011	2 - GE 7FA 1856.3 MMBtu/hr/unit plus 562.26 MMBtu/hr DF	Each unit: 160 lb/hr Both units: 240 lb/hr

Table 4-5. Summary Of Recent NOx SUSD BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Turbine ¹	Emission Limits ²
				SUSD NOx (values are for a single unit at multiple unit facilities)
Portland Gen. Electric Carty Plant	Morrow, OR	12/29/2010	1 - Mitsubishi M501GAC 2866 MMBtu/hr	150 lb/hr; 3-hr rolling average
Dominion Warren County	Front Royal, VA	12/21/2010	3 -Mitsubishi M501 GAC 2996 MMBtu/hr/unit plus 500 MMBtu/hr DF	Minimize emissions, No numeric limits
Pondera/King Power Station	Houston, TX	08/05/2010	4 GE 7FA.05 2430 MMBtu/hr/unit GT plus DF or 4 Siemens SGT6-5000F5 2693 MMBtu/hr/unit GT plus DF	GE: 216 lb/hr/unit Siemens: 220 lb/hr/unit
Live Oaks Power	Sterling, GA	03/30/2010	Siemens SGT6-5000F	Minimize emissions, No numeric limits
Victorville 2 Hybrid	Victorville, CA	03/11/2010	2 GE 7FA 154 MW per unit plus 424.3 MMBtu/hr DF	Cold Start: 96 lbs/event Warm/Hot Start: 40 lbs/event Shutdown: 57 lbs/event
Stark Power/Wolf Hollow	Granbury, TX	03/03/2010	2 GE 7FA 170 MW/unit plus 570 MMBtu/hr DF or 2 Mitsubishi M501G 254 MW/unit plus 230 MMBtu/hr DF	GE: 420 lb/hr/unit Mitsubishi: 239 lb/hr/unit
Russell City Energy Center	Hayward, CA	02/03/2010	2 - Siemens 501F 2238.6 MMBtu/hr/unit plus 200 MMBtu/hr DF	Cold Start: 480 lbs/event/unit Warm Start: 125 lbs/event/unit Hot Start: 95 lbs/event/unit Shutdown: 40 lbs/event/unit
Panda Sherman Power	Grayson, TX	02/03/2010	2 GE 7FA or 2 Siemens SGT6-5000F with 468 MMBtu/hr/unit DF	GE: 242 lb/hr/unit Mitsubishi: 148.5 lb/hr/unit
Lamar Power Partners II LLC	Paris, TX	06/22/2009	4 - GE 7FA with 200 MMBtu/hr DF	No SUSD limits in RBLC or TX permit
Pattillo Branch Power LLC	Savoy, TX	06/17/2009	4 – GE 7FA, GE7FB, or Siemens SGT6-5000F With DF	650 lb/hr/unit (each option)
Entergy Lewis Creek Plant	The Woodlands, TX	05/19/2009	2 - GE 7FA with 362 MMBtu/hr DF	200 lb/hr

¹ DF refers to duct firing; ² Short-term limits only. Limits obtained from agency permitting documents when not available in RBLC.

PVEC does have a somewhat more stringent NO_x SUSD BACT limit on an hourly basis (62.0 lbs per hour) compared to the equivalent Footprint lb/hr value of 93.5 lbs/hr. However, PVEC has longer startup and shutdown times, with up to 5 hours for a cold start, 2 hours for a warm start, and 1 hour for a shutdown. On a pound per event basis, PVEC has greater SUSD emissions compared to Footprint.

Footprint will achieve the lowest practical emissions achievable for SUSD, and the proposed PSD permit allows the MassDEP to reset the SUSD BACT limits if different values are demonstrated to be achievable.

4.2 Auxiliary Boiler

This section supplements the PSD BACT analysis for the auxiliary boiler to address public comments made on the draft permit documents. The Project is subject to PSD review for NO_x, PM/PM₁₀/PM_{2.5}, H₂SO₄, and GHG, and thus the auxiliary boiler is subject to PSD BACT for these pollutants.

The Project includes an 80 MMBtu/hr auxiliary boiler that will have natural gas as the only fuel of use. Table 4-6 presents the proposed BACT limits for the auxiliary boiler for pollutants subject to PSD review.

Table 4-6. Auxiliary Boiler Proposed PSD BACT Limits

Pollutant	Emission Limitation	Control Technology
NO _x	9 ppmvd at 3% O ₂ 0.011 lbs/MMBtu	Ultra Low NO _x Burners (9 ppm) Good combustion practices Natural gas
PM/PM ₁₀ /PM _{2.5}	0.005 lbs/MMBtu	
H ₂ SO ₄	0.0009 lbs/MMBtu	Natural Gas
GHG as CO ₂ e	119.0 lb/MMBtu	Natural Gas

(Note: the H₂SO₄ value is revised to reflect the inclusion of a CO oxidation catalyst)

In order to inform the PSD BACT process, Footprint has compiled all the PSD BACT determinations in the last five years for auxiliary boilers at new large (> 100 MW) combustion turbine combined cycle projects. This compilation is based on the USEPA RBLC (RACT/BACT/LAER Clearinghouse). Several recent projects not included in RBLC have also been included in this compilation. Table 4-7 provides this compilation. Table 4-7 will be referred to in the individual pollutant discussion below.

4.2.1 Fuel Selection

Step 1: Identify Candidate Fuels

- Natural gas
- ULSD

Step 2: Eliminate Infeasible Technologies

Both these technologies are technically feasible.

Step 3: Rank Control Technologies by Control Effectiveness

Natural gas boilers can achieve lower emissions compared to ULSD.

Step 4: Evaluate Controls

Footprint has chosen the lowest emitting fuel for the auxiliary boiler, natural gas. Therefore, a detailed evaluation of alternate fuels is not required.

Step 5: Select BACT

Natural gas is proposed as the BACT fuel for the auxiliary boiler.

Table 4-7. Summary Of Recent PSD BACT Determinations for Natural Gas Auxiliary Boilers at Large (>100MW) Gas Fired Combined-Cycle Generating Plants for NO_x, PM, H₂SO₄, GHG

Facility	Location	Permit Date	Auxiliary Boiler Size MMBtu/hr	Emission Limits ¹ (lb/MMBtu except where noted)			
				NO _x	PM/PM10/PM2.5	H ₂ SO ₄	GHG
Carroll County Energy	Washington Twp., OH	11/5/2013	99	0.02	0.008	0.00022	26,259.76 tpy
Renaissance Power	Carson City, MI	11/1/2013	(2) - 40	0.035	0.005	--	11,503.7 tpy (both units)
Oregon Clean Energy	Oregon, OH	06/18/2013	99	0.02	0.008	0.00011	11,671 tpy
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	75	9 ppmvd at 3% O ₂ (= 0.011 lb/MMBtu)	Pipeline natural gas < 0.1 gr S/100scf	--	Pipeline natural gas
Hickory Run Energy LLC	New Beaver Twp., PA	04/23/2013	40	0.011	0.005	0.0005	13,696 tpy
Sunbury Generation	Sunbury, PA	04/01/2013	Not provided (repowered unit)	0.036	0.008	--	--
Brunswick County Power	Freeman, VA	03/12/2013	66.7	9 ppmvd at 3% O ₂ (= 0.011 lb/MMBtu)	Pipeline natural gas < 0.4 gr S/100scf	Pipeline natural gas < 0.4 gr S/100scf	Pipeline natural gas
St. Joseph Energy Center	New Carlisle, IN	12/03/2012	(2) - 80	0.032	0.0075	--	81,996 tpy; 80% efficiency
Hess Newark Energy Center	Newark, NJ	11/01/2012	66.2	0.66 lb/hr (based on 0.010 lb/MMBtu)	0.33 lb/hr (based on 0.005 lb/MMBtu)	0.006 lb/hr (=0.0001 lb/MMBtu at full load)	7,788 lb/hr
Channel Energy Center, LLC	Houston, TX	10/15/2012	(3) - 430	21.6 lb/hr/unit (=0.05 lb/MMBtu at full load)	7.8 lb/hr/unit (=0.018 lb/MMBtu at full load)	1.0 lb/hr/unit (=0.002 lb/MMBtu at full load)	--
Cricket Valley	Dover, NY	09/27/2012	60	0.011	0.005	--	--
Pioneer Valley Energy Center (PVEC)	Westfield, MA	04/05/2012	21	0.029	0.0048	0.0005	--
Palmdale Hybrid Power	Palmdale, CA	10/18/2011	110	9 ppmvd at 3% O ₂ (= 0.011 lb/MMBtu)	0.33 lb/hr (=0.003 lb/MMBtu at full load)	--	Annual tuneup
Entergy Nine-mile Point Unit 6	Westwego, LA	08/16/2011	338	--	7.6 lb/MMscf (= 0.0076 lb/MMBtu)	--	117 lb/MMBtu

Table 4-7. Summary Of Recent PSD BACT Determinations for Natural Gas Auxiliary Boilers at Large (>100MW) Gas Fired Combined-Cycle Generating Plants for NO_x, PM, H₂SO₄, GHG

Facility	Location	Permit Date	Auxiliary Boiler Size MMBtu/hr	Emission Limits ¹ (lb/MMBtu except where noted)			
				NO _x	PM/PM10/PM2.5	H ₂ SO ₄	GHG
Brockton Power	Brockton MA	07/20/2011 (MA Plan Approval)	60	0.011	0.01	--	--
Avenal Power Center	Avenal, CA	05/27/2011	37.4	9 ppmvd at 3% O ₂ (= 0.011 lb/MMBtu)	0.34 grains S/100 dscf and pipeline quality gas	--	--
Portland Gen. Electric Carty Plant	Morrow, OR	12/29/2010	91	50 lb/MMscf (= 0.05 lb/MMBtu)	2.5 lb/MMscf (= 0.0025 lb/MMBtu)	--	--
Dominion Warren County	Front Royal, VA	12/21/2010	88.1	0.011 lb/MMBtu	0.44 lb/hr (=0.005 lb/MMBtu at full load)	--	--
Pondera/King Power Station	Houston, TX	08/05/2010	(2) - 45	0.45 lb/hr/unit (=0.01 lb/MMBtu at full load)	0.32 lb/hr/unit (=0.007 lb/MMBtu at full load)	--	--
Victorville 2 Hybrid	Victorville, CA	03/11/2010	35	9 ppmvd at 3% O ₂ (= 0.011 lb/MMBtu)	0.2 grains S/100 dscf and pipeline quality gas	--	--
Stark Power/Wolf Hollow	Granbury, TX	03/03/2010	142	1.42 lb/hr/unit (=0.01 lb/MMBtu at full load)	1.06 lb/hr/unit (=0.0075 lb/MMBtu at full load)	--	--
Panda Sherman Power	Grayson, TX	02/03/2010	53	0.53 lb/hr/unit (=0.01 lb/MMBtu at full load)	0.53 lb/hr/unit (=0.01 lb/MMBtu at full load)	--	--
Pattillo Branch Power LLC	Savoy, TX	06/17/2009	(4) - 40	1.4 lb/hr/unit (=0.01 lb/MMBtu at full load)	0.3 lb/hr/unit (=0.0075 lb/MMBtu at full load)	--	--

¹Short term limits only for NO_x, PM, and H₂SO₄. Limits obtained from agency permitting documents when not available in RBLC

4.2.2 NO_x

Step 1: Identify Candidate Control Technologies

- Selective Catalytic Reduction
- Ultra-Low NO_x burner
- Low NO_x burner, typically with flue gas recirculation

Step 2: Eliminate Infeasible Technologies

All these technologies are technically feasible, although application of SCR is unusual for natural gas boilers in this size range.

Step 3: Rank Control Technologies by Control Effectiveness

The ranking of these technologies is as follows:

1. SCR: Demonstrated to have achieved less than 5.0 ppmvd NO_x at 3% O₂ for gas fired boilers. Can be used as supplemental control with a low NO_x burner but not demonstrated with an ultra-low-NO_x burner.
2. Ultra-Low NO_x burner: Demonstrated to have achieved 9 ppmvd NO_x at 3% O₂
3. Low NO_x burner, typically with flue gas recirculation: Generally recognized to achieve 30 ppmvd NO_x at 3% O₂.

Step 4: Evaluate Controls

Since SCR is technically feasible, an economic analysis of the cost effectiveness for emission control was conducted. This economic analysis is presented in Table 4-8. The capital cost estimate for an SCR system and an ultra-low NO_x burner are based on information provided by Cleaver Brooks. The SCR has been conservatively assumed to control 90% of the potential NO_x emissions (to 3 ppmvdc at 3% O₂) even though 5 ppmvdc has been approved in past projects. Control to this NO_x level is likely to correspond to an ammonia slip level of 10 ppm at 3% O₂. Table 4-8 indicates that the average and particularly the incremental cost effectiveness of an SCR are excessive, at over \$19,000 per ton for average cost of control, and nearly \$70,000 per ton on an incremental basis. The ultra-low-NO_x burner is cost effective and is the proposed BACT. There are no energy or environmental issues with ultra-low NO_x burners that would indicate selection of SCR as BACT, given the unfavorable SCR economics.

Step 5: Select BACT

With respect to NO_x, the lowest limit identified for any of the power plant auxiliary boilers in Table 4-7 is consistent with the standard guarantee for ultra-low-NO_x burners, which is 9 ppmvd at 3% O₂. This corresponds to 0.011 lb/MMBtu. There are several boilers with BACT limits for NO_x in lb/hr calculated with 0.01 rather than 0.011 lb/MMBtu, but this is considered effectively the same limit at full load and is actually less stringent at part-load, since the limits expressed as 9 ppmvd at 3% O₂/0.011 lb/MMBtu apply throughout the load range. The Project auxiliary boiler meets this most stringent limit found for natural gas-fired auxiliary boilers at new large (> 100 MW) combustion turbine combined cycle projects.

Table 4-8. Summary of Auxiliary Boiler Top-Down BACT Analysis for NOx

Control Alternative	NOx Emissions			Economic Impacts				Energy Impacts (compared to baseline)	Environmental Impacts	
	ppmvd @ 3% O2	Tons per year (tpy)	Emissions Reduction Compared to Baseline (tpy)	Installed Capital Cost (differential over baseline)	Total Annualized Cost (differential over baseline)	Average Cost Effectiveness	Incremental Cost Effectiveness		Toxics Impacts (Yes/No)	Adverse Environmental Impacts (Yes/No)
SCR	3	0.95	8.51	\$414,750	\$162,668	\$19,115	\$69,786	Small	Yes	No
ULN	9	2.89	6.57	\$134,400	\$27,283	\$4,153	--	negligible	No	No
LN (baseline)	30	9.46	--	--	--	--	--			

SCR – Selective Catalytic Reduction

ULN – Ultra low-NOx burner

LN – Low NOx burner

See Appendix A, Calculation Sheets 8 and 9, for calculation of cost values.

4.2.3 PM/PM₁₀/PM_{2.5}

For PM/PM₁₀/PM_{2.5}, this evaluation does not identify and discuss each of the five individual steps of the “top-down” BACT process, since there are no post-combustion control technologies available for PM/PM₁₀/PM_{2.5}. The “top-down” procedure does require selection of BACT emission limits, which is addressed in the following paragraphs.

Table 4-7 presents the review of BACT precedents for auxiliary boilers. With respect to PM/PM₁₀/PM_{2.5}, for limits expressed in mass units (lb/MMBtu or lb/hr converted to lb/MMBtu at full load), only two of the auxiliary boilers listed in the Table 4-7 have PM/PM₁₀/PM_{2.5} limits that are more stringent than the Project auxiliary boiler limit of 0.005 lb/MMBtu. One of these boilers is at the Palmdale Hybrid Power facility, with a limit of 0.33 lb/hr, which corresponds to 0.003 lb/MMBtu at full load. However, this lb/hr limit could be met by reducing the boiler load, if the actual emissions exceed 0.003 lb/MMBtu. So at lower loads it is actually less stringent than the Project limit of 0.005 lb/MMBtu, which applies throughout the load range. The other boiler listed in the RBLC with a lower lb/MMBtu emission limit is at the Portland (OR) General Electric Carty Plant. This limit of 2.5 lb/MMcf of natural gas (which corresponds to 0.0025 lb/MMBtu) is considered unrealistically low for a guarantee for a boiler of this type. This is because of uncertainty and variability with available PM/PM₁₀/PM_{2.5} test methods, and the risk of artifact emissions resulting in a tested exceedance. All new gas-fired boilers, properly operated, are expected to have intrinsically low PM/PM₁₀/PM_{2.5} emissions. A limit of 0.005 lb/MMBtu is within the range of recent PSD BACT levels and is justified as PSD BACT.

Several of the boilers listed in Table 4-7 have PM/PM₁₀/PM_{2.5} PSD BACT limits expressed as the sulfur content of the natural gas. These values range from 0.1 grains/100 scf to 0.4 grains/100 scf. All of these values are lower than what USEPA defines as the maximum sulfur content of pipeline natural gas (0.5 grains/100 scf). The Applicant does not believe it is prudent to assume a natural gas sulfur content lower than EPA’s definition for pipeline natural gas. Therefore, these sulfur limits for PM/PM₁₀/PM_{2.5} PSD BACT limits are not appropriate.

4.2.4 H₂SO₄

For H₂SO₄, this evaluation does not identify and discuss each of the five individual steps of the “top-down” BACT process, since the only available control for H₂SO₄ is limiting the fuel sulfur content. Based on the selection of natural gas as the BACT fuel, this is the lowest sulfur content fuel suitable for the auxiliary boiler.

The BACT process for H₂SO₄ proceeds directly to the selection of BACT. Footprint has based the H₂SO₄ limit on 40% molar conversion of fuel sulfur to H₂SO₄. This is because Footprint has incorporated a CO oxidation catalyst to reduce CO emissions. One of the collateral impacts of this oxidation catalyst is an increase in H₂SO₄ emissions. With respect to H₂SO₄, none of the 6 of the projects in Table 4-7 with numeric H₂SO₄ limits have oxidation catalysts. Therefore, the proposed Project limit is less stringent than 5 of these 6 limits. The proposed Project limit of 0.0009 lb/MMBtu H₂SO₄ is justified as PSD BACT with the addition of a CO catalyst.

4.2.5 GHG

For GHG, this evaluation does not identify and discuss each of the five individual steps of the “top-down” BACT process, since there are no post-combustion controls suitable for GHG. The BACT process for GHG proceeds directly to the selection of BACT.

With respect to GHG, most of the auxiliary boilers listed in Table 4-7 with GHG limits for PSD BACT are expressed as a mass emission value, which is a project specific number reflecting the particular size and gas throughput limits of the specific project unit. For its proposed GHG limit for the Auxiliary Boiler, the Project has chosen a conservative value based on the USEPA Part 75 default emission factor (119 lb/MMBtu). Another unit listed in the RBLC has an 80% efficiency specified in addition to an annual mass limit. This is the only auxiliary boiler approved with this type of limit. The Project will install an auxiliary boiler with a nominal efficiency of 83.7%. The Applicant proposes a GHG PSD BACT limit expressed in the units of lb/MMBtu (119 lb/MMBtu) as most appropriate PSD BACT limit.

4.3 Emergency Diesel Generator

This section supplements the PSD BACT analysis for the emergency diesel generator to address public comments made on the draft permit documents. The Project is subject to PSD review for NO_x, PM/PM₁₀/PM_{2.5}, H₂SO₄, and GHG, and thus the emergency diesel generator is subject to PSD BACT for these pollutants.

The Project includes a 750 kW emergency diesel generator that will have ultra-low sulfur diesel (ULSD) as the only fuel of use. Table 4-9 presents the proposed BACT limits for the emergency diesel generator for pollutants subject to PSD review.

Table 4-9. Emergency Diesel Generator Proposed PSD BACT Limits

Pollutant	Emission Limitation (grams/kWhr)	Emission Limitation (grams/hphr)
NO _x	6.4	4.8
PM/PM ₁₀ /PM _{2.5}	0.20	0.15
H ₂ SO ₄	0.0009 lb/hr (0.00012 lb/MMBtu)	
GHG as CO ₂ e	162.85 lb/MMBtu	

The proposed PSD BACT limits for NO_x and PM/PM₁₀/PM_{2.5} are based on compliance with the EPA New Source Performance Standards (NSPS), 40 CFR 60 Subpart IIII. For a 750 kW engine, Subpart IIII requires what is referred to as a Tier 2 engine. For H₂SO₄, the PSD BACT limit is based on use of ultra-low sulfur diesel (ULSD) fuel, and conversion of 5% of the fuel sulfur on a molar basis to H₂SO₄. The GHG limit is based on EPA emission factors for ULSD.

In order to inform the PSD BACT process, Footprint has compiled all the PSD BACT determinations in the last five years for emergency generators at new large (> 100 MW) combustion turbine combined cycle projects. This compilation is based on the USEPA RBLC (RACT/BACT/LAER Clearinghouse). Several recent projects not included in RBLC have also been included in this compilation. Table 4-10 provides this compilation. Review of Table 4-10 indicates that only one emergency generator is fired with natural gas, and all the others are fired with ULSD. The gas-fired engine, at Avenal Power Center in CA, does have SCR to control NO_x. All other emergency generators in Table 4-10 do not have any post combustion controls for PSD pollutants. Table 4-10 will be referred to in the individual pollutant discussion below.

Table 4-10. Summary Of Recent PSD BACT Determinations for Emergency Generators at Large (>100MW) Gas Fired Combined-Cycle Generating Plants for NO_x, PM, H₂SO₄, GHG

Facility	Location	Permit Date	Emergency Generator Size ¹	Emission Limits ¹			
				NO _x	PM/PM10/PM2.5	H ₂ SO ₄	GHG
Carroll County Energy	Washington Twp., OH	11/5/2013	1112 kW	Subpart IIII		0.000132 grams/kWhr	433.96 tpy
Renaissance Power	Carson City, MI	11/1/2013	(2) – 1000 kW	Subpart IIII		--	1731.4 tpy (both units)
Langley Gulch Power	Payette, ID	08/14/2013	750 kW	Subpart IIII		--	--
Oregon Clean Energy	Oregon, OH	06/18/2013	2250 kW	Subpart IIII		0.000132 grams/kWhr	877 tpy (87)
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	1500 kW	Subpart IIII		--	Low carbon fuel and efficient operation
Hickory Run Energy LLC	New Beaver Twp., PA	04/23/2013	750 kW	6.0 grams/kWhr	0.25 grams/kWhr	--	80.5 tpy
Brunswick County Power	Freeman, VA	03/12/2013	2200 kW	Subpart IIII		ULSD	Low carbon fuel and efficient operation
Moxie Patriot LLC	Clinton Twp PA	01/31/2013	1472 hp	4.93 grams/hp-hr	0.02 grams/hp-hr	--	--
St. Joseph Energy Center	New Carlisle, IN	12/03/2012	(2) – 1006 hp	Subpart IIII		--	1186 tpy
Hess Newark Energy Center	Newark, NJ	11/01/2012	1500 kW	Subpart IIII		--	--
Moxie Liberty LLC	Asylum Twp, PA	10/10/2012		4.93 grams/hp-hr	0.02 grams/hp-hr	--	--
Cricket Valley	Dover, NY	09/27/12	4 Black Start EDGs 3000 kW each	Subpart IIII		--	--
ES Joslin Power	Calhoun, TX	09/12/2012	(2) -EDG	14.11 lb/hr/unit	0.44 lb/hr/unit	--	--
Pioneer Valley Energy Center (PVEC)	Westfield, MA	04/05/2012	2174 kW	Subpart IIII		--	--
Palmdale Hybrid Power	Palmdale, CA	10/18/2011	110	Subpart IIII		--	--

Facility	Location	Permit Date	Emergency Generator Size ¹	Emission Limits ¹			
				NOx	PM/PM10/PM2.5	H2SO4	GHG
Thomas C. Ferguson Power	Llano, TX	09/01/2011	1340 hp	16.52 lb/hr (5.5 grams/hp-hr)	0.55 lb/hr	--	15,314 lb/hr 30 day rolling average 765.7 tpy 365 day rolling average
Entergy Nine-mile Point Unit 6	Westwego, LA	08/16/2011	1250 hp	--	Subpart IIII	--	CO _{2e} 163.6 lb/MMBtu,
Avenal Power Center	Avenal, CA	05/27/2011	550 kW natural gas engine	SCR to 1 gram/hp-hr	0.34 gram/hp-hr	--	--
Dominion Warren County	Front Royal, VA	12/21/2010	2193 hp	Subpart IIII		--	--
Pondera/King Power Station	Houston, TX	08/05/2010	Size not given	26.61 lb/hr	1.88 lb/hr	--	--
Brockton Power	Brockton MA	07/20/2011 (MA Plan Approval)	3- 2000 kW each	5.45 gm/hp-hr	0.032 gm/hp-hr	--	--
Victorville 2 Hybrid	Victorville, CA	03/11/2010	2000 kW	Subpart IIII		--	--
Stark Power/Wolf Hollow	Granbury, TX	03/03/2010	750 hp	23.25 lb/hr (14 grams/hp-hr)	1.65 lb/hr (1.0 grams/hp-hr)	--	--
Panda Sherman Power	Grayson, TX	02/03/2010	Size not given	35.24 lb/hr	0.17 lb/hr	--	--
Pattillo Branch Power LLC	Savoy, TX	06/17/2009	Size not given	18.0 lb/hr	0.5 lb/hr	--	--

¹ Generators are diesel generators except where noted.

² Short term limits only for NOx, PM, and H2SO4. Limits obtained from agency permitting documents when not available in RBLIC.

4.3.1 Fuel Selection

Step 1: Identify Candidate Fuels

- Natural gas
- ULSD

Step 2: Eliminate Infeasible Technologies

Both these technologies are technically feasible, although use of natural gas is unusual for an emergency engine.

Step 3: Rank Control Technologies by Control Effectiveness

Natural gas engines can achieve lower emissions compared to ULSD.

Step 4: Evaluate Controls

Normally, for an emergency generator, it is very important to have the fuel supply directly available without the possibility of a natural gas supply interruption making it impossible to operate the emergency generator in an emergency. The purpose of the emergency generator is to be able to safely shut the plant down in the event of an electric power outage. So in order to maintain this important equipment protection function, ULSD, which can be stored in a small tank adjacent to the emergency generator, is the fuel of choice. Footprint is not aware of the specific circumstance for the emergency generator fuel selection at Avenal, but Footprint does not believe a natural gas fired generator for the Salem Project is a prudent choice.

Step 5: Select BACT

ULSD is proposed as the BACT fuel for the Project emergency generator.

4.3.2 NO_x

Step 1: Identify Candidate Control Technologies

- Selective Catalytic Reduction
- Low NO_x engine design in accordance with EPA NSPS, 40 CFR 60 Subpart IIII (Tier 2 engine for 750 kW unit)

Step 2: Eliminate Infeasible Technologies

Both these technologies are technically feasible, although application of SCR is unusual for an emergency engine.

Step 3: Rank Control Technologies by Control Effectiveness

SCR can normally achieve 90% remove of NO_x emissions, so it is more effective than the Tier 2 engine design which is based on low-NO_x engine design. However, for an emergency generator, if this unit is used just for short period of test and facility shutdown in an actual emergency, the ability of the SCR to control emissions will be significantly reduced since the engine/SCR takes time to warm up to achieve good NO_x control.

Step 4: Evaluate Controls

Since SCR is technically feasible, an economic analysis of the cost effectiveness for emission control was conducted. This economic analysis is presented in Table 4-11. The capital cost estimate for an SCR system is based on information provided by Milton Cat Power Systems. The other factors are from the OAQPS Cost Control Manual. The SCR has been conservatively assumed to control 90% of the potential NO_x emissions even though this is unlikely in this application. Table 4-11 indicates that the cost effectiveness of an SCR is over \$33,000 per ton of NO_x. This cost is excessive, even if the emergency generator runs the maximum allowable amount of 300 hours per year (unlikely) and 90% NO_x control of the full potential to emit is achieved.

There are no energy or environmental issues with a Tier 2 generator that would indicate selection of SCR as BACT, given the unfavorable SCR economics.

Step 5: Select BACT

With respect to the selection of a PSD BACT for NO_x for the emergency generator, Table 4-10 indicates that compliance with Subpart IIII is the most common limit. Several BACT determinations contain gram/kWhr or gram/hp-hr limits that approximate the Subpart IIII values but do not specifically reference Subpart IIII. Several Texas projects have lb/hr limits but do not provide the engine size to determine limits per unit of output.

Overall, with the elimination of SCR on economic grounds, the review of other RBLC precedents supports the selection of Subpart IIII compliance as BACT.

4.3.3 PM/PM₁₀/PM_{2.5}

Step 1: Identify Candidate Control Technologies

- Active Diesel Particulate Filter (DPF)
- Low PM engine design in accordance with EPA NSPS, 40 CFR 60 Subpart IIII (Tier 2 engine for 750 kW unit)

Step 2: Eliminate Infeasible Technologies

Both these technologies are technically feasible, although application of a DPF is unusual for an emergency engine.

Step 3: Rank Control Technologies by Control Effectiveness

An active DPF can achieve up to 85% particulate removal (CARB Level 3), so it is more effective than the Tier 2 engine design which is based on low-emission engine design.

Step 4: Evaluate Controls

Since a DPF is technically feasible, an economic analysis of the cost effectiveness for emission control was conducted. This economic analysis is presented in Table 4-12. The capital cost estimate for an active system is based on information provided by Milton Cat Power Systems. The other factors are from the OAQPS Cost Control Manual. Table 4-12 indicates that the cost effectiveness of an active DPF is over \$600,000 per ton of PM/PM₁₀/PM_{2.5}. This cost is excessive, even if the emergency generator runs the maximum allowable amount of 300 hours per year (unlikely).

**TABLE 4-11 750 KW EMERGENCY GENERATOR
ECONOMIC ANALYSIS - SELECTIVE CATALYTIC REDUCTION -**

BACT Assessment				
Control System Life:	10 years			
Interest Rate:	10.00%		Baseline NOx Emissions per 40 CFR 60 Subpart III: (tpy)	1.74
Economic Factors from MassDEP Form BWP-AQ-BACT			SCR Control Efficiency (%)	90%
Capital Recovery Factor (CRF)	0.163			
Equipment Cost (EC)	(Factor)		Capital Recovery	\$40,563
a. SCR Capital Cost Estimate (Per Milton Cat)		\$150,000	Direct Operating Costs	
b. Instrumentation (0.10A)		Included	a. Ammonia	\$2,256
c. Taxes and Freight (EC*0.05)		\$7,500	b. Operating Labor (OL):(0.5 hr/shift)(\$25.6/hr)	\$480
Total Equipment Cost (TEC)		\$157,500	c. Maintenance Labor (ML):(0.5 hr/shift)(\$25.6/hr)	\$480
Direct Installation Costs			d. Maintenance Materials = Maintenance Labor	\$480
a. Foundation (TEC*0.08)		\$12,600	Total Direct Operating Cost	\$960
b. Erection and Handling (TEC*0.14)		\$22,050	Catalyst Replacement is not included since the emergency generator will only operate a maximum of 300 hours in any year	
c. Electrical (TEC*0.04)		\$6,300		
d. Piping (TEC*0.02)		\$3,150	Indirect Operating Costs	
e. Insulation (TEC*0.01)		\$1,575	a. Overhead (60% of OL+ML)	\$576
f. Painting (TEC*0.01)		\$1,575	b. Property Tax: (TCC*0.01)	\$2,489
Total Direct Installation Cost		\$47,250	c. Insurance: (TCC*0.01)	\$2,489
Indirect Installation Costs			d. Administration: (TCC*0.02)	\$4,977
a. Engineering and Supervision (TEC*0.1)		\$15,750	Total Indirect Operating Cost	\$10,531
b. Construction/Field Expenses (TEC*0.05)		\$7,875		
c. Construction Fee (TEC*0.1)		\$15,750	Total Annual Cost	\$52,054
d. Start up (TEC*0.02)		\$3,150	NOx Reduction (tons/yr)	1.57
e. Performance Test (TEC*0.01)		\$1,575	Cost of Control (\$/ton - NOx)	\$33,230
Total Indirect Installation Cost		\$44,100		
Total Capital Cost (TCC)		\$248,850		

Note 1: Ammonia cost based on estimated as delivered cost for 19% aqueous ammonia of \$0.60 per pound of ammonia, and 1.2 lbs of NH3 injected per pound of NOx removed

**TABLE 4-12 750 KW EMERGENCY GENERATOR
ECONOMIC ANALYSIS - ACTIVE DIESEL PARTICULATE FILTER**

BACT Assessment			
Control System Life:	10 years		
Interest Rate:	10.00%	Baseline PM Emissions per 40 CFR 60 Subpart III (tpy)	0.06
Economic Factors from Mass DEP Form BWP-AQ-BACT		DPF Control Efficiency (%)	85%
Capital Recovery Factor (CRF)	0.163		
Equipment Cost (EC)	(Factor)	Capital Recovery	\$24,338
a. DPF Capital Cost Estimate (per Milton Cat)			
b. Instrumentation (0.10A)		Direct Operating Costs	
c. Taxes and Freight (EC*0.05)	\$4,500	a. Operating Labor (OL):(0.25 hr/shift)(\$25.6/hr)	\$240
		b. Maintenance Labor (ML):(0.25 hr/shift)(\$25.6/hr)	\$240
Total Equipment Cost (TEC)	\$94,500	c. Maintenance Materials = Maintenance Labor	\$240
		Total Direct Operating Cost	\$720
Direct Installation Costs			
a. Foundation (TEC*0.08)	\$7,560	DPF Replacement is not included since the emergency generator will only operate a maximum of 300 hours in any year	
b. Erection and Handling (TEC*0.14)	\$13,230		
c. Electrical (TEC*0.04)	\$3,780		
d. Piping (TEC*0.02)	\$1,890		
e. Insulation (TEC*0.01)	\$945		
f. Painting (TEC*0.01)	\$945		
Total Direct Installation Cost	\$28,350		
		Indirect Operating Costs	
Indirect Installation Costs		a. Overhead (60% of OL+ML)	\$288
a. Engineering and Supervision (TEC*0.1)	\$9,450	b. Property Tax: (TCC*0.01)	\$1,493
b. Construction/Field Expenses (TEC*0.05)	\$4,725	c. Insurance: (TCC*0.01)	\$1,493
c. Construction Fee (TEC*0.1)	\$9,450	d. Administration: (TCC*0.02)	\$2,986
d. Start up (TEC*0.02)	\$1,890	Total Indirect Operating Cost	\$6,260
e. Performance Test (TEC*0.01)	\$945		
Total Indirect Installation Cost	\$26,460		
Total Capital Cost (TCC)	\$149,310	Total Annual Cost	\$31,318
		PM Reduction (tons/yr)	0.05
		Cost of Control (\$/ton - PM)	\$614,080

There are no energy or environmental issues with a Tier 2 generator that would indicate selection of a DPF as BACT, given the unfavorable economics.

Step 5: Select BACT

With respect to the selection of a PSD BACT for PM/PM₁₀/PM_{2.5} for the emergency generator, Table 4-10 indicates that compliance with Subpart IIII is the most common limit. There are two BACT determinations for PA projects (Moxie projects) that both have very low PM/PM₁₀/PM_{2.5} limits of 0.02 gram/hp-hr. Footprint suspects that this limit is a mistaken entry for the Subpart IIII value of 0.2 grams/kWhr. Several Texas projects have lb/hr limits but do not provide the engine size to determine limits per unit of output. Brockton (MA) also has a very low PM limit, much lower than the Subpart IIII requirements. Footprint does not consider a PM limit less than the Subpart IIII requirements to be an appropriate BACT

Overall, with the elimination of a DPF on economic grounds, the review of other RBLC precedents supports the selection of Subpart IIII compliance as BACT.

4.3.4 H₂SO₄

For H₂SO₄, this evaluation does not identify and discuss each of the five individual steps of the “top-down” BACT process, since the only available control for H₂SO₄ is limiting the fuel sulfur content. Based on the selection of ULSD as the BACT fuel, this is the lowest sulfur content fuel suitable for the emergency generator.

The BACT process for H₂SO₄ proceeds directly to the selection of BACT. Footprint has based the H₂SO₄ limit on 5% molar conversion of fuel sulfur to H₂SO₄. Most of the emergency generators in Table 4-10 do not have an H₂SO₄ limit. The only numerical limits for H₂SO₄ identified for an emergency generator are those for the two recent Ohio PSD permits (Oregon and Carroll County). The limit in each case is 0.000132 grams/kWhr. Both these project are approved with ULSD as the emergency generator fuel. Conversion of the Footprint limit to grams/kWhr indicates that 5% molar conversion of the fuel sulfur to H₂SO₄ yields 0.0005 grams/kWhr, or about 4 times the Ohio limits. Review of the Ohio approvals indicates this factor is based on an EPA toxics emission factor which apparently allows for a much lower molar conversion of fuel sulfur to H₂SO₄. While this factor may be suitable for estimating actual emissions, Footprint believes this factor is not appropriate for setting an emission limit. Therefore, given that most agencies do not even regulate emergency generator H₂SO₄, Footprint believes the PSD BACT emission rate based on 5% molar conversion of fuel sulfur to H₂SO₄ is justified as BACT. This 5% molar conversion of fuel sulfur to H₂SO₄ is a reasonable upper limit permit limit assumption for fuel combustion sources that do not have an SCR or oxidation catalyst.

4.3.5 GHG

For GHG, this evaluation does not identify and discuss each of the five individual steps of the “top-down” BACT process, since there are no post-combustion controls suitable for GHG. The BACT process for GHG proceeds directly to the selection of BACT. Given that emergency generators operate so little, agencies have not required review of generator efficiency as part of GHG BACT.

With respect to GHG, most of the emergency generators listed on the RBLC with GHG limits for PSD BACT are expressed as a mass emission value, which is a project specific number reflecting the particular size and gas throughput limits of the specific project unit. Therefore, these GHG equipment-specific limits are not automatically transferrable as comparable limits for this Project. One unit listed in

Table 4-10 has a lb/MMBtu limit based on ULSD corresponding to 163.6 lb CO₂e/MMBtu. For its proposed GHG limit for the emergency generator, the Project has chosen a value based on the USEPA Part 75 default emission factors (162.85 lb/MMBtu), incorporating both CO₂, CH₄, and N₂O. The Applicant proposes a GHG PSD BACT limit expressed in the units of lb/MMBtu (162.85 lb/MMBtu) as most appropriate PSD BACT limit.

4.4 Emergency Fire Pump

This section supplements the PSD BACT analysis for the emergency diesel fire pump to address public comments made on the draft permit documents. The Project is subject to PSD review for NO_x, PM/PM₁₀/PM_{2.5}, H₂SO₄, and GHG, and thus the emergency diesel fire pump is subject to PSD BACT for these pollutants.

The Project includes a 371 hp emergency diesel fire pump that will have ultra-low sulfur diesel (ULSD) as the only fuel of use. Table 4-13 presents the proposed BACT limits for the emergency diesel fire pump for pollutants subject to PSD review.

Table 4-13. Emergency Diesel Fire Pump Proposed PSD BACT Limits

Pollutant	Emission Limitation (grams/kWhr)	Emission Limitation (grams/hphr)
NO _x	4.0	3.0
PM/PM ₁₀ /PM _{2.5}	0.20	0.15
H ₂ SO ₄	0.0003 lb/hr (0.00012 lb/MMBtu)	
GHG as CO ₂ e	162.85 lb/MMBtu	

The proposed PSD BACT limits for NO_x and PM/PM₁₀/PM_{2.5} are based on compliance with the EPA New Source Performance Standards (NSPS), 40 CFR 60 Subpart IIII. For a 371 hp fire pump engine, Subpart IIII requires what is referred to as a Tier 3 engine. For H₂SO₄, the PSD BACT limit is based on use of ultra-low sulfur diesel (ULSD) fuel, and conversion of 5% of the fuel sulfur on a molar basis to H₂SO₄. The GHG limit is based on EPA emission factors for ULSD.

In order to inform the PSD BACT process, Footprint has compiled all the PSD BACT determinations in the last five years for emergency fire pumps at new large (> 100 MW) combustion turbine combined cycle projects. This compilation is based on the USEPA RBLC (RACT/BACT/LAER Clearinghouse). Several recent projects not included in RBLC have also been included in this compilation. Table 4-14 provides this compilation. Review of Table 4-14 indicates that all emergency fire pumps are fired with ULSD. All emergency fire pumps in Table 4-14 do not have any post combustion controls for PSD pollutants. Table 4-14 will be referred to in the individual pollutant discussion below.

Table 4-14. Summary of Recent PSD BACT Determinations for Reciprocating Fire Pump Engines at Large (>100MW) Gas Fired Combined-Cycle Generating Plants for NO_x, PM, H₂SO₄, GHG

Facility	Location	Permit Date	Fire Pump Engine Size	Emission Limits ¹			
				NO _x	PM/PM10/PM2.5	H ₂ SO ₄	GHG
Carroll County Energy	Washington Twp., OH	11/5/2013	400 hp	Subpart IIII		0.000132 grams/kWhr	115.75 tpy
Oregon Clean Energy	Oregon, OH	06/18/2013	300 hp	Subpart IIII		0.000132 grams/kWhr	87 tpy
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	330 hp	Subpart IIII		--	Low carbon fuel and efficient operation
Hickory Run Energy LLC	New Beaver Twp., PA	04/23/2013	450 hp	1.9 gm/hp-hr	0.15 grams/hp-hr	0.00012 grams/hp-hr	33.8 tpy
Brunswick County Power	Freeman, VA	03/12/2013	305 hp	Subpart IIII		ULSD	Low carbon fuel and efficient operation
Moxie Patriot LLC	Clinton Twp PA	01/31/2013	460 hp	2.6 grams/hp-hr	0.09 grams/hp-hr	--	--
St. Joseph Energy Center	New Carlisle, IN	12/03/2012	(2) – 371 hp	Subpart IIII		--	172 tpy
Hess Newark Energy Center	Newark, NJ	11/01/2012	270 hp	Subpart IIII		--	--
Moxie Liberty LLC	Asylum Twp PA	10/10/2012	Size not given	2.6 grams/hp-hr	0.09 grams/hp-hr	--	--
Cricket Valley	Dover, NY	09/27/2012	460 hp	Subpart IIII		--	--
ES Joslin Power	Calhoun, TX	09/12/2012	Size not given	2.08 lb/hr	0.10 lb/hr	--	--
Pioneer Valley Energy Center (PVEC)	Westfield, MA	04/05/2012	270 hp	Subpart IIII		--	--
Palmdale Hybrid Power	Palmdale, CA	10/18/2011	182 hp	Subpart IIII		--	--
Thomas C. Ferguson Power	Llano, TX	09/01/2011	617 hp	3.81 lb/hr	0.20 lb/hr	--	7,027.8 lb/hr 30 day rolling average 351.4 tpy 365 day rolling average
Entergy Nine-mile Point Unit 6	Westwego, LA	08/16/2011	350 hp	--	Subpart IIII	--	CO ₂ e 163.6 lb/MMBtu,

Facility	Location	Permit Date	Fire Pump Engine Size	Emission Limits ¹			
				NOx	PM/PM10/PM2.5	H2SO4	GHG
Brockton Power	Brockton MA	07/20/2011 (MA Plan Approval)	100 hp	5.45 gm/hp-hr	0.032 gm/hp-hr	--	--
Avenal Power Center	Avenal, CA	05/27/2011	288 hp	3.4 grams/hp-hr	ULSD	--	--
Portland Gen. Electric Carty Plant	Morrow, OR	12/29/2010	265	Subpart IIII		--	--
Dominion Warren County	Front Royal, VA	12/21/2010	2,3 MMBtu/hr	Subpart IIII		--	--
Pondera/King Power Station	Houston, TX	08/05/2010	Size not given	1.54 lb/hr	0.55 lb/hr	--	--
Victorville 2 Hybrid	Victorville, CA	03/11/2010	182 hp	Subpart IIII		--	--
Panda Sherman Power	Grayson, TX	02/03/2010	Size not given	7.75 lb/hr	0.55 lb/hr	--	--
Pattillo Branch Power LLC	Savoy, TX	06/17/2009	Size not given	9.3 lb/hr	0.7 lb/hr	--	--

¹ Short term limits only for NOx, PM, and H2SO4. Limits obtained from agency permitting documents when not available in RBLC

4.4.1 Fuel Selection

Step 1: Identify Candidate Fuels

- Natural gas
- ULSD

Step 2: Eliminate Infeasible Technologies

Both these technologies are technically feasible, although use of natural gas would be unusual for an emergency fire pump engine.

Step 3: Rank Control Technologies by Control Effectiveness

Natural gas engines can achieve lower emissions compared to ULSD.

Step 4: Evaluate Controls

Normally, for an emergency fire pump, it is very important to have the fuel supply directly available without the possibility of a natural gas supply interruption making it impossible to operate the emergency fire pump in an emergency. The purpose of the emergency fire pump is to be able to pump water in the event of a fire. So in order to maintain this important emergency function, ULSD, which can be stored in a small tank adjacent to the emergency fire pump, is the fuel of choice.

Step 5: Select BACT

ULSD is proposed as the BACT fuel for the Project emergency fire pump.

4.4.2 NO_x

Step 1: Identify Candidate Control Technologies

- Selective Catalytic Reduction
- Low NO_x engine design in accordance with EPA NSPS, 40 CFR 60 Subpart III (Tier 3 engine for 371 hp fire pump unit)

Step 2: Eliminate Infeasible Technologies

Both these technologies are technically feasible, although application of SCR is unusual for an emergency fire pump.

Step 3: Rank Control Technologies by Control Effectiveness

SCR can normally achieve 90% remove of NO_x emissions, so it is more effective than the Tier 3 engine design which is based on low-NO_x engine design. However, for an emergency fire pump, if this unit is used just for short period of test and facility shutdown in an actual emergency, the ability of the SCR to control emissions will be significantly reduced since the engine/SCR takes time to warm up to achieve good NO_x control.

Step 4: Evaluate Controls

Since SCR is technically feasible, an economic analysis of the cost effectiveness for emission control was conducted. This economic analysis is presented in Table 4-15. The capital cost estimate for an SCR

system is based on information provided by Milton Cat Power Systems. The other factors are from the OAQPS Cost Control Manual. The SCR has been conservatively assumed to control 90% of the potential NO_x emissions even though this is unlikely in this application. Table 4-15 indicates that the cost effectiveness of an SCR is over \$90,000 per ton of NO_x. This cost is excessive, even if the emergency fire pump runs the maximum allowable amount of 300 hours per year (unlikely) and 90% NO_x control of the full potential to emit is achieved.

There are no energy or environmental issues with a Tier 3 fire pump that would indicate selection of SCR as BACT, given the unfavorable SCR economics.

Step 5: Select BACT

With respect to the selection of a PSD BACT for NO_x for the emergency fire pump, Table 4-14 indicates that compliance with Subpart IIII is the most common limit. Several BACT determinations contain gram/kWhr or gram/hp-hr limits that approximate the Subpart IIII values but do not specifically reference Subpart IIII. Several Texas projects have lb/hr limits but do not provide the engine size to determine limits per unit of output.

With the elimination of SCR on economic grounds, the review of other RBLC precedents supports the selection of Subpart IIII compliance as BACT.

4.4.3 PM/PM₁₀/PM_{2.5}

Step 1: Identify Candidate Control Technologies

- Active Diesel Particulate Filter (DPF)
- Low PM engine design in accordance with EPA NSPS, 40 CFR 60 Subpart IIII (Tier 3 engine for 371 hp unit)

Step 2: Eliminate Infeasible Technologies

Both these technologies are technically feasible, although application of a DPF is unusual for an emergency engine.

Step 3: Rank Control Technologies by Control Effectiveness

An active DPF can achieve up to 85% particulate removal (CARB Level 3), so it is more effective than the Tier 3 engine design which is based on low-emission engine design.

Step 4: Evaluate Controls

Since a DPF is technically feasible, an economic analysis of the cost effectiveness for emission control was conducted. This economic analysis is presented in Table 4-16. The capital cost estimate for an active system is based on information provided by Milton Cat Power Systems. The other factors are from the OAQPS Cost Control Manual. Table 4-16 indicates that the cost effectiveness of an active DPF is over \$1,000,000 per ton of PM/PM₁₀/PM_{2.5}. This cost is excessive, even if the emergency fire pump runs the maximum allowable amount of 300 hours per year (unlikely).

**TABLE 4-15 371 HP EMERGENCY FIRE PUMP
ECONOMIC ANALYSIS - SELECTIVE CATALYTIC REDUCTION -**

BACT Assessment:			
Control System Life:	10 years		
Interest Rate:	10.00%	Baseline NOx Emissions per 40 CFR 60 Subpart III (tpy):	0.37
Economic Factors from Mass DEP Form BWP-AQ-BACT		SCR Control Efficiency (%):	90%
Capital Recovery Factor (CRF):	0.163		
Equipment Cost (EC)	(Factor)	Capital Recovery	\$22,985
a. SCR Capital Cost Estimate (per Milton Cat)		Direct Operating Costs	
b. Instrumentation (0.10A)	Included	a. Ammonia	\$477
c. Taxes and Freight (EC*0.05)	\$4,250	b. Operating Labor (OL):(0.5 hr/shift)(\$25.6/hr)	\$480
Total Equipment Cost (TEC)	\$89,250	c. Maintenance Labor (ML):(0.5 hr/shift)(\$25.6/hr)	\$480
		d. Maintenance Materials = Maintenance Labor	\$480
Direct Installation Costs		Total Direct Operating Cost	\$1,440
a. Foundation (TEC*0.08)	\$7,140		
b. Erection and Handling (TEC*0.14)	\$12,495	Catalyst Replacement is not included since the emergency fire pump will only operate a maximum of 300 hours in any year	
c. Electrical (TEC*0.04)	\$3,570		
d. Piping (TEC*0.02)	\$1,785		
e. Insulation (TEC*0.01)	\$893		
f. Painting (TEC*0.01)	\$893		
Total Direct Installation Cost	\$26,775	Indirect Operating Costs	
Indirect Installation Costs		a. Overhead (60% of OL+ML)	\$576
a. Engineering and Supervision (TEC*0.1)	\$8,925.00	b. Property Tax: (TCC*0.01)	\$1,410
b. Construction/Field Expenses (TEC*0.05)	\$4,463	c. Insurance: (TCC*0.01)	\$1,410
c. Construction Fee (TEC*0.1)	\$8,925	d. Administration: (TCC*0.02)	\$2,820
d. Start up (TEC*0.02)	\$1,785	Total Indirect Operating Cost	\$6,216
e. Performance Test (TEC*0.01)	\$893		
Total Indirect Installation Cost	\$24,990	Total Annual Cost	\$30,641
Total Capital Cost (TCC)	\$141,015	NOx Reduction (tons/yr)	0.33
		Cost of Control (\$/ton - NOx)	\$92,502

Note 1: Ammonia cost based on estimated as delivered cost for 19% aqueous ammonia of \$0.60 per pound of ammonia, and 1.2 lbs of NH3 injected per pound of NOx removed

**TABLE 4-16 371 HP EMERGENCY DIESEL FIRE PUMP
ECONOMIC ANALYSIS - ACTIVE DIESEL PARTICULATE FILTER**

BACT Assessment				Baseline PM Emissions per 40 CFR 60 Subpart III (tpy)	
Control System Life:		10 years		0.018	
Interest Rate:		10.00%		85%	
Economic Factors from MassDEP Form BWP-AQ-BACT				DPF Control Efficiency (%)	
Capital Recovery Factor (CRF):		0.163			
Equipment Cost (EC) (Factor)			Capital Recovery \$12,169		
a.	DPF Capital Cost Estimate	\$45,000	Direct Operating Costs		
b.	Instrumentation (0.10A)	Included			
c.	Taxes and Freight (EC*0.05)	\$2,250	a	Operating Labor (OL):(0.25 hr/shift)(\$25.6/hr)	\$240
Total Equipment Cost (TEC) \$47,250			b	Maintenance Labor (ML):(0.25 hr/shift)(\$25.6/hr)	\$240
Direct Installation Costs			c.	Maintenance Materials = Maintenance Labor	\$240
a.	Foundation (TEC*0.08)	\$3,780	Total Direct Operating Cost \$720		
b.	Erection and Handling (TEC*0.14)	\$6,615	DPF Replacement is not included since the emergency fire pump will only operate a maximum of 300 hours in any year		
c.	Electrical (TEC*0.04)	\$1,890	Indirect Operating Costs		
d.	Piping (TEC*0.02)	\$945	a.	Overhead (60% of OL+ML)	\$288
e.	Insulation (TEC*0.01)	\$473	b.	Property Tax: (TCC*0.01)	\$747
f.	Painting (TEC*0.01)	\$473	c.	Insurance: (TCC*0.01)	\$747
Total Direct Installation Cost \$14,175			d.	Administration: (TCC*0.02)	\$1,493
Indirect Installation Costs			Total Indirect Operating Cost \$3,275		
a.	Engineering and Supervision (TEC*0.1)	\$4,725.00	Total Annual Cost \$16,164		
b.	Construction/Field Expenses (TEC*0.05)	\$2,363	PM Reduction (tons/yr) 0.02		
c.	Construction Fee (TEC*0.1)	\$4,725	Cost of Control (\$/ton - PM) \$1,033,319		
d.	Start up (TEC*0.02)	\$945			
e.	Performance Test (TEC*0.01)	\$473			
Total Indirect Installation Cost \$13,230					
Total Capital Cost (TCC) \$74,655					

There are no energy or environmental issues with a Tier 3 fire pump that would indicate selection of a DPF as BACT, given the unfavorable economics.

Step 5: Select BACT

With respect to the selection of a PSD BACT for PM/PM₁₀/PM_{2.5} for the emergency fire pump, Table 4-14 indicates that compliance with Subpart IIII is the most common limit. There are two BACT determinations for PA project (Moxie projects) that both have very low PM/PM₁₀/PM_{2.5} limits of 0.02 gram/hp-hr. Footprint suspects that this limit is a mistaken entry for the Subpart IIII value of 0.2 grams/kWhr. Several Texas projects have lb/hr limits but do not provide the engine size to determine limits per unit of output. Brockton (MA) also has a very low PM limit, much lower than the Subpart IIII requirements. Footprint does not consider a PM limit less than the Subpart IIII requirements to be an appropriate BACT

With the elimination of a DPF on economic grounds, the review of other RBLC precedents supports the selection of Subpart IIII compliance as BACT.

4.4.4 H₂SO₄

For H₂SO₄, this evaluation does not identify and discuss each of the five individual steps of the “top-down” BACT process, since the only available control for H₂SO₄ is limiting the fuel sulfur content. Based on the selection of ULSD as the BACT fuel, this is the lowest sulfur content fuel suitable for the emergency fire pump.

The BACT process for H₂SO₄ proceeds directly to the selection of BACT. Footprint has based the H₂SO₄ limit on 5% molar conversion of fuel sulfur to H₂SO₄. Most of the emergency fire pumps in Table 4-14 do not have an H₂SO₄ limit. The only numerical limits for H₂SO₄ identified for an emergency fire pump are those for the two recent Ohio PSD permits (Oregon and Carroll County), and the Hickory Run (PA) project. The limit for the Ohio cases is 0.000132 grams/kWhr, and for Hickory Run is 0.00012 grams/hp-hr (0.00016 grams/kW-hr). All these projects are approved with ULSD as the emergency fire pump fuel. Conversion of the Footprint limit to grams/kWhr indicates that 5% molar conversion of the fuel sulfur to H₂SO₄ yields 0.0005 grams/kWhr, or about 4 times the Ohio limits and three times the Hickory Run limit. Review of the Ohio approvals indicates this factor is based on an EPA toxics emission factor which apparently allows for a much lower molar conversion of fuel sulfur to H₂SO₄. While this factor may be suitable for actual emissions, Footprint believes this factor is not appropriate for setting an emission limit. Therefore, given that most agencies do not even regulate emergency fire pump H₂SO₄, Footprint believes the PSD BACT emission rate based on 5% molar conversion of fuel sulfur to H₂SO₄ is justified as BACT. As noted above for the emergency diesel generator, this 5% molar conversion of fuel sulfur to H₂SO₄ is a reasonable upper limit permit limit assumption for fuel combustion sources that do not have an SCR or oxidation catalyst.

4.4.5 GHG

For GHG, this evaluation does not identify and discuss each of the five individual steps of the “top-down” BACT process, since there are no post-combustion controls suitable for GHG. The BACT process for GHG proceeds directly to the selection of BACT. Given that emergency fire pumps operate so little, agencies have not required review of fire pump efficiency as part of GHG BACT.

With respect to GHG, most of the emergency pumps listed on the RBLC with GHG limits for PSD BACT are expressed as a mass emission value, which is a project specific number reflecting the particular size

and gas throughput limits of the specific project unit. Therefore, these GHG equipment-specific limits are not automatically transferrable as comparable limits for this Project. One unit listed in Table 4-14 has a lb/MMBtu limit based on ULSD corresponding to 163.6 lb CO₂e/MMBtu. For its proposed GHG limit for the emergency pumps, the Project has chosen a value based on the USEPA Part 75 default emission factors (162.85 lb/MMBtu), incorporating both CO₂, CH₄, and N₂O. The Applicant proposes a GHG PSD BACT limit expressed in the units of lb/MMBtu (162.85 lb/MMBtu) as most appropriate PSD BACT limit.

4.5 Auxiliary Cooling Tower

This section provides a PSD BACT analysis for the auxiliary mechanical draft cooling tower. The primary function for the auxiliary cooling tower is to provide necessary equipment cooling for the gas turbine itself, which is not possible to provide using the Air Cooled Condenser (ACC) used to condense steam discharged from steam turbines. The auxiliary mechanical draft cooling tower planned for use is a 3-cell commercial scale tower, with a total circulating water flow (all 3 cells) of 13,000 gallons per minute (gpm).

In general, mechanical draft cooling towers provide cooling of the circulating water by spraying (warm) circulating water over sheets of plastic material known as fill. This exposes the circulating water to ambient air being drawn in through the sides of the tower towards a fan generally located above the fill. A fraction of the circulating water evaporates into this air, warming it and causing it to become saturated with moisture. A small portion of the circulating water may be entrained into this air flow. These droplets of circulating water contain dissolved solids. Specially designed drift eliminators are typically located above the water sprays to remove most of these droplets and return them to the fill. But a small fraction of these droplets can escape into the fan discharge into the atmosphere. These droplets then evaporate, and the particulates in these droplets are a source of particulate (PM/PM₁₀/PM_{2.5}) emissions. PM/PM₁₀/PM_{2.5} are the only PSD pollutants emitted from the auxiliary cooling tower.

The Footprint auxiliary cooling tower is being designed to limit the drift rate to 0.001% of the circulating water flow (0.13 gpm). The design dissolved solids concentration for the circulating water is 1,500 milligrams per liter (mg/l) As documented in Appendix B of the December 2012 PSD Application, Calculation Sheet 6, the potential PM/PM₁₀ emissions from the auxiliary cooling tower are 0.43 tpy, and the potential PM_{2.5} emissions are 0.17 tpy.

Step 1: Identify Candidate Technologies

Particulate control technologies identified for cooling towers at new large > 100 MW combined cycle turbines are as follows:

- Air-Cooled Condensers (ACCs): This eliminates the use of circulating water for cooling and thus eliminates drift for large towers used for steam turbine condenser cooling
- High efficiency cooling tower drift eliminators.
- Reduction in the dissolved solids concentration in circulating water.

Step 2: Eliminate Infeasible Technologies

ACCs are technically feasible for steam turbine condenser cooling large combined cycle units. However, use of an ACC is not technically feasible for the auxiliary equipment cooling required for a GE Frame

7FA.05 combustion turbines since ACCs cannot achieve the degree of cooling performance required. High efficiency cooling tower drift eliminators are also technically feasible for mechanical draft cooling towers. The total dissolved solids concentration (TDS) in circulating water is a function of the makeup water TDS, which depends on the makeup water source, and the TDS at which the tower is operated. Removing TDS from the makeup water is considered technically infeasible for a small auxiliary mechanical draft cooling tower. However, the TDS in the circulating water can be decreased by increasing the amount of “blowdown” from the tower. Blowdown is a stream of wastewater continuously discharged from the tower to remove TDS from the circulating water. Increasing blowdown reduces the TDS and is technically feasible.

Step 3: Rank Control Technologies by Control Effectiveness

The ranking of the technically feasible technologies is as follows:

1. High efficiency cooling tower drift eliminators: Generally recognized to be capable of achieving a drift rate of 0.0005% of circulating water flow for large cooling tower used for power plant steam turbine condenser cooling. However, for small commercial mechanical draft cooling towers being used in this application, the standard design is for 0.001% drift.
2. Reduce the TDS in circulating water: Mechanical draft cooling towers are operated with circulating water TDS as low as 1000 milligrams/liter (mg/l).

Step 4: Evaluate Controls

Footprint has compiled all the PSD BACT determinations in the last five years for mechanical draft cooling towers at new large (> 100 MW) combustion turbine combined cycle projects. This compilation is based on the USEPA RBLC (RACT/BACT/LAER Clearinghouse). Several recent projects not included in RBLC have also been included in this compilation. Table 4-17 provides this compilation.

Review of Table 4-17 indicates that the available cooling tower BACT determinations are almost exclusively for large towers used for steam turbine condenser cooling. These towers are commonly specified for 0.0005% drift. Texas project determinations typically do not have the size of the tower indicated, and only have lb/hr emissions indicated which does not provide a meaningful comparison.

The smallest tower identified with a PM PSD BACT determination is the 12,000 gpm chiller tower at the Entergy Ninemile Point project in Louisiana. This tower in fact has drift specified at 0.001%, which agrees with our finding that small towers are designed for 0.001% drift. Therefore, it is concluded that 0.001% drift is justified as BACT for the small auxiliary mechanical draft cooling tower for Footprint. All towers identified with drift limits of 0.0005% are significantly larger than the Footprint auxiliary tower.

With respect to the circulating water total dissolved solids (TDS) concentration, for projects where this value is identified, these values range from 1000 to 6200 mg/l. Only two projects have design values < Footprint’s 1500 mg/l. A collateral environmental impact of increasing the blowdown to decrease TDS is increasing consumption of water. Footprint has selected 1500 mg/l as a reasonable TDS value balance to drift emissions and water conservation.

Step 5: Select BACT

The Footprint Project will meet 0.001% drift and limit the potential PM/PM₁₀ emissions from the auxiliary cooling tower to 0.43 tpy, and the potential PM_{2.5} emissions to 0.17 tpy. These values are justified as BACT.

Table 4-17. Summary of Recent Cooling Tower Particulate BACT Determinations for Large (>100MW) Gas Fired Combined-Cycle Generating Plants

Facility	Location	Permit Date	Cooling Tower Description (total circulating water flow rate in gallons per minute unless otherwise specified)	BACT ¹ PM/PM ₁₀ /PM _{2.5}
Renaissance Power	Carson City, MI	11/1/2013	10 cell tower	0.0005% drift
Langley Gulch Power	Payette, ID	08/14/2013	76,151 gpm	Drift Eliminators (not limit specified); 5000 mg/l
Oregon Clean Energy	Oregon, OH	06/18/2013	322,000 gpm	0.0005% drift; 2030.5 mg/l
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	187,400 gpm	0.0005% drift; 5000 mg/l
Brunswick County Power	Freeman, VA	03/12/2013	46,000 gpm (towers for turbine inlet air chillers)	0.0005% drift; 1000 mg/l
St. Joseph Energy Center	New Carlisle, IN	12/03/2012	2 towers at 170,000 gpm each	0.0005% drift
Hess Newark Energy	Newark, NJ	11/01/2012	220,870 gpm	0.0005% drift; 4150 mg/l
Channel Energy Center, LLC	Houston, TX	10/15/2012	Size not specified	1.33 lb/hr PM ₁₀
Pioneer Valley Energy Center (PVEC)	Westfield, MA	04/05/2012	Full wet cooling for 431 MW combined cycle facility – circulating flow not given	0.0005% drift
Deer Park Energy Center LLC	Deer Park, TX	09/26/2012	Cooling tower size not specified	PM –3.13 lb/hr PM ₁₀ /PM _{2.5} 1.75lb/hr
Entergy Ninemile Point Unit 6	Westwego, LA	08/16/2011	Chiller cooling tower 12,000 gpm Unit 6 cooling tower 115,847 gpm	Chiller cooling tower 0.001% drift Unit 6 cooling tower 0.0005% drift
Brockton Power	Brockton MA	7/20/2011	92,500 gpm	0.0005% drift; 3235 mg/l
Portland Gen. Electric Carty Plant	Morrow, OR	12/29/2010	Cooling tower circulating water flow rate 85,000 gpm	0.0005% drift; 1200 mg/l
Pondera/King Power Station	Houston, TX	08/05/2010	2 towers - size not specified	1.28 lb/hr/tower
Victorville 2 Hybrid	Victorville, CA	03/11/2010	130,000 gpm	0.0005% drift; 5000 mg/l
Stark Power/Wolf Hollow	Granbury, TX	03/03/2010	Cooling tower size not specified	0.0005% drift
Russell Energy Center	Hayward, CA	02/03/2010	141,352 gpm	0.0005% drift; 6200 mg/l
Panda Sherman Power	Grayson, TX	02/03/2010	Cooling tower sizes not specified	Main tower 4.68 lb/hr PM, inlet air chiller tower 0.27 lb/hr PM Both 0.0005% drift
Lamar Power Partners II LLC	Paris, TX	06/22/2009	Cooling tower size not specified	2.4 lb/hr PM ₁₀
Pattillo Branch Power LLC	Savoy, TX	06/17/2009	4 towers - size not specified	1.0 lb/hr/tower PM 0.3 lb/hr/tower PM ₁₀

¹Mass emissions (lb/hr) are only specified if comparable units across projects (% drift, total dissolved solids) are not provided.

Appendix A

Updates to Footprint Air Emissions Calculations

Updated GE performance data is provided as Attachment A-1 (3 sheets). These sheets update the performance data previously provided.

Items that have changed subsequent to the public review drafts issued by MassDEP are highlighted in yellow on all the sheets that are updates of prior sheets.

Calculation Sheet 1 presents the potential to emit (PTE) calculations for one turbine. Two operating cases are used to calculate potential emissions (PTE) are 100% load at 50 °F for baseload operation (8,040 hours/year) and 100% load at 90 °F with the duct burners and evaporative coolers on (720 hours per year). GE Case 7 is 100% load at 50 °F, with a heat input of 2,130 MMBtu/hr. GE Case 12 is 100% load at 90 °F with the duct burners and evaporative coolers on with a heat input of 2,449 MMBtu/hr. The PTE values are based on the direct calculation with the exact lb/MMBtu values shown on Sheet 1.

For CO, Sheet 1 shows the PTE based on 8,760 hours of operation, but the worst case PTE is based on separate calculations using startup and shutdown (SUSD) emissions and an assumed operating scenario. These calculations are provided on Sheet 2 for GE and reflect a higher PTE for CO compared to those in Sheet 1. Therefore, the maximum SUSD scenario value for CO PTE is used. Calculation Sheet 1 shows the revised emissions for CO for both the turbine (based on a maximum rate of 8.0 lb/hr/turbine) and the auxiliary boiler with the CO catalyst. The auxiliary boiler CO emission rate with the oxidation catalyst is 10% of the prior rate (0.035 lb/MMBtu)(0.10) = 0.0035 lb/MMBtu.

Calculation Sheet 3 in the December 21, 2012 application had been for Siemens SUSD and is now dropped. Calculation Sheets 4, 5, and 6 presented emission calculations for the emergency generator, emergency diesel fire pump, and auxiliary cooling tower respectively. These have not changed and are not repeated here.

Calculation Sheet 7 presents the updated overall summary of potential-to-emit (PTE) for the facility.

Calculation Sheets 8 and 9 are new, and are the NO_x BACT cost spreadsheets for the auxiliary boiler, supporting the values in Table 4-8.

Attachment A-1 (Sheet 1 of 3)

GE Energy 107F Series 5 Rapid Response Combined Cycle Plant - Emissions Data - Natural Gas

GE Energy Performance Data - Site Conditions

Operating Point		1	2	3	4	5	6	7	8	9	10	11	12	13
Case Description		Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	50% DB firing	100% DB firing	Unfired
Ambient Temperature	°F	0	0	0	20	20	20	50	50	50	90	90	90	90
Ambient Pressure	psia	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7
Ambient Relative Humidity	%	60	60	60	60	60	60	60	60	60	60	60	60	60

GE Energy Performance Data - Plant Status

HRSG Duct Burner (On/Off)		Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Fired	Fired	Unfired
Evaporative Cooler state (On/Off)		Off	Off	Off	Off	Off	Off	Off	Off	Off	On	On	On	Off
Gas Turbine Load	%	BASE	75%	50%	BASE	75%	46%	BASE	75%	46%	BASE	PEAK	PEAK	BASE
Gas Turbines Operating		1	1	1	1	1	1	1	1	1	1	1	1	1

GE Energy Performance Data - Fuel Data

GT Heat Consumption	MMBtu/hr	2300	1850	1460	2250	1790	1360	2130	1700	1310	2040	2082	2082	1980
Duct Burner Heat Consumption	MMBtu/hr	0	0	0	0	0	0	0	0	0	0	183	367	0
Total (GT + DB)	MMBtu/hr	2300	1850	1460	2250	1790	1360	2130	1700	1310	2040	2265	2449	1980

GE Energy Performance Data - HRSG Exit Exhaust Gas Emissions

NOx	ppmvdc	2	2	2	2	2	2	2	2	2	2	2	2	2
CO	ppmvdc	2	2	2	2	2	2	2	2	2	2	2	2	2
VOC	ppmvdc	1	1	1	1	1	1	1	1	1	1	2	2	1
NH3	ppmvdc	2	2	2	2	2	2	2	2	2	2	2	2	2

NOx	lb/MMBtu	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074
CO	lb/MMBtu	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045
VOC	lb/MMBtu	0.0013	0.0013	0.0013	0.0013	0.0013	0.0013	0.0013	0.0013	0.0013	0.0013	0.0022	0.0022	0.0013
NH3	lb/MMBtu	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027
Particulates - Filterable + Condensable, Including Sulfates	lb/MMBtu	0.0038	0.0048	0.0060	0.0039	0.0049	0.0065	0.0041	0.0052	0.0067	0.0043	0.0057	0.0053	0.0044

NOx	lb/hr	17.0	13.7	10.8	16.7	13.2	10.1	15.8	12.6	9.7	15.1	16.8	18.1	14.7
CO	lb/hr	8.0	8.0	6.6	8.0	8.0	6.1	8.0	7.7	5.9	8.0	8.0	8.0	8.0
VOC	lb/hr	3.0	2.4	1.9	2.9	2.3	1.8	2.8	2.2	1.7	2.7	5.0	5.4	2.6
NH3	lb/hr	6.2	5.0	3.9	6.1	4.8	3.7	5.8	4.6	3.5	5.5	6.1	6.6	5.3
Particulates - Filterable + Condensable, Including Sulfates	lb/hr	8.8	8.8	8.8	8.8	8.8	8.8	8.8	8.8	8.8	8.8	13.0	13.0	8.8

ppmvdc is parts per million by volume, dry basis, corrected to 15% O2
MMBtu is on a Higher Heating Value (HHV) basis

Attachment A-1 (Sheet 2 of 3)

GE Energy 107F Series 5 Rapid Response Combined Cycle Plant - Emission Data - Natural Gas

GE Energy Performance Data - Site Conditions

Operating Point		14	15	16	17	18	19	20	21	22	23	24	25
Case Description		50% DB firing	100% DB firing	Unfired	Unfired	Unfired	50% DB firing	100% DB firing	Unfired	50% DB firing	100% DB firing	Unfired	Unfired
Ambient Temperature	°F	90	90	90	90	105	105	105	105	105	105	105	105
Ambient Pressure	psia	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7
Ambient Relative Humidity	%	60	60	60	60	50	50	50	50	50	50	50	50

GE Energy Performance Data - Plant Status

HRSO Duct Burner (On/Off)		Fired	Fired	Unfired	Unfired	Unfired	Fired	Fired	Unfired	Fired	Fired	Unfired	Unfired
Evaporative Cooler state (On/Off)		Off	Off	Off	Off	On	On	On	Off	Off	Off	Off	Off
Gas Turbine Load	%	PEAK	PEAK	75%	47%	BASE	PEAK	PEAK	BASE	PEAK	PEAK	75%	49%
Gas Turbines Operating		1	1	1	1	1	1	1	1	1	1	1	1

GE Energy Performance Data - Fuel Data

GT Heat Consumption	MMBtu/hr	2017	2017	1590	1260	1990	2005	2005	1880	1928	1928	1520	1240
Duct Burner Heat Consumption	MMBtu/hr	183	377	0	0	0	183	377	0	183	377	0	0
Total Heat Consumption (GT + DB)	MMBtu/hr	2201	2394	1590	1260	1990	2188	2382	1880	2112	2305	1520	1240

GE Energy Performance Data - HRSO Exit Exhaust Gas Emissions

NOx	ppmvdc	2	2	2	2	2	2	2	2	2	2	2	2
CO	ppmvdc	2	2	2	2	2	2	2	2	2	2	2	2
VOC	ppmvdc	1.7	1.7	1	1	1	1.7	1.7	1	1.7	1.7	1	1
NH3	ppmvdc	2	2	2	2	2	2	2	2	2	2	2	2

NOx	lb/MMBtu	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074
CO	lb/MMBtu	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045	0.0045
VOC	lb/MMBtu	0.0022	0.0022	0.0013	0.0013	0.0013	0.0022	0.0022	0.0013	0.0022	0.0022	0.0013	0.0013
NH3	lb/MMBtu	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027
Particulates - Filterable + Condensable, Including Sulfates	lb/MMBtu	0.0059	0.0054	0.0055	0.0070	0.0044	0.0059	0.0055	0.0047	0.0062	0.0056	0.0058	0.0071

NOx	lb/hr	16.3	17.7	11.8	9.3	14.7	16.2	17.6	13.9	15.6	17.1	11.2	9.2
CO	lb/hr	8.0	8.0	7.2	5.7	8.0	8.0	8.0	8.0	8.0	8.0	6.8	5.6
VOC	lb/hr	4.8	5.3	2.1	1.6	2.6	4.8	5.2	2.4	4.6	5.1	2.0	1.6
NH3	lb/hr	5.9	6.5	4.3	3.4	5.4	5.9	6.4	5.1	5.7	6.2	4.1	3.3
Particulates - Filterable + Condensable, Including Sulfates	lb/hr	13.0	13.0	8.8	8.8	8.8	13.0	13.0	8.8	13.0	13.0	8.8	8.8

ppmvdc is parts per million by volume, dry basis, corrected to 15% O2
MMBtu is on a Higher Heating Value (HHV) basis

Attachment A-1 (Sheet 3 of 3)

GE Energy 107FA.05 Rapid Response Combined Cycle Plant

Manufacturer's Emissions Data - Natural Gas - Startup and Shutdown Conditions - Single Unit Basis

	NOx (lb)	CO (lb)	VOC (lb)	PM10 (lb)	Duration (min)
Cold Start (GT Fire to HRSG Stack Emissions Compliance with Base Load Hold)	89	285	23	7.3	45
Warm Start (GT Fire to HRSG Stack Emissions Compliance with Base Load Hold)	54	129	13	5.0	32
Hot Start (GT Fire to HRSG Stack Emissions Compliance with Base Load Hold)	28	121	12	2.6	18
Shutdown (HRSG Stack EC to GT Flame Off)	10	151	29	5.8	27

Calculation Sheet 1
Annual Potential Emissions for Combustion Turbines and Auxiliary Boiler

	One Combustion Turbine at 100% Load			Auxiliary Boiler	
	50 deg F	90 deg F	Annual	Gas	Annual
	No DF	DF, EC	tpy	lb/MMBtu	tpy
Hours per Year	8040	720		6570 (FLE)	6570 (FLE)
MMBtu/hr	2130	2449		80	
NOx (lb/MMBtu)	0.0074	0.0074	69.9	0.011	2.9
CO	8.0 lb/hr		35.0	0.0035	0.9
VOC (lb/MMBtu)	0.0013	0.0022	13.1	0.005	1.3
SO2 (lb/MMBtu)	0.0015	0.0015	14.2	0.0015	0.4
PM/PM-10/PM-2.5	8.8 lb/hr	13.0 lb/hr	40.1	0.005	1.3
NH3 (lb/MMBtu)	0.0027	0.0027	25.5	--	--
H2SO4 (lb/MMBtu)	0.001	0.001	9.4	0.0009	0.24
Lead (lb/MMBtu)	--	--	--	4.90E-07	0.00013
Formaldehyde (lb/MMBtu)	0.00035	0.00035	3.3	7.40E-05	0.019
Total HAP (lb/MMBtu)	0.000667	0.000667	6.3	1.90E-03	0.5
CO2 (lb/MMBtu)	118.9	118.9	1,122,920	118.9	31,247
CO2e (lb/MMBtu)	119.0	119.0	1,124,003	119.0	31,277
Notes:					
1. DF = Duct Firing					
2. EC = Evaporative Coolers					
3. FLE = Full Load Equivalent					
4. Annual potential emissions per turbine for all pollutants except CO and PM are based on $[(2130 \text{ MMBtu/hr})(\text{lb/MMBtu no DF})(8040 \text{ hrs}) + (2449 \text{ MMBtu/hr})(\text{lb/MMBtu DF})(720 \text{ hrs})] / 2000 \text{ lb/ton}$					
5. Annual potential emissions shown here per turbine for CO are based on 8 lb/hr for 8760 hours. However, the worst case PTE for CO includes the startup/shutdown scenario as shown in Calculation Sheet 2					
6. Annual potential emissions per turbine for PM/PM-10/PM-2.5 are based on $[(8.8 \text{ lb/hr})(8040 \text{ hrs}) + (13.0 \text{ lb/hr})(720 \text{ hrs})] / 2000 \text{ lb/ton}$					
7. H2SO4 emissions for the aux boiler are based on 40% molar conversion of fuel sulfur to H2SO4 Correcting for molecular weight, the H2SO4 emission rate is: $(0.0015 \text{ lb SO}_2/\text{MMBtu})(0.4)(98 \text{ lb/mole H}_2\text{SO}_4)/(64 \text{ lb/mole SO}_2) = 0.0009 \text{ lb/MMBtu}$					
8. Annual potential emissions for the aux boiler are based on: $(80 \text{ MMBtu/hr})(\text{lb/MMBtu})(6570 \text{ hours FLE}) / (2000 \text{ lb/ton})$					

Calculation Sheet 2
GE Emissions for CO and VOC Including Startup Shutdown Scenario

Emissions for Normal Load Cases			
	MMBtu/hr	CO (lb/hr)	VOC (lb/hr)
Spring/Fall Normal Load Case 7 (50 deg)	2130	8.0	2.8
Summer Case 13 except for 720 hours	1980	8.0	2.6
Summer Case 12 for 720 hours (90 deg)	2449	8.0	5.4
Winter Case 4 (20 deg)	2250	8.0	2.9

	ASSUMED OPERATING SCENARIOS					GE STARTUP/SHUTDOWN EMISSIONS									Normal Load Cases Emissions for Each Season						
	Assumed Operating Profile Normal Loads					starts/wk			starts/yr			CO				VOC					
	days/ week	hrs/ day	hrs/ week	Weeks/ yr	hrs/yr	cold	warm	hot	cold	warm	hot	cold	warm	hot		cold	warm	hot			
	<i>Combined startup/shutdown pounds of emissions per single event</i>					436	280	272	52	42	41										
						Annual SUSD emissions for each category and season (lbs)															
Spring/Fall	5	12	60	20	1200	0.25	4.75	0	5	95	0	2180	26600	0	260	3990	0	Case 7	9600	3323	
Summer	7	24	168	2	336	0	2	0	0	4	0	0	1120	0	0	168	0				
	5	16	80	8	640	0	5	0	0	40	0	0	11200	0	0	1680	0				
	5	12	60	2	120	0	5	0	0	10	0	0	2800	0	0	420	0	Case 13	3008	968	
Winter																	Case 12	5760	3879		
	7	24	168	2	336	0	1	0	0	2	0	0	560	0	0	84	0				
	5	16	80	8	640	0.25	4.75	0	2	38	0	872	10640	0	104	1596	0	Case 4	7808	2855	
TOTAL RUN HRS																					
Planned outage	7	24	168	4	672						6	2616	0	0	312	0	0				
Not Dispatched (includes time in SUSD)																					
Unplanned FO	4.1%											4				1088				164	
ANNUAL HRS																					
Total Tons in Each Category																					
																	13.1	5.5			
																	CO	VOC			
																	Total Emissions per unit	42.9	9.9		

Note: The startup/shutdown cycling scenario is no longer controlling for annual VOC emissions.

Calculation Sheet 7
Summary of Facility Potential to Emit (PTE) in tons per year (tpy)

Pollutant	Annual emissions, tons/year						Facility Totals
	CT Unit 1 (GT + DB)	CT Unit 2 (GT + DB)	Aux Boiler	Emergency Generator	Fire Pump	Aux Cooling Tower	
NO _x	69.9	69.9	2.9	1.7	0.4	0	144.8
CO	42.9	42.9	0.9	1.0	0.3	0	88.0
VOC	13.1	13.1	1.3	0.35	0.12	0	28.0
SO ₂	14.2	14.2	0.4	0.0017	0.0006	0	28.8
PM ₁₀	40.1	40.1	1.3	0.1	0.0	0.4	82.0
PM _{2.5}	40.1	40.1	1.3	0.1	0.0	0.2	81.8
NH ₃	25.5	25.5	0	0	0	0	51.0
H ₂ SO ₄ mist	9.4	9.4	0.24	1.33E-04	4.84E-05	0	19.0
Lead	0	0	0.00013	8.54E-07	3.10E-07	0	0.00013
Formaldehyde	3.3	3.3	0.019	8.76E-05	4.76E-04	0	6.6
Total HAP	6.3	6.3	0.5	1.76E-03	1.57E-03	0	13.1
CO ₂	1,122,920	1,122,920	31247	180	66	0	2,277,333
CO ₂ e	1,124,003	1,124,003	31277	181	66	0	2,279,530

Calculation Sheet 8

80 MMBtu/hr Auxiliary Boiler ECONOMIC ANALYSIS - SELECTIVE CATALYTIC REDUCTION

BACT Assessment:			
Control System Life:	10 years		
Interest Rate:	10.00%	Baseline Emissions at 30 ppmvdc corrected to 3% O ₂ (tpy)	9.46
Economic Factors from Mass DEP Form BWP-AQ-BACT		SCR Emissions at 3 ppmvdc corrected to 3% O ₂ (tpy)	0.95
Capital Recovery Factor (CRF):	0.163		
Equipment Cost (EC)	(Factor)	Capital Recovery	\$67,604
a. SCR Capital Cost Estimate (Cleaver Brooks)	\$250,000	Direct Operating Costs	
b. Taxes and Freight (EC*0.05)	\$12,500	a. Ammonia	\$12,261
Total Equipment Cost (TEC)	\$262,500	b. Operating Labor (OL):(0.5 hr/shift)(\$25.6/hr)	\$10,512
Direct Installation Costs		c. Maintenance Labor (ML):(0.5 hr/shift)(\$25.6/hr)	\$10,512
a. Foundation (TEC*0.08)	\$21,000	d. Maintenance Material = Maintenance Labor	\$10,512
b. Erection and Handling (TEC*0.14)	\$36,750	Total Direct Operating Cost	\$43,797
c. Electrical (TEC*0.04)	\$10,500	Catalyst Replacement	
d. Piping (TEC*0.02)	\$5,250	a. 33% of TEC required at year 3.33 and year 6.67, plus	
e. Insulation (TEC*0.01)	\$2,625	erection and indirect costs (0.25 of replacement)	
f. Painting (TEC*0.01)	\$2,625	b. 10-year annualized cost for catalyst replacement	\$22,062
Total Direct Installation Cost	\$78,750	Indirect Operating Costs	
Indirect Installation Costs		a. Overhead (60% of OL+ML)	\$12,614
a. Engineering and Supervision (TEC*0.1)	\$26,250	b. Property Tax: (TCC*0.01)	\$4,148
b. Construction/Field Expenses (TEC*0.05)	\$13,125	c. Insurance: (TCC*0.01)	\$4,148
c. Construction Fee (TEC*0.1)	\$26,250	d. Administration: (TCC*0.02)	\$8,295
d. Start up (TEC*0.02)	\$5,250	Total Indirect Operating Cost	\$29,205
e. Performance Test (TEC*0.01)	\$2,625		
Total Indirect Installation Cost	\$73,500	Total Annual Cost	\$162,668
Total Capital Cost (TCC)	\$414,750	NOx Reduction (tons/yr)	8.51
		Cost of Control (\$/ton - NOx)	\$19,115

Note 1: Ammonia cost based on estimated as delivered cost for 19% aqueous ammonia of \$0.60 per pound of ammonia, and 1.2 lbs of NH₃ injected per pound of NO_x removed

Calculation Sheet 9

80 MMBtu/hr Auxiliary Boiler ECONOMIC ANALYSIS - ULTRA LOW NOx (ULN) BURNER COMPARED TO STANDARD LOW NOx BURNER			
BACT Assessment			
Control System Life:	10 years		
Interest Rate:	10.00%	Baseline Emissions: at 30 ppmvdc corrected to 3% O2 (tpy)	9.46
Economic Factors from MassDEP Form BWP-AQ-BACT		Controlled Emissions: at 9 ppmvdc corrected to 3% O2 (tpy)	2.89
Capital Recovery Factor (CRF):	0.163		
Equipment Cost (EC)	(Factor)	Capital Recovery	\$21,907
a. Capital Cost Estimate (Differential Cost of ULN compared to standard low NOx burner)	\$100,000		
(per Cleaver Brooks)		Direct Operating Costs	
b. Taxes and Freight (EC*0.05)	\$5,000	Direct Operating Costs are assumed to be the same for ULN compared to standard low-NOx burner	
Total Equipment Cost (TEC)	\$105,000		
Direct Installation Costs			
Direct Installation Costs are assumed to be the same for ULN compared to standard low-NOx burner		Indirect Operating Costs (based on differential cost)	
Indirect Installation Costs (based on differential cost)		a. Overhead (60% of OL+ML)	\$0
a. Engineering and Supervision (TEC*0.1)	\$10,500	b. Property Tax: (TCC*0.01)	\$1,344
b. Construction/Field Expenses (TEC*0.05)	\$5,250	c. Insurance: (TCC*0.01)	\$1,344
c. Construction Fee (TEC*0.1)	\$10,500	d. Administration: (TCC*0.02)	\$2,688
d. Start up (TEC*0.02)	\$2,100	Total Indirect Operating Cost	\$5,376
e. Performance Test (TEC*0.01)	\$1,050		
Total Indirect Installation Cost	\$29,400		
Total Capital Cost Differential for ULN Compared to Standard Low NOx Burner	\$134,400	Total Annual Cost	\$27,283
		NOx Reduction (tons/yr)	6.57
		Cost of Control (\$/ton - NOx)	\$4,153

ENCLOSURE

EPA's Comments on MassDEP's Proposed Air Quality Plan Approval and Draft PSD Permit for Footprint Power Salem Harbor Development LP's Salem Harbor Station Redevelopment Project, Salem, MA

1. Draft PSD Permit Fact Sheet: Best Available Control Technology (BACT) Analysis

a. The Fact Sheet's BACT analysis only provided the results of the BACT analysis but not the analysis itself. Without the analysis showing how the MassDEP reached its permit decisions, it is difficult for the public or EPA to provide informed and effective comments regarding the MassDEP's SHR BACT decisions. We understand the MassDEP is relying on the BACT analysis provided in Footprint's PSD permit application. EPA recommends the MassDEP attach the applicant's BACT analysis as an appendix to the Fact Sheet or include a hyperlink that links the Fact Sheet to the applicant's BACT analysis. EPA-1

In particular, the Fact Sheet states that permit applicants are required to follow a top-down BACT analysis to determine BACT for any given project. We understand the MassDEP procedures are modeled after EPA's October 1990 draft New Source Review Workshop manual and the MassDEP's own June 2011 BACT guidance document. This analysis should be available for the public and EPA to review. EPA-2

b. The fourth paragraph of page 9 in the Fact Sheet in the section entitled "NOx," includes the following statement, "Since determinations of LAER and BACT are similar, and LAER is more stringent than BACT, the control technology evaluation for NOx reflects the requirements of both BACT and LAER." This statement is not accurate. While Lowest Achievable Emission Rate (LAER) and BACT may result in similar emission rates for the pollutant under review, LAER and BACT are separate technology standards used in different permitting programs with different policy and regulatory requirements. EPA recommends the MassDEP document that the applicant needs to meet both BACT and LAER technology requirements separately. EPA-3

c. A BACT analysis requires the permitting agency to evaluate the energy, environmental and economic impacts for any control option to determine if any significant collateral impact exists that would preclude a control option to be selected as BACT. EPA recommends the MassDEP's BACT analysis follow the procedures developed in its 2011 "top-down" BACT guidance document and document the results of the analysis in its Fact Sheet. EPA-4

2. Draft PSD Permit Fact Sheet: Impact Analysis Based on Modeling

a. Similar to comment 1.a, the Fact Sheet only provided the results from the modeling analysis but not the analysis itself. EPA understands the full modeling analysis can be a voluminous document that is difficult to transport. EPA recommends the Fact Sheet include a hyperlink to the applicant's analysis to provide easy access for the public and EPA to review the analysis. EPA-5

b. The second paragraph on page 19 states, "Compliance with the NAAQS and the PSD increments is therefore, according to EPA guidance, demonstrated for all pollutants and the averaging periods for which the impacts are below the SILs." The use of Significant Impact Levels (SILs) alone as a screening tool to show compliance with National Ambient Air Quality Standards (NAAQS) and PSD increments may not be adequate. As was noted by EPA in a recent rulemaking and in a recent court decision considering that rule, there may be locations where the background concentration is close to the NAAQS and the difference in the background ambient air concentration levels and the NAAQS is less than the concentration level reflected in the relevant SIL. In these locations, a showing that the impacts of the proposed facility are below the relevant SIL may not be sufficient by itself to demonstrate that the proposed constructions will not cause or contribute to a violation of NAAQS or PSD increments.

To ensure NAAQS and PSD increments are protected in all instances, EPA suggests that MassDEP compile information on the background concentration levels in the areas where the project is located. If the data shows that the difference between the NAAQS and background concentration levels is greater than the applicable SIL values, then EPA believes it would be sufficient in most cases for the permitting authorities to conclude that sources with impacts below the SIL value will not cause or contribute to a violation of the NAAQS without the need for additional modeling.

EPA-G

November 1, 2013

Cosmo Buttaro
MassDEP Northeast Regional Office
205B Lowell Street
Wilmington, MA 01887
Cosmo.Buttaro@state.ma.us

RE: Application No.: NE-12-022, Transmittal No.: X254064, Comments on Draft PSD Permit and Proposed Air Quality Plan Approval for Footprint Power Salem Harbor Development LP

Dear Mr. Buttaro:

Conservation Law Foundation ("CLF") and the undersigned organizations and individuals hereby provide these comments on the draft Prevention of Significant Deterioration Permit, Proposed Air Quality Plan Approval and Proposed Section 61 Findings issued regarding the above-referenced project on September 9, 2013. These comments are intended to supplement the comments already submitted during the public hearing that was held on October 10, 2013. CLF also received additional information from the Department in response to a public records request on Monday, October 28, 2013, and additional information regarding the air dispersion modeling from Footprint Power Salem Harbor Development LP on Wednesday, October 30, 2013. CLF and the undersigned organizations and individuals may seek leave to provide supplemental comments based upon these materials after having the opportunity to fully review them.

I. The Permit and Application Do Not Properly Conduct BACT Analyses

CLF-1

MassDEP entered into an "Agreement for Delegation of the Federal Prevention of Prevention of Significant Deterioration (PSD) Program by the United States Environmental Protection Agency, Region 1 to the Massachusetts Department of Environmental Protection" ("Delegation Agreement") on April 11, 2011. Exhibit 1. Under that Delegation Agreement, the MassDEP agreed to implement and enforce 40 C.F.R. 52.21 as of July 1, 2010 and with respect to PM2.5 increments, the amendments of October 20, 2010. Exhibit 1 at 1. In addition, the Delegation Agreement provides:

E. MassDEP will follow EPA policy, guidance, and determinations as applicable for implementing the federal PSD program, whether issued before or after the execution of this Delegation Agreement, including:

1. PSD policy, guidance, and determinations issued by EPA. EPA will provide MassDEP with copies of EPA policies, guidance, and determinations through the Region 7 NSR database and/or hard copies where appropriate and will collaborate with MassDEP as necessary regarding interpretations of EPA policies, guidance and determinations. Where no current EPA policy or guidance clearly covers a specific situation, MassDEP shall consult with the EPA, Region 1, Office of Ecosystem Protection, Air Planning Branch, Air Permits, Toxics and Indoor Air Unit if it has questions on the interpretation of the EPA regulations.
2. The requirement to identify and address, as appropriate, disproportionately high and adverse human health or environmental effects of federal programs, policies, and activities on minority and low-income populations, as set forth in *Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations*, Exec. Order 12,898, 59 Fed. Reg. 7,629 (Feb. 16, 1994).

F. MassDEP will at no time grant a waiver to the requirements of 40 CFR 52.21 or to the requirements of an issued PSD permit.

Major new sources and major modifications to existing major sources are required to apply BACT pursuant to the PSD regulations at 40 C.F.R. § 52.21(j)(2) and (3). BACT is defined as “an emissions limitation... based on the maximum degree of reduction for each pollutant subject to regulation under [the Clean Air] Act which would be emitted from any proposed major stationary source or major modification which the Administrator, on a case-by-case basis, taking into account energy, environmental, and economic impacts and other costs, determines is achievable for such source or modification through application of production processes or available methods, systems and techniques... for control of such pollutant.” 40 C.F.R. § 52.21(b)(12); Clean Air Act (CAA) §169(3). In addition, BACT can be no less stringent than any applicable NSPS or MACT standard. Id.

Massachusetts has its own definition of BACT for the purposes of implementing its Comprehensive Plan Approval program under 310 CMR 7.02. Under that program, a source may propose an emission control limitation in lieu of an emission-unit-specific top-down BACT analysis, including reliance upon action issued by the Department, also known as “Top Case BACT.”. See 310 CMR 7.02(8)(a)2.a. Based upon Footprint Power’s application, it appears that Footprint Power relied upon the MassDEP “Top Case BACT Guidelines for Combustion Sources” to establish several of its proposed BACT limits for the PSD permit. See Salem Harbor Redevelopment Project, Comprehensive Plan Approval Application, at 5-1, 5-3, 5-4, 5-5; See also MassDEP Draft PSD Permit Fact Sheet, at 9.

The BACT analysis required under 40 C.F.R. 52.21 does not allow for this type of BACT by proxy; instead, it has been held repeatedly to require a unit-specific, case-by-case analysis that establishes a BACT limit that is "tailor-made" for each source and each pollutant. See In re City of Palmdale (Palmdale Hybrid Power Project), PSD Appeal No. 11-07, EAB, 2012 WL 4320533 (E.P.A.) Sept. 17, 2012, citing In re Prairie State Generating Co., 13 E.A.D. 1, 12 (EAB 2006), aff'd sub. nom. Sierra Club v. U.S. EPA, 499 F.3d 653 (7th Cir. 2007); In re Three Mountain Power, LLC, 10 E.A.D. 39, 47 (EAB 2001); Knauf I, 8 E.A.D., at 128-29. Therefore, the applicant should be required to provide and MassDEP should conduct new BACT analyses for any and all of the pollutants for which the applicant relied upon MassDEP's Top Case BACT guidance to ensure that the requirements of the federal regulations are met, and MassDEP should include more detailed information consistent with the requirements of 40 C.F.R. 52.21 regarding its analysis and justification for the BACT emissions limits that were ultimately set. CLF -1

The establishment of BACT emission limits in the draft PSD permit in a manner which is inconsistent with 40 C.F.R. 52.21 constitutes an error of law by it relying upon the less stringent Massachusetts BACT standard and the MassDEP BACT guidance rather than implementing the legal requirements for BACT analysis set forth at 40 C.F.R. 52.21 as required by the Delegation Agreement. As discussed more fully below, this results in a Draft PSD permit with BACT limits that are invalid as a matter of law because they were not properly developed in accordance with the Delegation Agreement, the requirements of 40 C.F.R. 52.21, and the requirements of the Clean Air Act, 42 U.S.C. §7479(3).

II. Proposed gas turbine emission limits: 2 ppm NOx, 2 ppm CO, 1 ppm VOC (no duct firing), 1.7 ppm VOC (duct firing), 2 ppm NH3

The draft PSD permit establishes a CO limit of 2.0 ppmvd @ 15% O2 without conducting the proper BACT analysis, as described above. See Draft PSD Permit at Table 2, at 5. The draft PSD permit also establishes a VOC limit of 1.0 ppmvd @ 15% O2 without duct firing and 1.7 ppmvd @ 15% O2 with duct firing without conducting the proper BACT analysis as described above. See Draft PSD Permit at Table 2, at 6.

MassDEP clearly relied upon the Massachusetts Top Case BACT Guidelines in establishing the CO limit rather than implementing the federally required case-by-case BACT analysis. See MassDEP Draft PSD Fact Sheet at 12 ("Footprint proposes that the SHR Project will achieve CO emissions of 2.0 ppmvdc, which matches the top level of control for CO emissions as specified in the June 2011 MassDEP Top Case BACT Guidelines for combustion turbine combined cycle units firing natural gas."). Although the Fact Sheet also references two other recent projects, it does not indicate that a full BACT analysis was conducted. Thus, the CO BACT limit is invalid as a matter of law because it was derived in reliance upon the less stringent Massachusetts standards rather than in accordance with the federal regulations and laws governing BACT analysis. CLF -2

In addition, permit applications with lower CO and VOC limits are under review. See March 2013 Cove Point LNG export project air permit application, for example. The project includes two GE Frame 7EA gas turbines. The proposed Cove Point GE gas turbine CO limit is 1.5 ppm. The proposed gas turbine VOC limit is 0.7 ppm.

Table 1. Gas Turbine Emission Limits at Proposed Cove Point (MD) LNG Export Project.

Emissions Source	Pollutant	Control Technology	Emission Rate ¹
GE 7FA Turbines (2)	NO _x NO ₂	Selective Catalytic Reduction (SCR)	2.5 ppmvd
	CO	Oxidation Catalyst	1.5 ppmvd
	VOC	Oxidation Catalyst	0.7 ppmvd

Reducing the gas turbine CO limit from 2.0 ppm to 1.5 ppm would reduce projected Footprint Power CO emissions by more than 20 tpy. Reducing the gas turbine VOC limit from either 1.0 ppm (no duct firing) or 1.7 ppm (duct firing) to 0.7 ppm, under either no duct firing or duct firing, would reduce projected Footprint Power VOC emissions by at least 8 tpy.

Footprint Power and MassDEP provide no explanation why the proposed VOC emission rate is increased during duct firing while the 2 ppm CO limit is not increased during duct firing. Both CO and VOC are “products of incomplete combustion,” and would generally be expected to increase or decrease in tandem. No justification has been offered for increasing the VOC limit during duct firing while leaving the CO limit unchanged. CLF-3

Further, Table 2, Footnote 2 explains that the emissions rates are based on burning natural gas in any one combustion turbine at a maximum natural gas firing rate of 2,449 MMBtu/hr, HHV, at 90 F ambient temperature, 14.7 psia ambient pressure, and 60% ambient relative humidity (combustion turbine and duct burner combined). Thus, the limits provided for the unit with and without duct firing don't appear to provide a clear indication of the differences for each limitation with and without duct firing. We request that this information be included in the final permit. CLF-4

III. Gas turbine start-up and shutdown emissions

Both GE and Siemens market rapid response combined cycle gas turbine power plants. Footprint Power will utilize GE Frame 7FA gas turbines. The unfired heat input to the Siemens SGT6-5000F turbine, at 2,096 MMBtu/hr, is very similar to the 2,130 MMBtu/hr unfired heat input to the GE Frame 7FA to be used at Footprint Power.^{1,2} The draft air permit allows up to 89 lb of NO_x per startup event over a period of up to 45 minutes. The NO_x emissions limit during normal operations is 18.1 lb/hr. Therefore NO_x emissions during an hour that includes a startup would be:

$$89 \text{ lb} + (0.25 \text{ hr}/1 \text{ hr})(18.1 \text{ lb/hr}) = 93.5 \text{ lb per startup hour.}$$

¹ SCAQMD, El Segundo Power, LLC, Addendum to Determination of Compliance, February 29, 2008, p.1, attached as Exhibit 2.

² MassDEP, Footprint Power Salem Harbor Development LP Draft PSD Permit Fact Sheet, Table 2, footnote, p. 7.

In contrast, the Siemens rapid response combined cycle power plant emits up to 24 lb of NOx over an uncontrolled 12-minute startup. The remaining 48 minutes of the startup hour would be at the controlled normal operations NOx emission rate of 15.44 lb/hr per turbine. Therefore, according to the SCAQMD, based on its review of the Siemens fast response turbine startup NOx emission rate, the maximum NOx emissions during a startup hour would be:

$$24 \text{ lb} + (0.80\text{hr})(15.44 \text{ lb/hr}) = 36.4 \text{ lb/hr.}$$

The draft PSD permit indicates that up to 206 startups will occur each year on each combustion turbine.³ Therefore 11.8 tons per year of additional startup NOx emissions would be avoided by either (1) use of the Siemens rapid response turbine or (2) reducing the NOx startup limit for the GE turbine selected by Footprint Power to an equivalent level. CLF-5

$$2 \text{ turbines} \times (206 \text{ startup/hr per turbine/yr}) \times [(93.5 \text{ lb/hr} - 36.4 \text{ lb/hr}) / (2,000 \text{ lb/ton})] = 11.8 \text{ tpy}$$

Moreover, although the MassDEP Draft Permit Fact Sheet indicates that the proposed startup and shutdown emissions limits represent BACT, it provides no basis for this conclusion. Again, MassDEP has failed to meet the requirements established by the Delegation Agreement, the federal regulations and the Clean Air Act regarding BACT analysis. Therefore, the MassDEP committed an error of law and the current BACT limits for startup and shutdown are invalid. CLF-6

IV. Auxiliary boiler emission limits: 9 ppm NOx, 47 ppm CO, 11.8 ppm VOC

The auxiliary boiler is permitted to operate 6,570 hours/year. The auxiliary boiler will be permitted to operate on a base load, round-the-clock schedule. Yet the proposed emission limits are high and represent what would be expected for back-up combustion equipment. Footprint Power erroneously cites to the June 2011 MassDEP BACT guideline document as the basis for the auxiliary boiler limits. As noted above, use of the MassDEP guidance is contrary to the Delegation Agreement, the federal regulations, and the Clean Air Act. Therefore, the BACT emissions limit established for the auxiliary boilers was based upon an error of law and is invalid. CLF-7

In addition, the one BACT example used in the BACT guideline document is for a boiler greater than 50 MMBtu/hr heat input. Here is the relevant excerpt from the BACT guideline document (p. 5):

Case Study: In the recent past, boiler manufacturers have developed "ultra-low NOx burners" (ULNBs) which can achieve an oxides of nitrogen emission rate of 9 parts per million (ppm). Before the advent of ULNBs, BACT for NOx for boilers with capacity above approximately 50 million British thermal units per hour was achieved by the use of Selective Catalytic Reduction (SCR) to reduce NOx emissions to 5 ppm, accompanied by a 5 ppm ammonia (NH₃) slip. When analyzing the incremental cost of using SCR to reduce the 9 ppm NOx emission rate attained by ULNB to reach a 5 ppm NOx emission limit, it became readily apparent that requiring SCR with added NH₃ emissions would be economically infeasible, on a dollar-per-ton-of-pollutant-removed basis. Therefore, NOx BACT for this category of emission units is now 9 ppm, with no NH₃ emissions.

³ MassDEP Fact Sheet, Table 2, footnote 1, p. 7.

What the MassDEP provides in the BACT guideline document is a historical example, not a rigorous 2013 top-down BACT analysis for the Footprint Power auxiliary boiler. The 2011 example presumes that the best performance possible for an SCR on a boiler greater than 50 MMBtu/hr is 5 ppm NOx and 5 ppm ammonia slip. In contrast, the two gas turbines at Footprint Power have proposed NOx and ammonia limits of 2 ppm. There is no dispute that 2 ppm NOx and 2 ppm ammonia slip is achievable when located in the waste-heat boiler of a combined cycle unit. If SCR is available with 2 ppm NOx and 2 ppm ammonia slip limits for the auxiliary boiler, SCR would be BACT for the Footprint Power auxiliary boiler and consistent with the 2011 MassDEP BACT guideline document. Nonetheless, the MassDEP is still obligated by the Delegation Agreement and the federal regulations to conduct a case-by-case BACT analysis rather than simply relying upon its less stringent guidance document. CLF-8

The CO and VOC limits proposed in the draft air permit for the auxiliary boiler are high at 47 ppm and 11.8 ppm respectively. The draft air permit does not indicate that any case-by-case BACT analysis, as required by the Delegation Agreement and federal regulations, was conducted, nor does it even attempt to rely on the MassDEP BACT guideline document example to justify these high limits. Nor does the draft air permit acknowledge that the reason the proposed ultra-low burner can meet a 9 ppm NOx limit is by reducing the excess air to the burner to a minimum, which has the side effect of increasing products of incomplete combustion, CO and VOC, substantially. An oxidation catalyst on the auxiliary boiler would solve this CO and VOC emissions problem. Nor does the permit adequately explain the analysis for the NOx and VOC limits. CLF-9

As a result, the current BACT limit for CO for the auxiliary boiler is based upon an error of law and is invalid.

V. Other Issues

Particulate Matter

Currently the permit establishes parametric monitoring as the primary method for ensuring compliance with the PM/PM10/PM2.5. Footprint should be required to install PM CEMS which are commercially available and have been installed on at least one electric generating unit operating in the Commonwealth (Mt. Tom Station) and are being required for two other electric generating units in the Commonwealth (Brayton Point and Palmer Renewable Energy). Particulate matter is one of the most deadly pollutants emitted from power plants, and should be monitored continuously to ensure compliance. The permit should also distinguish between filterable and condensable limits for PM. CLF-10

With respect to the PM limits themselves, it appears that the BACT analysis required by the Delegation Agreement, the federal regulations and the Clean Air Act, as referenced above, was not implemented. MassDEP appears to have relied upon the top case BACT Guidance to establish that a rate of 0.0067 lbs/MMBtu and 0.0071 lbs/MMBtu would constitute BACT. See MassDEP Draft PSD Fact Sheet at 12-13. However, the most recent PSD permit issued by the EPA in Massachusetts determined that BACT was 0.004 lbs/MMBtu. *Id.* MassDEP failed to provide sufficient information for its conclusion that the PSD permit issued by Region 1 EPA for CLF-11

the Pioneer Valley Energy Center Project which included an emissions limit of 0.004 lbs/MMBtu would not be achievable and should not represent BACT for this facility. See MassDEP Draft PSD Permit Fact Sheet at 13. Rather than relying upon the MassDEP guidance and the performance of a facility that was constructed years ago, the MassDEP should have required a case-by-case, unit specific BACT analysis for PM as required by the federal regulations, the Delegation Agreement and the Clean Air Act. Failure to do so constitutes an error of law which renders the BACT limits for PM invalid.

Sulfur Content of Fuel

The permit establishes a limit of 0.5 grains/100scf of natural gas for Units 1-3, but the permit does not appear to provide any particular method to ensure continuous monitoring, reporting and compliance with this limit.

CLF-12

NO₂

We recently received additional information regarding the air dispersion modeling conducted to support the analysis of the potential impacts of the facility on ambient air quality. There appears to have been a significant change to the analysis with respect to NO₂. In one of the earlier scenarios, the cumulative impact of the facility along with the interactive sources appears to reach the 1-hour NAAQS for NO₂, 188 µg/m³. See June 2013 revision with modeling for cumulative impacts at Table 6-11 shows that NO₂ reaches 188 which is the NAAQS for NO₂. They also appear to have changed the tons per year from 150 to 148.8.

However, the final Table 2 of the Proposed Plan Approval shows a maximum impact of 166. See Proposed Plan Approval at 14. MassDEP should require the applicant to explain the basis for the revisions to the analysis and expected potential to emit that changed the final analysis of the cumulative impacts of the facility.

CLF-13

Greenhouse Gas BACT

The draft/proposed permits establish a BACT limit for greenhouse gas emissions, however, it is unclear whether the project will achieve the same levels of efficiency and the heat rate limits of recently permitted projects. MassDEP should review the greenhouse gas emissions limits set for the Newark Energy Center in New Jersey as well as the other facilities referenced in a recent letter from Steven Riva, EPA Region 2 to the NJ DEP. See Letter from Steven Riva, Chief, Permitting Section, Air Programs Branch to Francis Steitz, Acting Asst Director, NJ DEP, Re: Newark Energy Center Project, Comments on PSD and NSR Preconstruction Permit Application (April 17, 2012). In that letter, Mr. Riva explained that:

CLF-14

To minimize the GHG emissions, Newark Energy Center proposes as BACT to operate the turbines in combined-cycle mode at a heat rate limit of 6,005 Btu/kW-hr to achieve the thermal efficiency of 58.4% (LHV) with no duct firing. In comparison, the Russell Energy Project in California proposed to achieve a 56.4% efficiency and the Cricket Valley Project in New York proposed to achieve 57.4% efficiency.

Although the permit establishes a lb/MWh limit and higher heating value limits, it should also translate these limits into a thermal efficiency requirement. CLF-15

The permit references additional greenhouse gas emissions from nitrous oxide and methane, but it does not appear to account for the methane and nitrous oxide emissions in determining compliance with the emission limit for total GHGs. The emission factors from Table C-2 of 40 C.F.R. part 98 and global warming potentials from Table A-1 of 40 C.F.R. part 98 should be used, along with the measured heat input to the combustion turbines. CLF-16

Alternative Site Evaluation

Based upon the proposed/draft permits, MassDEP appears to have taken the project proponent's claims at face value regarding the alternative site analysis required under the Nonattainment New Source Review program. For example, MassDEP accepted the CRA analysis of the potential greenhouse gas emissions impacts of the facility without examining the underlying assumptions and recognizing that some of these assumptions (such as the heavy and arbitrary discount to the mandated energy savings goals from the Department of Public Utilities approved energy efficiency programs), an incomplete analysis of proposed transmission upgrades, a failure to include the Commonwealth's goals for installation of wind and solar capacity, and a flawed analysis of expected retirements of generating facilities in the region. See Proposed Plan Approval at 10. MassDEP should have conducted a more thorough analysis of the claims and studies provided by the project proponent rather than simply accepting these analyses as accurate and complete. CLF-17

Air Modeling and Dispersion Analysis

We have not had an opportunity to complete our analysis of the recently provided air dispersion modeling and underlying assumptions, but at this stage we would request that the MassDEP provide a more detailed explanation regarding why preconstruction monitoring as provided for through the PSD regulations was not undertaken, why the monitors from Lynn and Harrison Avenue were considered appropriate for estimating the impacts of this facility, and, as noted above, what changes in the emissions inventory caused the reduction of the maximum predicted 1-hour NO₂ concentration to be reduced from 188 (µg/m³) (the NAAQS) to 166 (µg/m³). Given how little difference there is between the predicted 1-hour concentration and the standard, small changes in emissions can be very important to a compliance demonstration. CLF-18

Also, the modeling analysis is defective due to its use of Logan Airport meteorological data. The specific geographic, wind, and other feature differences as between Logan airport and the site that render it inappropriate for use in the modeling. In addition, it was improper to choose the rural determination rather than the urban given the densely populated areas surrounding the site. We are particularly concerned about the statements in both the Air Dispersion Modeling Protocol of August 2012 and the Proposed Plan Approval that, on the basis of land use within a 3 km radius around the site "rural dispersion coefficients were used in the dispersion modeling." We understand that the dispersion coefficients for use in AERMOD are not to be determined by a rural/urban designation but are to be determined by the values of the CLF-19

surface roughness length, surface albedo and surface Bowen Ratio as calculated by the application of AERSURFACE to the area within a 1 km radius of the anemometer used for wind speeds and directions in AERMOD .

Recordkeeping/Reporting Requirements

Table 10 of the Proposed Plan Approval requires the Permittee to maintain monthly records to demonstrate compliance with the facility-wide emission limits specified in Table 7. We recommend requiring that those monthly records be submitted to MassDEP on a quarterly basis in addition to the semi-annual reporting requirement contained in Table 11. CLF-21

GWSA Compliance

As we stated at the public hearing, there is no evidence in the record to support MassDEP's proposed Section 61 finding that this project is consistent with the GWSA requirements. The only analysis that MassDEP apparently relies upon to reach its conclusion was the analysis presented by Charles River Associates, which only covered the period through 2025, and was riddled with flawed assumptions as referenced above. There is no indication that the applicant presented any information regarding the greenhouse gas emissions impacts from the project through 2050. In addition, MassDEP has a special obligation to ensure compliance with the requirements of the GWSA because it was required to promulgate regulations establishing declining annual aggregate emissions limits for sources and categories of sources by no later than January 1, 2012 to go into effect by January 1, 2013 through December 31, 2020. G.L. c. 21N, § 3d; St. 2008, c. 298, § 16. MassDEP's failure to promulgate these rules does not excuse sources and categories of sources of greenhouse gas emissions from being required to meet the mandates of the GWSA.

Process and Venue for Appeals

The Draft Prevention of Significant Deterioration Fact Sheet (the "Fact Sheet") misstates the law regarding appeals of air permits. MassDEP's procedures and activities in reviewing and rendering a determination on an application for an air permit are governed, in the first instance, by its enabling authority as enacted by the General Court of the Commonwealth of Massachusetts. A recent MassDEP Commissioner's decision clarified that the filing of an application for an air quality permit which seeks "the Department's determination of its right to construct and operate a facility" commences an "adjudicatory proceeding" as the term is defined in Massachusetts G.L. c. 30A, §1 for purposes of appealing any such decision. See, In the Matter of Palmer Renewable Energy, LLC, Final Decision dated September 11, 2012; OADR Docket No. 2011-021 & -022. As codified in G.L. c. 111, § 142B and c. 30A, § 14 appeals of agency determinations, as would be rendered by MassDEP in the instant proceeding, "shall be instituted in the Superior Court..." CLF-22

The Fact Sheet (at page 34), however, provides that interested parties seeking to appeal MassDEP's final permitting decision "may submit a petition for review of the Permit to MassDEP's Wilmington Office, which is consistent with appeal requirements specified in 40 C.F.R. 124.19." Under 40 C.F.R. 124.19, the venue for appeals of PSD permitting decisions is

the USEPA Environmental Appeals Board (EAB). Even a cursory review of the process under 40 CFR §124.19 makes it clear that appeals to the EAB are not and would not be consistent with the foregoing codified Massachusetts law governing appeals of air permitting decisions rendered by MassDEP.

The procedures and venue for appeals of MassDEP air permitting decisions, as provided in the Fact Sheet, are ultra vires, and any such permitting action by MassDEP based on the process and venue provided in the Fact Sheet would be inconsistent with Massachusetts law. In its Final Permit Decision, MassDEP needs to clarify the venue and procedure for appeals of its final PSD Permit Decision in a manner which conforms to its codified enabling authority.

Respectfully submitted,

CONSERVATION LAW FOUNDATION

By its attorney,



Shanna Cleveland

and

Elizabeth Michaud
Michel Beheshti
Jeff Brooks
Andrea Celestine
William Dearstyne
Linda Haley
Douglas Haley
HealthLink
Clean Water Action
Jane Bright
Martha Dansdill
Rosalind Nadeau
Sue Kirby, 350ma.org
Dorian Williams, Better Futures Project
Jody Howard
Marlene Faust

ENCLOSURE

EPA's Comments on MassDEP's Proposed Air Quality Plan Approval and Draft PSD Permit for Footprint Power Salem Harbor Development LP's Salem Harbor Station Redevelopment Project, Salem, MA

1. Draft PSD Permit Fact Sheet: Best Available Control Technology (BACT) Analysis

a. The Fact Sheet's BACT analysis only provided the results of the BACT analysis but not the analysis itself. Without the analysis showing how the MassDEP reached its permit decisions, it is difficult for the public or EPA to provide informed and effective comments regarding the MassDEP's SHR BACT decisions. We understand the MassDEP is relying on the BACT analysis provided in Footprint's PSD permit application. EPA recommends the MassDEP attach the applicant's BACT analysis as an appendix to the Fact Sheet or include a hyperlink that links the Fact Sheet to the applicant's BACT analysis. EPA-1

In particular, the Fact Sheet states that permit applicants are required to follow a top-down BACT analysis to determine BACT for any given project. We understand the MassDEP procedures are modeled after EPA's October 1990 draft New Source Review Workshop manual and the MassDEP's own June 2011 BACT guidance document. This analysis should be available for the public and EPA to review. EPA-2

b. The fourth paragraph of page 9 in the Fact Sheet in the section entitled "NOx," includes the following statement, "Since determinations of LAER and BACT are similar, and LAER is more stringent than BACT, the control technology evaluation for NOx reflects the requirements of both BACT and LAER." This statement is not accurate. While Lowest Achievable Emission Rate (LAER) and BACT may result in similar emission rates for the pollutant under review, LAER and BACT are separate technology standards used in different permitting programs with different policy and regulatory requirements. EPA recommends the MassDEP document that the applicant needs to meet both BACT and LAER technology requirements separately. EPA-3

c. A BACT analysis requires the permitting agency to evaluate the energy, environmental and economic impacts for any control option to determine if any significant collateral impact exists that would preclude a control option to be selected as BACT. EPA recommends the MassDEP's BACT analysis follow the procedures developed in its 2011 "top-down" BACT guidance document and document the results of the analysis in its Fact Sheet. EPA-4

2. Draft PSD Permit Fact Sheet: Impact Analysis Based on Modeling

a. Similar to comment 1.a, the Fact Sheet only provided the results from the modeling analysis but not the analysis itself. EPA understands the full modeling analysis can be a voluminous document that is difficult to transport. EPA recommends the Fact Sheet include a hyperlink to the applicant's analysis to provide easy access for the public and EPA to review the analysis. EPA-5

b. The second paragraph on page 19 states, "Compliance with the NAAQS and the PSD increments is therefore, according to EPA guidance, demonstrated for all pollutants and the averaging periods for which the impacts are below the SILs." The use of Significant Impact Levels (SILs) alone as a screening tool to show compliance with National Ambient Air Quality Standards (NAAQS) and PSD increments may not be adequate. As was noted by EPA in a recent rulemaking and in a recent court decision considering that rule, there may be locations where the background concentration is close to the NAAQS and the difference in the background ambient air concentration levels and the NAAQS is less than the concentration level reflected in the relevant SIL. In these locations, a showing that the impacts of the proposed facility are below the relevant SIL may not be sufficient by itself to demonstrate that the proposed constructions will not cause or contribute to a violation of NAAQS or PSD increments.

To ensure NAAQS and PSD increments are protected in all instances, EPA suggests that MassDEP compile information on the background concentration levels in the areas where the project is located. If the data shows that the difference between the NAAQS and background concentration levels is greater than the applicable SIL values, then EPA believes it would be sufficient in most cases for the permitting authorities to conclude that sources with impacts below the SIL value will not cause or contribute to a violation of the NAAQS without the need for additional modeling.

EPA-G



January 10, 2014

Mr. James Belsky, Permit Chief
MassDEP Northeast Region
205B Lowell Street
Wilmington, MA 01887

**Re: Major Comprehensive Plan Application No. NE-12-022
Transmittal Number X254064 - Salem Harbor Redevelopment (SHR) Project
Draft PSD Permit and Proposed Air Quality Plan Approval**

Dear Mr. Belsky:

This letter supplements the submission dated December 11, 2013, responding to comments made by the Environmental Protection Agency Region 1 (“EPA”) and the Conservation Law Foundation (“CLF”) on the draft PSD permit and proposed Air Quality Plan Approval for the Footprint Power Salem Harbor Development LP (“Footprint” or “Applicant”) Salem Harbor Redevelopment Project (“Project”). Specifically, this letter provides:

- (1) Updates to the proposed combustion turbine combined cycle startup/shutdown (SU/SD) emissions for PM/PM₁₀/PM_{2.5}, as provided in Appendix C-4 of the December 2012 PSD/Air Plans Application. These revised proposed emissions limits are *reduced* from the limits originally proposed.
- (2) Clarification on the calculation of the SU/SD limits for H₂SO₄.

1. PM Emissions During SU/SD

As was the case with the proposed revised CO emissions rates contained in Footprint’s December 11, 2013 submission, GE also has now also revised its PM emission performance estimates for startup and shutdown. These revised reduced SU/SD emissions estimates are based on GE’s collection of new PM test data for combustion turbine combined cycle units using strict quality control methods for EPA test procedures. Based on these latest data, GE has provided new reduced PM SU/SD performance estimates as follows:

	Emissions (lb/event/unit)	Event Duration (minutes)
Cold Start	7.3 6.60	45
Warm Start	5.0 4.69	32
Hot Start	2.6	18
Shutdown	5.8 3.96	27

(Old values shown with strikethrough and revised values are in bold)

Based on these reduced PM SU/SD emissions estimates, the PM mass emissions during SU/SD will remain *equivalent to or lower than* the PM mass emissions during normal operation.¹

Accordingly, Footprint requests that DEP revise Table 7 of the Proposed Air Quality Plan Approval and Table 2 of the Draft PSD Permit, dated September 9, 2013, by incorporating the revised, reduced values of 6.60 lb/event for startup and 3.96 lb/event for shutdown (for PM/PM₁₀/PM_{2.5}), to replace the prior values of 7.3 lb/event for startup and 5.8 lb/event for shutdown, most recently provided in Attachment 1 of our August 6, 2013 submission to MassDEP.

2. Calculation of H₂SO₄ SU/SD Limits

The proposed Air Quality Plan Approval and the draft PSD permit dated September 9, 2013 include the following proposed limits for H₂SO₄ during SU/SD: 1.3 lb/event for startup and 0.2 lb/event for shutdown.² As is standard practice, the proposed limits for H₂SO₄ were derived by using a ratio to the proposed SO₂ limits.

As provided in the supplemental information letter dated August 20, 2013, the proposed SU/SD limits for SO₂ are 2.0 lb/event for startup and 0.3 lb/event for shutdown. As also documented in the August 20 letter, Footprint employed the following ratio of SO₂ to H₂SO₄ emissions for the combustion turbine combined cycle units: $(0.413)(98/64) = 0.63$.³ Footprint applied this ratio and calculated the resulting H₂SO₄ limits as follows: Multiplying 2.0 lb/event for SO₂ by 0.63 yields 1.3 lb/event for H₂SO₄ for startup; and similarly multiplying 0.3 lb/event for SO₂ by 0.63 yields 0.2 lb/event for H₂SO₄ for shutdown.

We are also providing the H₂SO₄ emissions for SU/SD for warm and hot starts, based on the SO₂ emissions for warm and hot starts as provided in our August 20, 2013 letter to MassDEP:

Warm Start: $(1.5 \text{ lb/event for SO}_2)(0.63) = 0.95 \text{ lb/event for H}_2\text{SO}_4$.

Hot Start: $(0.6 \text{ lb/event for SO}_2)(0.63) = 0.38 \text{ lb/event for H}_2\text{SO}_4$.

If you have additional questions on this letter, please contact either me at (617) 803-7809 or George Lipka at (617) 443-7545.

Sincerely,



Keith H. Kennedy
Senior Consultant – Energy Programs

¹ Accordingly, the validity of the Proponent's SU/SD BACT analysis is unaffected by these new, reduced estimates. See the December 11, 2013 submittal at Attachment 1, page 4-24.

² See Table 7 on page 25 of 59, of the Proposed Air Quality Plan Approval and Table 2 on page 7 of 25 of the Draft PSD Permit.

³ See page 3 of the August 20, 2013 submittal.



TETRA TECH

January 16, 2014

Mr. James Belsky, Permit Chief
MassDEP Northeast Region
205B Lowell Street
Wilmington, MA 01887

**Re: Major Comprehensive Plan Application No. NE-12-022
Transmittal Number X254064 - Salem Harbor Redevelopment (SHR) Project
Draft PSD Permit and Proposed Air Quality Plan Approval**

Dear Mr. Belsky:

This letter supplements the submissions dated December 11, 2013, and January 10, 2014, with respect to the draft PSD permit and proposed Air Quality Plan Approval for the Footprint Power Salem Harbor Development LP ("Footprint" or "Applicant") Salem Harbor Redevelopment Project ("Project"). Specifically, this letter provides:

- (1) Revised air quality dispersion modeling results for PM_{10} and $PM_{2.5}$, reflecting the reduction in the PM_{10} and $PM_{2.5}$ emission rates for the GE turbine provided in our letters dated November 1, 2013 and January 10, 2014.
- (2) Updated CO and H_2SO_4 emission rates in parts per million (ppm) for the auxiliary boiler reflecting the updated emissions with incorporation of the oxidation catalyst.
- (3) Correction of several minor typographical errors in prior submissions.

1. Revised Dispersion Modeling Results for PM_{10} and $PM_{2.5}$

Dispersion modeling results for PM_{10} and $PM_{2.5}$ have been recalculated using the updated emission rates for normal operation as well as for startup and shutdown. The modeling procedures used are identical to those documented in our prior submissions. The model inputs and results are found in the updated Application Tables 4-1, 6-2, 6-3, 6-9 and 6-12, provided in Attachment 1. The maximum predicted 24-hr PM_{10} and 24-hr $PM_{2.5}$ impacts with respect to the Significant Impact Levels (SILs) are unchanged. This is because the ancillary sources (emergency diesel generator and emergency fire pump), rather than the combustion turbines, have the greatest predicted contribution to the maximum 24-hr PM impacts.

The maximum annual $PM_{2.5}$ impact with respect to SILs has decreased from 0.12 to 0.11 micrograms/cubic meter (ug/m^3) as a result of the updated lower emission rates for the combustion turbines.

The concentration statistics used for the 24-hr and annual $PM_{2.5}$ increment consumption are different than the SIL statistics for $PM_{2.5}$. While the SIL statistics for $PM_{2.5}$ are based on 5-year averages of the maximum concentrations at each receptor, the 24-hr $PM_{2.5}$ increment

consumption is based on the highest second-highest value at any receptor in any one year, and the annual PM_{2.5} increment consumption is based on the maximum concentration at any receptor in any one year. Using the PM_{2.5} increment consumption statistics with the updated lower emission rates, the 24-hr PM_{2.5} increment consumption decreases from 3.2 to 3.0 ug/m³, while the annual PM_{2.5} increment consumption remains unchanged at 0.12 ug/m³.

Enclosed is a disk containing all revised computer modeling files.

2. Calculation of Auxiliary Boiler CO and H₂SO₄ Emission in parts per million (ppm)

The auxiliary boiler CO and H₂SO₄ emissions in parts per million (ppm) corrected to 3% O₂ (dry basis) are calculated using Equation 19-1 from 40 CFR 60, Method 19. Equation 19-1 is solved for ppm at 3% O₂ dry, as follows:

$$\text{ppm} = (K)(E \text{ in lb/MMBtu}) / [(8710 \text{ dscf/MMBtu})(20.9\% / (20.9\% - 3.0\% \text{ O}_2))]]$$

Where K is the conversion from lb/dscf to ppm, which is 7.27 E-08 for CO and 2.54 E-07 for H₂SO₄. The updated calculated values are as follows:

CO: 0.47 ppmvd @ 3% O₂


H₂SO₄: 0.35ppmvd @ 3% O₂

3. Correction of Minor Typographical Errors

Table 6-2 in Attachment 1 contains two typographical errors that have been corrected and are shown in bold. Attachment 2 shows corrections made to the lb/MWhr values for CO in Table 2-1 of our December 11, 2013 Attachment 1, which had been inadvertently transposed.

If you have additional questions on this letter, please contact either me at (617) 803-7809 or George Lipka at (617) 443-7545.

Sincerely,



Keith H. Kennedy
Senior Consultant – Energy Programs

Attachments

ATTACHMENT 1
UPDATED MODELING TABLES
JANUARY 16, 2014

Table 4-1 National and Massachusetts Ambient Air Quality Standards

Pollutant	Averaging Period	NAAQS/MAAQS ($\mu\text{g}/\text{m}^3$)		Significant Impact Level ($\mu\text{g}/\text{m}^3$)	Maximum Predicted SHR Project impact
		Primary	Secondary		
NO ₂	Annual ¹	100	Same	1	0.4
	1-hour ²	188	None	7.5	41.8
SO ₂	Annual ^{1, 3}	80	None	1	0.03
	24-hour ^{3, 4}	365	None	5	0.7
	3-hour ⁴	None	1,300	25	1.1
	1-hour ^{5, 6}	196	None	7.8	1.0
PM _{2.5}	Annual ⁷	12	Same	0.3	0.12 0.11
	24-hour ⁸	35	Same	1.2	3.2
PM ₁₀	24-hour ⁹	150	Same	5	4.3
CO	8-hour ⁴	10,000	None	500	112.4
	1-hour ⁴	40,000	None	2,000	313.6
O ₃	8-hr ¹⁰	147	Same	NA	NA
Pb	3-month ¹	0.15	Same	NA	<0.00016

¹ Not to be exceeded.
² Compliance based on 3-year average of the 98th percentile of the daily maximum 1-hour average at each monitor within an area.
³ The 24-hour and annual average primary standards for SO₂ will be revoked.
⁴ Not to be exceeded more than once per year.
⁵ Compliance based on 3-hour average of 99th percentile of the daily maximum 1-hour average at each monitor within an area.
⁶ The 1-hour SO₂ standard was effective as of August 23, 2010.
⁷ Compliance based on 3-year average of weighted annual mean PM_{2.5} concentrations at community-oriented monitors.
⁸ Compliance based on 3-year average of 98th percentile of 24-hour concentrations at each population-oriented monitor within an area.
⁹ Not to be exceeded more than once per year on average over 3 years.
¹⁰ Compliance based on 3-year average of fourth-highest daily maximum 8-hour average ozone concentrations measured at each monitor within an area.

Table 6-2 Stack Characteristics

Parameter	Turbine Stacks	Auxiliary Boiler Stack	Emergency Generator Stack	Fire Pump Engine Stack	Auxiliary Cooling Tower
Base Elevation, msl (feet/meters)	16 / 4.9	16 / 4.9	16 / 4.9	16 / 4.9	16 / 4.9
Stack Height (feet/meters)	230 / 70.1	230 / 70.1	86 / 26.2	22 / 6.71	23.3 / 7.1
Inside Stack Diameter (feet/meters)	28.3 / 8.6 (Corresponds to the effective area of both adjacent flues)	3 / 0.9	1 / 0.3	0.667 / 0.3	12 / 3.6
Number of Stacks	1 (with 2 adjacent flues modeled as a single stack)	1	1	1	3
Predominant Land Use Type	Rural	Rural	Rural	Rural	Rural
Stack Location (in NAD83): UTM-E (m) UTM-N(m)	345,732.6 4,709,832.6	345,738.1 4,709,835.2	345,836.1 4,709,846.0	345,760.2 4,709,848.0	345,837.0 4,709,808.2

Table 6-3 Turbine Load Scenarios and Emission Rates

Turbine Manufacturer	GE	GE	GE	GE
Operating Load	100%	75%	46%	Startup
Ambient Temperature (deg F)	90	20	20	50
Evap Cooler and Duct Firing Status	ON	OFF	OFF	OFF
Combined Turbine and Duct Firing Rate (MMBtu/hr) (both turbines)	4898	3580	2720	2530
Comment	Max Firing Case - GE	Intermediate Firing Case - GE	Low Firing Case - GE	Startup Worst Case Hour
Stack Exhaust Velocity (m/s)	18.87	15.82	11.95	12.89
Stack Exhaust Temperature (°K)	369.3	357.26	352.59	344.59
CO (g/s) (both turbines)	2.78	2.03	1.95	73.03
NO _x (g/s) (both turbines)	4.57	3.34	2.54	23.42
SO ₂ (g/s) (both turbines)	0.93	0.677	0.514	0.479
PM _{2.5} (g/s) (both turbines)	3.94 3.28	2.92 2.22	2.80 2.22	2.60 2.22
PM ₁₀ (g/s) (both turbines)	3.94 3.28	2.92 2.22	2.80 2.22	2.60 2.22

Table 6-9 Project Maximum Predicted Impact Concentrations Compared to Significant Impact Levels (micrograms/cubic meter)

Pollutant	Averaging Period	Maximum Predicted Salem Harbor Redevelopment Project Impact	SIL
PM ₁₀	24-Hour	4.3	5
PM _{2.5}	24-Hour	3.2	1.2
	Annual	0.42 0.11	0.3
NO ₂	1-Hour	41.8	7.5
	Annual	0.4	1
SO ₂	1-Hour	1.0	7.8
	3-Hour	1.1	25
	24-Hour	0.7	5
	Annual	0.03	1
CO	1-Hour	313.6	2000
	8-Hour	112.4	500

Table 6-12 Salem Harbor Station Redevelopment Project PSD Increment Compliance Assessment (micrograms/cubic meter)

Pollutant	Averaging Period	Project Increment Consumption ¹	Maximum Allowable PSD Increment
PM _{2.5} (µg/m ³)	24-Hour	3.2 3.0	9
PM _{2.5} (µg/m ³)	Annual	0.42 0.12	4

ATTACHMENT 2

**UPDATED SHORT TERM EMISSION RATE TABLE
COMBUSTION TURBINE COMBINED CYCLE UNITS**

JANUARY 16, 2014

Table 2-1. Short-Term Emission Rates for Combustion Turbine Combined Cycle Units

Pollutant	ppmvd at 15% O ₂	lb/MMBtu	lb/hr (per Unit)	lb/MWhr
NO _x , unfired	2.0	0.0074	17.0	0.051
NO _x , duct-fired	2.0	0.0074	18.1	0.055
CO, unfired	2.0	0.0045	Not to exceed 8.0	0.025 0.027
CO, duct fired	2.0	0.0045		0.027 0.025
VOC, unfired	1.0	0.0013	3.0	0.009
VOC, duct-fired	1.7	0.0022	5.4	0.016
SO ₂ , unfired	0.3	0.0015	3.5	0.010
SO ₂ , duct-fired	0.3	0.0015	3.7	0.011
PM/PM ₁₀ /PM _{2.5} , unfired	N/A	0.0071	8.8	0.029
PM/PM ₁₀ /PM _{2.5} , duct-fired	N/A	0.0062	13.0	0.041
NH ₃ , unfired	2.0	0.0027	6.2	0.019
NH ₃ , duct-fired	2.0	0.0027	6.6	0.020
H ₂ SO ₄ , unfired	0.1	0.0010	2.2	0.007
H ₂ SO ₄ duct-fired	0.1	0.0010	2.3	0.008



TETRA TECH

January 21, 2014

Mr. James Belsky, Permit Chief
MassDEP Northeast Region
205B Lowell Street
Wilmington, MA 01887

**Re: Major Comprehensive Plan Application No. NE-12-022
Transmittal Number X254064 - Salem Harbor Redevelopment (SHR) Project
Draft PSD Permit and Proposed Air Quality Plan Approval**

Dear Mr. Belsky:

This letter supplements the submissions dated December 11, 2013, and January 10, 2014, with respect to the draft PSD permit and proposed Air Quality Plan Approval for the Footprint Power Salem Harbor Development LP ("Footprint" or "Applicant") Salem Harbor Redevelopment Project ("Project"). This letter corrects two minor items and supersedes the January 16, 2013 letter. These corrections are under item 2, in the equation and in the revised CO concentration in auxiliary boiler exhaust. Specifically, this letter provides:

- (1) Revised air quality dispersion modeling results for PM_{10} and $PM_{2.5}$, reflecting the reduction in the PM_{10} and $PM_{2.5}$ emission rates for the GE turbine provided in our letters dated November 1, 2013 and January 10, 2014.
- (2) Updated CO and H_2SO_4 emission rates in parts per million (ppm) for the auxiliary boiler reflecting the updated emissions with incorporation of the oxidation catalyst.
- (3) Correction of several minor typographical errors in prior submissions.

1. Revised Dispersion Modeling Results for PM_{10} and $PM_{2.5}$

Dispersion modeling results for PM_{10} and $PM_{2.5}$ have been recalculated using the updated emission rates for normal operation as well as for startup and shutdown. The modeling procedures used are identical to those documented in our prior submissions. The model inputs and results are found in the updated Application Tables 4-1, 6-2, 6-3, 6-9 and 6-12, provided in Attachment 1. The maximum predicted 24-hr PM_{10} and 24-hr $PM_{2.5}$ impacts with respect to the Significant Impact Levels (SILs) are unchanged. This is because the ancillary sources (emergency diesel generator and emergency fire pump), rather than the combustion turbines, have the greatest predicted contribution to the maximum 24-hr PM impacts.

The maximum annual $PM_{2.5}$ impact with respect to SILs has decreased from 0.12 to 0.11 micrograms/cubic meter ($\mu g/m^3$) as a result of the updated lower emission rates for the combustion turbines.

The concentration statistics used for the 24-hr and annual PM_{2.5} increment consumption are different than the SIL statistics for PM_{2.5}. While the SIL statistics for PM_{2.5} are based on 5-year averages of the maximum concentrations at each receptor, the 24-hr PM_{2.5} increment consumption is based on the highest second-highest value at any receptor in any one year, and the annual PM_{2.5} increment consumption is based on the maximum concentration at any receptor in any one year. Using the PM_{2.5} increment consumption statistics with the updated lower emission rates, the 24-hr PM_{2.5} increment consumption decreases from 3.2 to 3.0 ug/m³, while the annual PM_{2.5} increment consumption remains unchanged at 0.12 ug/m³.

Enclosed is a disk containing all revised computer modeling files.

2. Calculation of Auxiliary Boiler CO and H₂SO₄ Emission in parts per million (ppm)

The auxiliary boiler CO and H₂SO₄ emissions in parts per million (ppm) corrected to 3% O₂ (dry basis) are calculated using Equation 19-1 from 40 CFR 60, Method 19. Equation 19-1 is solved for ppm at 3% O₂ dry, as follows:

$$\text{ppm} = (\text{E in lb/MMBtu}) / [(K)(8710 \text{ dscf/MMBtu})(20.9\% / (20.9\% - 3.0\% \text{ O}_2))]$$

Where K is the conversion from lb/dscf to ppm, which is 7.27 E-08 for CO and 2.54 E-07 for H₂SO₄. The updated calculated values are as follows:

CO: 4.7 ppmvd @ 3% O₂


H₂SO₄: 0.35 ppmvd @ 3% O₂

3. Correction of Minor Typographical Errors

Table 6-2 in Attachment 1 contains two typographical errors that have been corrected and are shown in bold. Attachment 2 shows corrections made to the lb/MWhr values for CO in Table 2-1 of our December 11, 2013 Attachment 1, which had been inadvertently transposed.

If you have additional questions on this letter, please contact either me at (617) 803-7809 or George Lipka at (617) 443-7545.

Sincerely,



Keith H. Kennedy
Senior Consultant – Energy Programs

Attachments

ATTACHMENT 1
UPDATED MODELING TABLES
JANUARY 21, 2014

Table 4-1 National and Massachusetts Ambient Air Quality Standards

Pollutant	Averaging Period	NAAQS/MAAQS ($\mu\text{g}/\text{m}^3$)		Significant Impact Level ($\mu\text{g}/\text{m}^3$)	Maximum Predicted SHR Project impact
		Primary	Secondary		
NO ₂	Annual ¹	100	Same	1	0.4
	1-hour ²	188	None	7.5	41.8
SO ₂	Annual ^{1, 3}	80	None	1	0.03
	24-hour ^{3, 4}	365	None	5	0.7
	3-hour ⁴	None	1,300	25	1.1
	1-hour ^{5, 6}	196	None	7.8	1.0
PM _{2.5}	Annual ⁷	12	Same	0.3	0.12 0.11
	24-hour ⁸	35	Same	1.2	3.2
PM ₁₀	24-hour ⁹	150	Same	5	4.3
CO	8-hour ⁴	10,000	None	500	112.4
	1-hour ⁴	40,000	None	2,000	313.6
O ₃	8-hr ¹⁰	147	Same	NA	NA
Pb	3-month ¹	0.15	Same	NA	<0.00016

¹ Not to be exceeded.

² Compliance based on 3-year average of the 98th percentile of the daily maximum 1-hour average at each monitor within an area.

³ The 24-hour and annual average primary standards for SO₂ will be revoked.

⁴ Not to be exceeded more than once per year.

⁵ Compliance based on 3-hour average of 99th percentile of the daily maximum 1-hour average at each monitor within an area.

⁶ The 1-hour SO₂ standard was effective as of August 23, 2010.

⁷ Compliance based on 3-year average of weighted annual mean PM_{2.5} concentrations at community-oriented monitors.

⁸ Compliance based on 3-year average of 98th percentile of 24-hour concentrations at each population-oriented monitor within an area.

⁹ Not to be exceeded more than once per year on average over 3 years.

¹⁰ Compliance based on 3-year average of fourth-highest daily maximum 8-hour average ozone concentrations measured at each monitor within an area.

Table 6-2 Stack Characteristics

Parameter	Turbine Stacks	Auxiliary Boiler Stack	Emergency Generator Stack	Fire Pump Engine Stack	Auxiliary Cooling Tower
Base Elevation, msl (feet/meters)	16 / 4.9	16 / 4.9	16 / 4.9	16 / 4.9	16 / 4.9
Stack Height (feet/meters)	230 / 70.1	230 / 70.1	86 / 26.2	22 / 6.71	23.3 / 7.1
Inside Stack Diameter (feet/meters)	28.3 / 8.6 (Corresponds to the effective area of both adjacent flues)	3 / 0.9	1 / 0.3	0.667 / 0.3	12 / 3.6
Number of Stacks	1 (with 2 adjacent flues modeled as a single stack)	1	1	1	3
Predominant Land Use Type	Rural	Rural	Rural	Rural	Rural
Stack Location (in NAD83): UTM-E (m) UTM-N(m)	345,732.6 4,709,832.6	345,738.1 4,709,835.2	345,836.1 4,709,846.0	345,760.2 4,709,848.0	345,837.0 4,709,808.2

Table 6-3 Turbine Load Scenarios and Emission Rates

Turbine Manufacturer	GE	GE	GE	GE
Operating Load	100%	75%	46%	Startup
Ambient Temperature (deg F)	90	20	20	50
Evap Cooler and Duct Firing Status	ON	OFF	OFF	OFF
Combined Turbine and Duct Firing Rate (MMBtu/hr) (both turbines)	4898	3580	2720	2530
Comment	Max Firing Case – GE	Intermediate Firing Case - GE	Low Firing Case - GE	Startup Worst Case Hour
Stack Exhaust Velocity (m/s)	18.87	15.82	11.95	12.89
Stack Exhaust Temperature (°K)	369.3	357.26	352.59	344.59
CO (g/s) (both turbines)	2.78	2.03	1.95	73.03
NO _x (g/s) (both turbines)	4.57	3.34	2.54	23.42
SO ₂ (g/s) (both turbines)	0.93	0.677	0.514	0.479
PM _{2.5} (g/s) (both turbines)	3.91 3.28	2.92 2.22	2.80 2.22	2.60 2.22
PM ₁₀ (g/s) (both turbines)	3.91 3.28	2.92 2.22	2.80 2.22	2.60 2.22

Table 6-9 Project Maximum Predicted Impact Concentrations Compared to Significant Impact Levels (micrograms/cubic meter)

Pollutant	Averaging Period	Maximum Predicted Salem Harbor Redevelopment Project Impact	SIL
PM ₁₀	24-Hour	4.3	5
PM _{2.5}	24-Hour	3.2	1.2
	Annual	0.12 0.11	0.3
NO ₂	1-Hour	41.8	7.5
	Annual	0.4	1
SO ₂	1-Hour	1.0	7.8
	3-Hour	1.1	25
	24-Hour	0.7	5
CO	Annual	0.03	1
	1-Hour	313.6	2000
	8-Hour	112.4	500

Table 6-12 Salem Harbor Station Redevelopment Project PSD Increment Compliance Assessment (micrograms/cubic meter)

Pollutant	Averaging Period	Project Increment Consumption ¹	Maximum Allowable PSD Increment
PM _{2.5} (µg/m ³)	24-Hour	3.2 3.0	9
PM _{2.5} (µg/m ³)	Annual	0.12 0.12	4

ATTACHMENT 2
UPDATED SHORT TERM EMISSION RATE TABLE
COMBUSTION TURBINE COMBINED CYCLE UNITS
JANUARY 21, 2014

Table 2-1. Short-Term Emission Rates for Combustion Turbine Combined Cycle Units

Pollutant	ppmvd at 15% O ₂	lb/MMBtu	lb/hr (per Unit)	lb/MWhr
NO _x , unfired	2.0	0.0074	17.0	0.051
NO _x , duct-fired	2.0	0.0074	18.1	0.055
CO, unfired	2.0	0.0045	Not to exceed 8.0	0.025 0.027
CO, duct fired	2.0	0.0045		0.027 0.025
VOC, unfired	1.0	0.0013	3.0	0.009
VOC, duct-fired	1.7	0.0022	5.4	0.016
SO ₂ , unfired	0.3	0.0015	3.5	0.010
SO ₂ , duct-fired	0.3	0.0015	3.7	0.011
PM/PM ₁₀ /PM _{2.5} , unfired	N/A	0.0071	8.8	0.029
PM/PM ₁₀ /PM _{2.5} , duct-fired	N/A	0.0062	13.0	0.041
NH ₃ , unfired	2.0	0.0027	6.2	0.019
NH ₃ , duct-fired	2.0	0.0027	6.6	0.020
H ₂ SO ₄ , unfired	0.1	0.0010	2.2	0.007
H ₂ SO ₄ duct-fired	0.1	0.0010	2.3	0.008