

Notice Inviting Written Public Comment

Notice is hereby given that the Executive Officer/Air Pollution Control Officer (EO/APCO) of the Bay Area Air Quality Management District has issued an amended Preliminary Determination of Compliance (PDOC) and a proposed PSD permit under application number 15487 for a proposed new power plant. The proposed **Russell City Energy Center (RCEC)** would be located at 3806 Depot Road in the City of Hayward, Alameda County, in an area zoned for industrial uses. The project was previously certified by the California Energy Commission on September, 2002. An amendment is required because the site is relocated approximately 1,500 feet to the north from the original location. The proposed facility would be a nominal 600-MW, natural-gas fired, combined-cycle merchant power plant consisting of two natural gas fired combustion turbine generators, one steam turbine generator and associated equipment, two fired heat recovery steam generators, a 9-cell wet cooling tower, and a 300 hp diesel fired pump engine. The PDOC documents the Air Pollution Control Officer's preliminary decision to issue an Authority to Construct for the proposed RCEC.

The proposed power plant would be permitted to emit the following maximum quantities of regulated air pollutants:

Nitrogen Oxides	134.6 tons per year
Carbon Monoxide	389.3 tons per year
Particulate Matter (PM ₁₀)	86.8 tons per year
Precursor Organic Compounds	28.5 tons per year
Sulfur Dioxide	12.2 tons per year

The emissions of nitrogen oxides (as NO₂), carbon monoxide, particulate matter (PM₁₀), and precursor organic compounds associated with this project will meet the Best Available Control Technology (BACT) requirement of District Regulation 2-2-301.1. The emission increases of nitrogen oxides and precursor organic compounds associated with this project will comply with the emission offset requirements of District Regulation 2-2-302.

Pursuant to District Regulation 2-2-405, the Air Pollution Control Officer invites written public comment on the Preliminary Determination of Compliance and its intended action.

The Preliminary Determination of Compliance is available for public inspection at the Outreach and Incentives Division Office located on the 5th floor of District headquarters at 939 Ellis Street, San Francisco CA, 94109. The PDOC may also be viewed on the District website at www.baaqmd.gov. Written comments should be directed to Weyman Lee of the District Engineering Division by May 12, 2007.

Dated at San Francisco, the 2nd day of April, 2007.

Signed by Brian Bunger for Jack P. Broadbent
Jack P. Broadbent
Executive Officer/APCO
Bay Area Air Quality Management District

Oakland Tribune

c/o ANG Newspapers
401 13th Street
Oakland, CA 94612
Advertising
293-2601

BAY AREA AIR QUALITY
939 ELLIS STREET, 4TH FLOOR,
SAN FRANCISCO CA 94109

PROOF OF PUBLICATION

FILE NO.

In the matter of

RUSSELL CITY ENERGY CENTER

The undersigned deposes that he/she is the Public Notice Advertising Clerk of the OAKLAND TRIBUNE, a newspaper of general circulation as defined by Government Code Section 26000, adjudicated as such by the Superior Court of the State of California, County of Alameda (Order No. 237798, on December 4, 1951), which is published and circulated daily in said county and state, seven days a week.

The PUBLIC NOTICE

was published in every issue of the OAKLAND TRIBUNE on the following date(s):

11/20/01

I certify (or declare) under the penalty of perjury that the foregoing is true and correct.


Public Notice Advertising Clerk

Legal No. 00026071

P.O. 13658

Notice Inviting Written Public Comment

Notice is hereby given that the Air Pollution Control Officer of the Bay Area Air Quality Management District has issued a preliminary Determination of Compliance and a proposed PSD permit for application number 2896 for the Russell City Energy Center, a natural gas fired power plant to be located at 3636 & 3590 Enterprise Avenue in the City of Hayward.

The proposed power plant is projected to emit the following maximum quantities of regulated air pollutants:

Nitrogen Oxides	134.6 tons per year
Carbon Monoxide	584.2 tons per year
Particulate Matter (PM10)	86.4 tons per year
Precursor Organic Compounds	28.5 tons per year
Sulfur Dioxide	12.2 tons per year

The emissions of nitrogen oxides, carbon monoxide, particulate matter (PM10), precursor organic compounds, and sulfur dioxide associated with this project trigger the Best Available Control Technology (BACT) requirement of District Regulation 2-2-301.1. The emissions of nitrogen oxides and precursor organic compounds associated with this project trigger the emission-offset requirements of District Regulation 2-2-302.

Pursuant to District Regulation 2-2-405, the Air Pollution Control Officer invites written public comment on the preliminary Determination of Compliance and its intended action.

The preliminary Determination of Compliance is available for public inspection at BAAQMD, Public Information Office, 5th floor, 939 Ellis Street, San Francisco, CA 94109. The document is also available on the District website at www.baaqmd.gov. Go to Russell City Energy Center in the index. Written comments should be directed to the District Permit Services Division by December 20, 2001.

Dated at San Francisco,
the 14th day of November 2001.

Ellen Garvey
Executive Officer/Air Pollution
Control Officer
Bay Area Air Quality
Management District

The Oakland Tribune, #26071
November 20, 2001

Notice of Final Action

Notice is hereby given that the Air Pollution Control Officer (APCO) of the Bay Area Air Quality Management District has issued an Authority to Construct pursuant to Application Number 15487 for the **Russell City Energy Center**, located at Depot Road and Cabot Blvd, Hayward, California effective November 1, 2007.

The project is a 600 MW combined-cycle power plant consisting of two natural gas fired combustion turbine generators (CTGs), one steam turbine generator (STG) and associated equipment, two supplementally fired heat recovery steam generators (HRSGs), a 9-cell wet cooling tower, and a 300-hp diesel fire pump engine.

The equipment is subject to the Prevention of Significant Deterioration (PSD) analysis requirement.

The final engineering evaluation document for the APCO's decision to issue the Authority to Construct is available for public inspection at the Public Information and Education Office located on the 5th floor of District headquarters at 939 Ellis Street, San Francisco California, 94109.

The proposed project is projected to emit the following maximum quantities of regulated air pollutants:

Nitrogen Oxides	134.6 tons per year
Carbon Monoxide	389.3 tons per year
Particulate Matter (PM ₁₀)	86.8 tons per year
Sulfur Dioxide	12.2 tons per year
Precursor Organic Compounds	28.5 tons per year

Dated at San Francisco, the 30th day of November, 2007.

Barry G. Young
Manager, Permit Evaluation
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109