

Russell City Energy Center

Configuration	Gross Plant Efficiency, LHV	Gross Plant Efficiency, HHV	Net Plant Efficiency, LHV	Net Plant Efficiency, HHV	Output kW
RCEC - 501 FD2	55.3%	50.7%	53.3%	48.9%	556,668
RCEC - 501 FD3	56.4%	51.7%	54.4%	49.9%	574,456
Delta	1.09%	1.00%	1.05%	0.96%	3.20%

54.1%