From: GEORGE PAPADOPOULOS
To: jdowning,dpincumb
Date: 1/27/98 3:20pm
Subject: Wayland calculations

Greetings,

Here are some quick phosphorus loading calculations:

If we agree to a 0.7 mg/l effluent limit for phosphorus:

(0.043 MGD) (0.7 mg/l P) (8.345) = 0.25 lbsday of P design flow factor

Using a trading scenario and suggesting a 3:1 ratio for nonpoint vs. point source pollution, the permittee would have to remove 0.75 lbs/day from local septic systems. Therefore, the additional flow which they must treat is solved for below. Assume an influent level of 10 mg/l of P, which would result in a reduction of 9.3 mg/l at the 0.7 mg/l.

But, since this would add another 0.7 mg/l to the River, this would be subtracted from the 9.3 to result in 8.6 mg/l of P removed in total.

(X flow) (8.6 mg/l) (8.345) = 0.75 lbs/dayX = 10,450 GPD.

This would result in a total flow of about 53,000 GPD, which the facility could handle.

If the effluent limit for phosphorus was determined to be 0.5 mg/l, then the coresponding flow which the permittee must treat to achieve the

3:1 "performance standard" would be about 7200 GPD, or 50,000 GPD total facility flow.

I will have a draft permit ready by this Friday.