



STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

OFFICE OF THE
SECRETARY

89 KINGS HIGHWAY
DOVER, DELAWARE 19901

PHONE: (302) 739-9000
FAX: (302) 739-6242

November 1, 2007

Mr. Donald S. Welsh (3RA00)
Regional Administrator
U. S. Environmental Protection Agency
Region III
1650 Arch Street
Philadelphia, PA 19103-2029

Dear Mr. Welsh:

I am pleased to submit the enclosed revision to the State of Delaware State Implementation Plan (SIP) for the Attainment and Maintenance of the National Ambient Air Quality Standards for Ozone. The revision adds a new regulation, Regulation No. 1144 – CONTROL OF STATIONARY GENERATOR EMISSIONS and amends Regulation No. 1102 - PERMITS. Regulation No. 1144 will impact any owner of a stationary generator, except the owner of any: mobile generator; residential generator for emergency use only; certain generators whose emissions are already well controlled; or generators with a standby power rating of 10 kW or less. The amendments to Regulation No. 1102 will clarify the permitting requirements for owners of stationary generators. The effective date of this regulation is January 11, 2006. We apologize for the lateness of this submittal; it was brought to our attention by your Air Quality Planning Branch, that this had not been received by Region III.

The requirements of the CAA Section 110(a)(2)(A) have been met through the normal public hearing process established by the State of Delaware with proper notification (30 days) prior to the convening of the public hearing. Attachments A and B are copies of affidavits as proof of proper notification. It is the position of the State of Delaware that all minimum requirements set forth in the 1990 Clean Air Act Amendments have been met.

We look forward to continuing the cooperative effort between Delaware and EPA in this important work. As always, feel free to contact me or Ali Mirzakhali, Administrator, (302) 739-9402, if you have any questions concerning the enclosed documents.

Sincerely,

A handwritten signature in black ink, appearing to read "John A. Hughes".

John. A. Hughes
Secretary

cc: Judy Katz, EPA w/encl.
James Werner, DNREC, w/o encl.
Ali Mirzakhali

Delaware's Good Nature depends on you!



STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
& ENVIRONMENTAL CONTROL
DIVISION OF AIR & WASTE MANAGEMENT

AIR QUALITY MANAGEMENT
SECTION

156 S. STATE STREET
DOVER, DELAWARE 19901

TELEPHONE: (302) 739 - 9402
FAX No.: (302) 739 - 3106

CERTIFICATION
October 29, 2007

I hereby certify that a public hearing was held August 25, 2005, on revisions to the State of Delaware State Implementation Plan for the Attainment and Maintenance of the National Ambient Air Quality Standards for Ozone, by adding a new Regulation No. 1144 – CONTROL OF STATIONARY GENERATOR EMISSIONS and amending Regulation No. 1102 - PERMITS. Regulation No. 1144 will impact any owner of a stationary generator, except the owner of any: mobile generator; residential generator for emergency use only; certain generators whose emissions are already well controlled; or generators with a standby power rating of 10 kW or less. The amendments to Regulation No. 1102 will clarify the permitting requirements for owners of stationary generators. The effective date of this regulation is January 11, 2006.

I further certify that the hearing was held in accordance with the notice required by Subsection 51.102 of 40 CFR 51.

A handwritten signature in black ink, appearing to read "Ali Mirzakhali".

Ali Mirzakhali, P.E.
Administrator
Air Quality Management
Division of Air and Waste Management