

New York State Department of Environmental Conservation

Permit ID: 1-4722-04426/00004

Facility DEC ID: 1472204426



Emission Unit: U-00002

Process: P05

Source Classification Code: 1-02-006-02

Process Description: Auxiliary boiler firing natural gas.

Emission Source/Control: AUX01 - Combustion

Design Capacity: 29.4 million Btu per hour

Item 67.6:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002

Process: P06

Source Classification Code: 1-02-005-02

Process Description:

Auxiliary boiler firing distillate oil. When the auxiliary boiler fires distillate oil the heat input is 28.0 mmBtu/hr.

Emission Source/Control: AUX01 - Combustion

Design Capacity: 29.4 million Btu per hour

Item 67.7:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00003

Process: P07

Source Classification Code: 1-05-001-06

Process Description: Fuel gas heater firing natural gas.

Emission Source/Control: FGH01 - Combustion

Design Capacity: 4.32 million Btu per hour

Item 67.8:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00003

Process: P08

Source Classification Code: 2-02-001-02

Process Description: Diesel fire pump.

Emission Source/Control: DFP01 - Combustion

Design Capacity: 300 horsepower (mechanical)

Condition 68: Compliance Demonstration

Effective between the dates of 08/01/2006 and Permit Expiration Date

Applicable State Requirement: 6NYCRR 201-5

Item 68.1:

The Compliance Demonstration activity will be performed for: