

UPPER BLACKSTONE WATER POLLUTION ABATEMENT DISTRICT

MONTHLY REPORT WASTEWATER TREATMENT OPERATIONS

From: 7/1/07 To: 7/31/07

Page 1 of 9

.....Weather.....				Sewage.....					
Date	Rain (in)	Temp (F)		Pl Inf. Temp (F)	Flow (mgd)		Total	Daily Septage	Grit Screening (cu. Ft.)
		Min	Max		Max	Min			
7/1/2007	0.001	52	69	64	32.1	15.2	21.8	0	0
7/2/2007	0.01	50	70	66	30.0	16.0	21.8	11200	0
7/3/2007	0	52	76	68	32.1	15.8	21.8	18000	54
7/4/2007	0.37	54	74		63.7	15.3	24.7	0	0
7/5/2007	0.63	61	81	66	63.1	22.6	29.9	18400	81
7/6/2007	0.001	62	80	69	60.8	17.0	26.3	12000	0
7/7/2007	0	57	78	66	34.1	16.0	22.2	0	162
7/8/2007	0.14	62	85	66	57.6	15.0	26.0	0	0
7/9/2007	0.21	62	87	67	65.2	20.2	33.8	20400	0
7/10/2007	0	64	90	69	32.0	17.7	23.6	6000	108
7/11/2007	0.05	69	82	68	29.8	17.3	23.6	23500	0
7/12/2007	0	62	77	69	30.2	16.3	22.4	7000	81
7/13/2007	0.001	60	79	67	29.0	16.7	21.8	30500	0
7/14/2007	0.001	60	80	66	28.4	15.8	21.1	0	54
7/15/2007	0.48	65	85	67	70.6	16.1	25.9	0	0
7/16/2007	0	67	79	69	22.9	19.1	22.9	19400	0
7/17/2007	0	64	82	69	29.0	17.2	22.1	18200	189
7/18/2007	0.18	66		68	54.4	17.5	25.7	26900	0
7/19/2007	0.15		77	70	46.4	17.8	25.3	11000	54
7/20/2007	0.09	60	77	69	31.3	18.2	23.1	24300	0
7/21/2007	0	58	77	67	30.7	16.4	21.9	0	54
7/22/2007	0	63	79	68	31.4	15.8	21.9	0	0
7/23/2007	0.22	59	64	68	36.9	17.4	24.1	21900	0
7/24/2007	0	61	75	69	28.4	17.5	22.5	10000	27
7/25/2007	0	63	83	71	28.9	17.6	22.2	54500	0
7/26/2007	0	65	86	71	28.5	17.1	22.1	14500	7
7/27/2007	0	70	86	70	29.7	18.9	22.6	6000	0
7/28/2007	0.41	68	76	69	64.0	17.9	28.9	0	297
7/29/2007	0.93	66	84	68	18.5	93.0	28.2	0	0
7/30/2007	0.43	68	82	73	57.7	16.3	29.6	14000	54
7/31/2007	0	68	83	71	15.6	36.2	23.1	1225150	243
Total	4.30	1858	2383	2050	1213.0	626.9	752.9	1592850	1465
Average	0.14	62	79	68	39.1	20.2	24.3	51382	47
Minimum	0.00	50	64	64	15.6	15.0	21.1	0	0
Maximum	0.93	70	90	73	70.6	93.0	33.8	1225150	297



Thomas K. Walsh
Engineer-Director-Treasurer