

**TABLE 3**  
**Calpine Corp.-Russell City Energy Center**  
**Hayward, CA.**  
**Aux BoilerStart Cost Effectiveness analysis**  
**CAPITAL COST SUMMARY**

**Costs for emissions reductions for CO and NOx for the addition of an Aux Boiler**

DIRECT CAPITAL COSTS (2008 \$)		Explanation of Cost Estimates
1. Purchased Equipment:		
A) Pollution Control Equipment	\$2,200,000	Base Cost
B) Instrumentation & Controls(No CEMS)	\$220,000	EPA1998 10% of Base Cost
C) Freight & Taxes	\$314,600	8% Taxes; 5% Freight; on 1A & 1B
Total Purchased Equip. Costs (TEC):	\$2,734,600	Sum 1A,1B,1C
2. Installation Costs:		
A) Foundation & Supports	\$218,800	EPA1998 8% of TEC
B) Erection and Handling	\$382,800	EPA1998 14% of TEC
C) Electrical	\$109,400	EPA1998 4% of TEC
D) Piping	\$54,700	EPA1998 2% of TEC
E) Insulation	\$27,300	1% of TEC
F) Painting	\$27,300	EPA1998 1% of TEC
G) Site Preparation	\$0	0% of TEC
Total Installation Costs (TINC):	\$820,300	Sum 2A,2B,2C,2D,2E,2F,2G
Total Direct Capital Costs (TDCC):	\$3,554,900	Sum TEC,TINC
 INDIRECT CAPITAL COSTS		
1. Engineering & Supervision	\$273,500	EPA1998 10% of TEC
2. Construction and Field Exp.	\$136,700	OAQPS 5% of TEC
3. Contractor Fees	\$273,500	OAQPS 10% of TEC
4. Start-up	\$54,700	OAQPS 2% of TEC
5. Performance Testing	\$27,300	OAQPS 1% of TEC
Total Indirect Capital Costs (TICC):	\$765,700	Sum 1,2,3,4,5,6
Total Direct & Indirect Capital Costs (TDICC):	\$4,320,600	Sum TDCC,TICC
Contingency (@12%):	\$518,500	20% TDICC (std engineering accuracy)
TOTAL CAPITAL COSTS (TCC):	\$4,839,100	Sum TDICC,Contingency

**TABLE 3 Cont'd**  
**Calpine Corp.-RCEC**  
**Hayward, CA.**  
**Aux BoilerStart Cost Effectiveness analysis**  
**ANNUAL OPERATING COST SUMMARY**

DIRECT OPERATING COSTS (2008 \$)		Explanation of Cost Estimates
		<b>per Turbine/HRSG</b>
1. Operating Labor	\$45,443	EPA1998 3 hr/day, @41.50 hr
2. Supervisory Labor	\$6,800	OAQPS 15% Operating Labor
3. Maintenance Labor & Materials	\$45,295	2 hr/day, \$41.50/hr, + 100% materials
4. Electricity Expense (\$0.0527/kWh)	\$0	
5. Catalyst Cost (replace)	\$75,000	Based on SCR for Boiler
6. Fuel Costs Boiler (\$6.75/mmbtu gas)	\$151,200	Monthly fuel costs
7. Annual Catalyst Cost	\$28,583	CRF, 7%, 3 yrs
Total Direct Operating Costs (TDOC):	\$277,321	Sum 1 through 7
INDIRECT OPERATING COSTS		
1. Overhead	\$27,300	OAQPS 60% Total Labor
Total Indirect Operating Costs (TIOC):	\$27,300	Sum 1
CAPITAL CHARGES COSTS		
1. Property Tax	\$48,400	OAQPS 1% TCC
2. Insurance	\$48,400	OAQPS 1% TCC
3. General Administrative	\$96,800	OAQPS 2% TCC
4. Capital Recovery Cost (7%, 15 years)	\$531,300	10.98%, TCC
Total Capital Charges Costs (TCCC):	\$724,900	Sum 1,2,3,4
TOTAL ANNUALIZED OPERATING COSTS:	\$1,029,521	Sum TDOC,TIOC,TCCC

**TABLE 3 Cont'd**

**Calpine Corp.-RCEC  
Hayward, CA.  
Aux BoilerStart Cost Effectiveness analysis**

Nox Reduction for Cold and Warm Start Control Cost Effectiveness	<b>0.9</b> <b>\$1,143,912</b>	TPY of Nox Per Ton of Nox
---	----------------------------------	------------------------------

CO Reduction for Cold and Warm Starts Control Cost Effectiveness:	<b>12.4</b> <b>\$82,800</b>	TPY CO Per Ton CO
--	--------------------------------	----------------------

References:

OAQPS - OAQPS Cost Control Manual, 5th ED., February 1996.

EPA1998 - Cost Effectiveness fo Oxidation Catalyst Control of HAP Emissions from Stationary  
Combustion Turbines, EPA, 1998.

\* NE estimated cost for additional catalyst to achieve 90% control of CO per EPA study.

\* EPA memo dated 12-30-99, Emissions Stds Division, Docket A-95-51, and May 14, 1999 memo on Stationary CT  
control cost options.