

EXHIBIT C



UPPER BLACKSTONE

WATER POLLUTION ABATEMENT DISTRICT

Engineer - Director / Treasurer Thomas K. Walsh, P.E.

BOARD OF DIRECTORS

Chairman
Robert L. Moylan Jr., P.E.
Worcester

Vice Chairman
J. Bradford Lange
Millbury

Secretary
Matthew J. Labovites
Worcester

Members

Lawrence H. Galkowski, P.E.
Holden

Philip Guerin
Worcester

F. Worth Landers
Worcester

Donald Manseau
Cherry Valley Sewer District

Rutland

Jeffrey C. Mitchell
Auburn

Stephen F. O'Neill
Worcester

John K. Westerling
West Boylston

August 14, 2007

Water Technical Unit (SEW)
U.S. Environmental Protection Agency
P.O. Box 8127
Boston MA 02114

RE: DNR NPDES Permit MA012369


To Whom It May Concern:

The District is submitting the July 2007 DMR. On 7/9 there was as effluent daily maximum total suspended solids violation.

Changing weather conditions caused an increase in the sludge volume index. On July 9 there were intermittent bulking solids in the final settling tanks.

The District believes there is an error on the DMR form. The effluent CBOD daily maximum should be 17 mg/l not 15mg/l as shown on the form.

Very truly yours,


William Wrightson
Administrative Officer

Cc: MADEP -Central Region