

UPPER BLACKSTONE WATER POLLUTION ABATEMENT DISTRICT

MONTHLY REPORT WASTEWATER TREATMENT OPERATIONS

From: 7/1/07

To: 7/31/07

Page 6 of 9

<-----Suspended Solids (mg/L)----->											
Date	PI Total	PI Vol.	PE Total	Sec. Total	Final Total	%	...Aer Tank...		...Re. Aer. Tank...		..Return..
							Total	Vol.	Total	Vol.	Total
7/1/2007	178	160			4.9	97.2					
7/2/2007	174	157	68		5.8	96.7	3560	2790	5935	4570	8025
7/3/2007	228	200			7.1	96.9	3620	2765	6435	4925	8120
7/4/2007	206	164			8.3	96.0					
7/5/2007	184	147	70		12.9	93.0	2780	2215	5525	4410	8365
7/6/2007	162	144	67		8.8	94.6	3295	2670	6060	4740	8935
7/7/2007	162	145			5.5	96.6					
7/8/2007	200	162			4.7	97.6					
7/9/2007	160	117	59		52.8	66.9	2695	2265	6290	4875	8500
7/10/2007	267	135	154		3.3	98.8	3530	2745	6365	4930	8560
7/11/2007	160	141	58		2.9	98.2	3705	2755	6110	4585	8500
7/12/2007	167	142	56		3.8	97.7	3315	2510	7485	5635	7725
7/13/2007	188	164	63		5.3	97.2	3810	2920	8005	6040	8055
7/14/2007	184	161			4.8	97.4					
7/15/2007	205	152			7.2	96.5					
7/16/2007	172	150	56		5.0	97.1	3654	2675	7525	5545	8445
7/17/2007	176	156	65		5.8	96.7	3725	2765	7945	6000	8115
7/18/2007	171	144	57		3.8	97.8	4015	3000	8280	6350	8650
7/19/2007	170	150	62		6.0	96.5	3265	2945	8055	6250	8355
7/20/2007	195	156	60		4.6	97.6	4000	3245	8380	6605	8550
7/21/2007	176	164			4.2	97.6					
7/22/2007	157	141			5.9	96.2					
7/23/2007	214	191			3.7	98.3	4055	3025	6260	4725	8740
7/24/2007	179	159	63		4.4	97.5	3920	3175	6300	5040	9125
7/25/2007	265	171	67		6.0	97.7	4035	3085	6545	5045	8410
7/26/2007	183	160	63		5.6	96.9	3910	2980	6365	4895	8200
7/27/2007	180	156	52		6.4	96.4	3975	3070	6100	4760	8275
7/28/2007	241	194			9.0	96.3					
7/29/2007	228	162			6.3	97.2					
7/30/2007	128	108	48		4.0	96.9	3270	2320	6070	4460	9035
7/31/2007	180	140	64		4.9	97.3	3555	2700	5425	4245	7750
Total	5840	4792	1254		223.7	2975.4	75689	58620	141460	108630	176435
Avg.	188	155	66		7.2	96.0	3604	2791	6736	5173	8402