



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY-REGION 7
 3015 MAY 28 AM 10:25

EXPEDITED SPCC SETTLEMENT AGREEMENT
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 7, 11201 RENNER BOULEVARD, LENEXA, KANSAS 66219

DOCKET NO. CWA-07-2015-0002

On: May 30, 2014

At: 3187 320th Street, Crawfordsville, Iowa

Owned or operated by, W2Fuel, LLC (Respondent), an authorized representative of the U.S. Environmental Protection Agency (EPA) requested information to determine compliance with the Oil Pollution Prevention (SPCC) regulations promulgated at 40 C.F.R. Part 112 under Section 311(j) of the Clean Water Act (33 U.S.C. § 1321(j)) (the Act), and found that Respondent had violated regulations implementing Section 311(j) of the Act by failing to comply with the regulations as noted on the attached SPILL PREVENTION CONTROL AND COUNTERMEASURES INSPECTION FINDINGS, ALLEGED VIOLATIONS, AND PROPOSED PENALTY FORM (Form), which is hereby incorporated by reference.

This proceeding and the Expedited Settlement are under the authority vested in the Administrator of the EPA by Section 311(b)(6)(B)(i) of the Act, 33 U.S.C. § 1321(b)(6)(B)(i), as amended by the Oil Pollution Act of 1990, and by 40 C.F.R. § 22.13(b). The parties enter into this Expedited Settlement in order to settle the civil violations described in the Form for a penalty of \$3125.

This settlement is subject to the following terms and conditions:

The EPA finds that Respondent is subject to the SPCC regulations, which are published at 40 C.F.R. Part 112, and has violated the regulations as further described in the Form. Respondent admits that he/she is subject to 40 C.F.R. Part 112 and that the EPA has jurisdiction over Respondent and Respondents conduct as described in the Form. Respondent neither admits nor denies the Inspection Findings, and waives any objections it may have to the EPA's jurisdiction. Respondent consents to the assessment of the penalty stated above.

Respondent certifies, subject to civil and criminal penalties for making a false submission to the United States Government, that the violations have been corrected and **Respondent has sent a certified check in the amount of \$3125, payable to the "Environmental Protection Agency," via certified mail to:**

U.S. Environmental Protection Agency
 P.O. Box 979077
 St. Louis, Missouri 63197-9000

And Respondent has noted on the penalty payment check "Docket No. CWA-07-2015-0002" and "OSLTF - 311." **The original, signed Settlement Agreement and copy of the penalty payment check must be sent via certified mail to:**

Mark Aaron
 U.S. Environmental Protection Agency
 Region 7, AWMD/STOP
 11201 Renner Boulevard
 Lenexa, Kansas 66219

This Expedited Settlement resolves Respondents liability for Federal civil penalties for the violations of the SPCC regulations described in the Form. However, the EPA does not waive any rights to take any enforcement action for any other past, present, or future violations by Respondent of the SPCC regulations or of any other federal statute or regulations. By its first signature, the EPA ratifies the Inspection Findings and Alleged Violations set forth in the Form.

Upon signing and returning this Expedited Settlement to the EPA, Respondent waives the opportunity for a hearing or appeal pursuant to Section 311 of the Act, and consents to the EPA's approval of the Expedited Settlement without further notice.

This Expedited Settlement is binding on the parties signing below, and is effective upon the Regional Judicial Officer's signature.

APPROVED BY EPA:

Margaret S. [Signature] Date 5-13-2015
 Chief, Storage Tanks & Oil Pollution Branch (STOP)
 Air & Waste Management Division (AWMD)

APPROVED BY RESPONDENT:

Name (print): GRAHAM TOWERTON
 Title (print): CHIEF EXECUTIVE OFFICER
 Signature: [Signature]
 Date: 5/11/15

The estimated cost for correcting the violation(s) is:

\$ 10,000.00

IT IS SO ORDERED:

Karina Borromeo Date 5/27/15
 Karina Borromeo
 Regional Judicial Officer

**Spill Prevention Control and Countermeasure Inspection
Findings, Alleged Violations, and Proposed Penalty Form**

(Note: Do not use this form for a farm or if there is no secondary containment)

These Findings, Alleged Violations and Penalties are issued by EPA Region 7 under the authority vested in the Administrator of the EPA by Section 311(b)(6)(B)(I) of the Clean Water Act, as amended by the Oil Pollution Act of 1990.

| | | |
|---|--------------------------|---|
| Company Name W2Fuel, LLC | | Docket Number CWA-07-2015-0002 |
| Facility Name W2Fuel Crawfordsville Plant | | Date May 8, 2014 |
| Address 3187 320th Street | | Inspection Number N/A |
| City Crawfordsville | | Inspector's Name Mark Aaron |
| State Iowa | Zip Code 52621 | EPA Approving Official Margaret Stockdale |
| Contact Rick Black | | Enforcement Contact Mark Aaron |



**Summary of Findings
(Bulk Storage Facilities)**

GENERAL TOPICS: 112.3(a), (d), (e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d)

(When the SPCC Plan review penalty exceeds \$1,500 enter only the maximum allowable of \$1,500)

-
- | | | |
|-------------------------------------|--|---------|
| <input checked="" type="checkbox"/> | No Spill Prevention Control and Countermeasure Plan 112.3 (\$1,500) | \$1,500 |
| <input type="checkbox"/> | Plan not certified by a professional engineer 112.3(d) (\$450) | |
| <input type="checkbox"/> | Certification lacks one or more required elements 112.3(d)(1) (\$100) | |
| <input type="checkbox"/> | Plan not maintained on site (if manned at least (4) hrs/day) or not available for review 112.3(e)(1) (\$300) | |
| <input type="checkbox"/> | No evidence of five-year review of plan by owner/operator 112.5(b) (\$75) | |
| <input type="checkbox"/> | No plan amendment(s) if the facility has had a change in: design, construction, operation, or maintenance which affects the facility's discharge potential 112.5(a) (\$75) | |
| <input type="checkbox"/> | Amendment(s) not certified by a professional engineer 112.5(c) (\$150) | |
| <input type="checkbox"/> | No management approval of plan 112.7 (\$450) | |
| <input type="checkbox"/> | Plan does not follow sequence of the rule and/or cross-reference not provided 112.7 (\$150) | |
| <input type="checkbox"/> | Plan does not discuss additional procedures/methods/equipment not yet fully operational 112.7 (\$75) | |
| <input type="checkbox"/> | Plan does not discuss conformance with SPCC requirements 112.7(a)(1) (\$75) | |

- Plan does not discuss alternative environmental protection to SPCC requirements 112.7(a)(2) (\$200)
- Plan has inadequate or no facility diagram 112.7(a)(3) (\$75)
- Inadequate or no listing of type of oil and storage capacity of containers 112.7(a)(3)(i) (\$50)
- Inadequate or no discharge prevention measures 112.7(a)(3)(ii) (\$50)
- Inadequate or no description of drainage controls 112.7(a)(3)(iii) (\$50)
- Inadequate or no description of countermeasures for discharge discovery, response and cleanup 112.7(a)(3)(iv) (\$50)
- Methods of disposal of recovered materials not in accordance with legal requirements 112.7(a)(3)(v) (\$50)
- No contact list & phone numbers for response & reporting discharges 112.7(a)(3)(vi) (\$50)
- Plan has inadequate or no information and procedures for reporting a discharge 112.7(a)(4) (\$100)
- Plan has inadequate or no description and procedures to use when a discharge may occur 112.7(a)(5) (\$150)
- Inadequate or no prediction of equipment failure which could result in discharges 112.7(b) (\$150)
- Plan does not discuss and facility does not implement appropriate containment/diversionary structures/ equipment 112.7(c) (\$400)
- Inadequate containment or drainage for Loading Area 112.7(c) (\$400)
- Plan had no or inadequate discussion of any applicable more stringent State rules, regulations, and guidelines 112.7(j) (\$75)
- Plan does not include a signed copy of the Certification of the Applicability of the Substantial Harm Criteria per 40 CFR Part 112.20 112.7(j) (\$150) \$150

- If claiming impracticability of appropriate containment/diversionary structures:

- Impracticability has not been clearly denoted and demonstrated in plan 112.7(d) (\$100)
- No contingency plan 112.7(d)(1) (\$150)
- No written commitment of manpower, equipment, and materials 112.7(d)(2) (\$150)
- No periodic integrity and leak testing 112.7(d) (\$150)
- Plan has no or inadequate discussion of general requirements not already specified 112.7(j) (\$75) \$75
The Plan does not provide information regarding compliance with the provisions of the regulations found in 40 CFR 112.12

QUALIFIED FACILITY REQUIREMENTS: 112.6

- Qualified Facility: No Self certification 112.6(a) (\$450)
- Qualified Facility: Self certification lacks required elements 112.6(a) or (b) (\$100)
- Qualified Facility: Technical amendments not certified 112.6(a) or (b) (\$150)
- Qualified Facility: Qualified facility Plan includes alternative measures not certified by licensed Professional Engineer 112.6(b) (\$150)

- Facility: Environmental Equivalence or Impracticability not certified by licensed Professional Engineer 112.6(b)(4) (\$350)

WRITTEN PROCEDURES AND INSPECTION RECORDS 112.7(e)

- Plan does not include inspections and test procedures in accordance with 40 CFR Part 112 112.7(e) (\$75)
- Inspections and tests required are not in accordance with written procedures developed for the facility 112.7(e) (\$75)
- No Inspection records were available for review 112.7(e) (\$200) \$200
 - Written procedures and/or a record of inspections and/or customary business records
 - No records were submitted with the facility's response to the 308 Information Request.
- Are not signed by appropriate supervisor or inspector 112.7(e) (\$75)
- Are not maintained for three years 112.7(e) (\$75)

PERSONNEL TRAINING AND DISCHARGE PREVENTION PROCEDURES 112.7(f)

- No training on the operation and maintenance of equipment to prevent discharges and for facility operations 112.7(f)(1) (\$75) \$75
- No training on discharge procedure protocols 112.7(f)(1) (\$75) \$75
- No training on the applicable pollution control laws, rules and regulations, and/or SPCC plan 112.7(f)(1)(\$75) \$75
- No designated person accountable for spill prevention 112.7(f)(2) (\$75) \$75
 - No information or records were submitted with the facility's response to the 308 Information Request.
- Spill prevention briefings are not scheduled and conducted at least once a year 112.7(f)(3) (\$75)
- Plan has inadequate or no discussion of personnel training and spill prevention procedures 112.7(a)(1) (\$75)

SECURITY (excluding Production Facilities) 112.7(g)

- Plan does not describe how the facility secures and controls access to the oil handling, processing and storage areas 112.7(g) (\$150)
- Master flow and drain valves not secured 112.7(g) (\$300)
- Starter controls on oil pumps not secured to prevent unauthorized access 112.7(g) (\$75)
- Out-of-service and loading/unloading connections of oil pipelines not adequately secured 112.7(g) (\$75)
- Plan does not address the appropriateness of security lighting to both prevent acts of vandalism and assist in the discovery of oil discharges 112.7(g) (\$150)

FACILITY TANK CAR AND TANK TRUCK LOADING/UNLOADING RACK 112.7(h)

- Inadequate secondary containment, and/or rack drainage does not flow to catchment basin, treatment system, or quick drainage system 112.7(h)(1) (\$750)
- Containment system does not hold at least the maximum capacity of the largest single compartment of any tank car or tank truck 112.7(h)(1) (\$450)
- There are no interlocked warning lights, or physical barrier system, or warning signs, or vehicle brake interlock system to prevent vehicular departure before complete disconnect from transfer lines 112.7(h)(2) (\$300)

- There is no inspection of lowermost drains and all outlets prior to filling and departure of any tank car or tank truck 112.7(h)(3) (\$150)
- Plan has inadequate or no discussion of facility tank car and tank truck loading/unloading rack 112.7(a)(1) (\$75)

QUALIFIED OIL OPERATIONAL EQUIPMENT 112.7(k)

- Failure to establish and document procedures for inspections or a monitoring program to detect equipment failure and/or a discharge 112.7(k)(2)(i) (\$150)
- Failure to provide an oil spill contingency plan 112.7(k)(2)(ii)(A) (\$150)
- No written commitment of manpower, equipment, and materials 112.7(k)(2)(ii)(B) (\$150)

FACILITY DRAINAGE 112.8(b) & (c) and/or 112.12(b) & (c)

- Secondary Containment circumvented due to containment bypass valves left open and/or pumps and ejectors not manually activated to prevent a discharge 112.8(b)(1)&(2), and 112.8(c)(3)(i) (\$600)
- Dike water is not inspected prior to discharge and/or valves not open & resealed under responsible supervision 112.8(c)(3)(ii)&(iii) (\$450)
- Adequate records (or NPDES permit records) of drainage from diked areas not maintained 112.8(c)(3)(iv) (\$75)
- Drainage from undiked areas do not flow into catchment basins ponds or lagoons, or no diversion system to retain or return a discharge to the facility 112.8(b)(3)&(4) (\$450)
- Two "lift" pumps are not provided for more that one treatment unit 112.8(b)(5) (\$50)
- Plan has inadequate or no discussion of facility drainage 112.7(a)(1) (\$75)

BULK STORAGE CONTAINERS 112.7(i), 112.8(c) and/or 112.12(c)

- Failure to conduct evaluation of field-constructed aboveground containers for risk of discharge or failure due to brittle fracture or other catastrophe 112.7(i) (\$300)
- Material and construction of tanks not compatible to the oil stored and the conditions of storage such as pressure and temperature 112.8(c)(1) (\$450)
- Secondary containment capacity is inadequate 112.8(c)(2) (\$750)
- Secondary containment systems are not sufficiently impervious to contain oil 112.8(c)(2) (\$375)
- Completely buried metallic tanks are not protected from corrosion or are not subjected to regular pressure testing 112.8(c)(4) (\$150)
- Buried sections of partially buried metallic tanks are not protected from corrosion 112.8(c)(5) (\$150)
- Aboveground tanks are not subject to visual inspections 112.8(c)(6) (\$450) \$450
No inspection records were submitted with the facility's response to the 308 Information Request.
- Above ground containers are not subject to periodic integrity testing techniques such as visual inspections, hydrostatic testing, or other nondestructive testing methods 112.8(c)(6) (\$450) \$450
No integrity testing records were submitted with the facility's response to the 308 Information Request.
- Records of inspections (or customary business records) do not include inspections of container supports/foundation, signs of container deterioration, discharges and/or accumulations of oil inside diked areas 112.8(c)(6) (\$75)

- Steam return/exhaust of internal heating coils that discharge into an open water course are not monitored, passed through a settling tank, skimmer or other separation system 112.8(c)(7) (\$150)
- Container installations are not engineered or updated in accordance with good engineering practice because none of the following are present 112.8(c)(8) (\$450)
 - high liquid level alarm with audible or visual signal, or audible air vent 112.8(c)(8)(i)
 - high liquid level pump cutoff devices set to stop flow at a predetermined level 112.8(c)(8)(ii)
 - direct audible or code signal communication between container gauger and pumping station 112.8(c)(8)(iii)
 - fast response system for determining liquid level of each bulk storage container, or direct vision gauges with a person present to monitor gauges and the overall filling of bulk storage containers 112.8(c)(8)(iv)
- No testing of liquid level sensing devices to ensure proper operation 112.8(c)(8)(v) (\$75)
- Effluent treatment facilities not observed frequently to detect possible system upsets that could cause a discharge as described in 112.1(b) 112.8(c)(9) (\$150)
- Causes of leaks resulting in accumulations of oil in diked areas are not promptly corrected 112.8(c)(10) (\$450)
- Mobile or portable storage containers are not positioned or located to prevent discharged oil from reaching navigable water, or have inadequate secondary containment 112.8(c)(11) (\$150)
- Secondary containment inadequate for mobile or portable storage tanks 112.8(c)(11) (\$500)
- Plan has inadequate or no discussion of bulk storage tanks 112.7(a)(1) (\$75)

FACILITY TRANSFER OPERATIONS, PUMPING, AND FACILITY PROCESS 112.8(d) and 112.12(d)

- Buried piping is not corrosion protected with protective wrapping, coating or cathodic protection 112.8(d)(1)(\$150)
- Corrective action is not taken on exposed sections of buried piping when deterioration is found 112.8(d)(1)(\$450)
- Not-in-service or standby piping is not capped or blank-flanged and marked as to origin 112.8(d)(2) (\$75)
- Pipe supports are not properly designed to minimize abrasion and corrosion, and allow for expansion and contraction 112.8(d)(3) (\$75)
- Aboveground valves, piping and appurtenances are not inspected regularly 112.8(d)(4) (\$300)
- Periodic integrity and leak testing of buried piping is not conducted at time of installation, modification, construction, relocation, or replacement 112.8(d)(4) (\$150)
- Vehicle traffic is not warned of aboveground piping or other oil transfer operations 112.8(d)(5) (\$150)
- Plan has inadequate or no discussion of facility transfer operations, pumping, and facility process 112.7(a)(1)(\$75)

(Do not use this if FRP subject; go to traditional enforcement)

| | |
|------------------|-------------------|
| SUB TOTAL | \$3,125 |
| | |
| TOTAL | \$3,125.00 |

IN THE MATTER OF W2Fuel, LLC, Respondent
Docket No. CWA-07-2015-0002

CERTIFICATE OF SERVICE

I certify that a true and correct copy of the foregoing Order was sent this day in the following manner to the addressees:

Copy by email to Compliance Officer for Complainant:

aaron.mark@epa.gov

Copy by First Class Mail to:

Graham Towerton
Chief Executive Officer
W2Fuel, LLC
3187 320th Street
Crawfordsville, Iowa 52621

Dated: 5/28/15



Kathy Robinson
Hearing Clerk, Region 7

