U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA), REGION 7
901 N. 5th Street, Kansas City, Kansas 66101
UNDERGROUND STORAGE TANK (UST) FIELD CITATION FORM FOR EXPEDITED SETTLEMENT DOCKET NO. RCRA-07-2011-0008

| | · |
|--|--|
| PART I: INSPECTION SUMMARY | PART II: SETTLEMENT AGREEMENT/COMPLIANCE ORDER |
| On: November 2, 2010 (Date of Inspection) | A. Settlement Agreement: The Owner or Operator by signing this Settlement Agreement (or by having an authorized representative sign it) agrees to settle the violations identified in Part I, subject to the following terms and conditions: |
| At: Zip Trip (KS State ID #07708) (Facility Name and Identification Number) Address: 200 E. Avenue A Hutchinson, Kansas 67501 | The Owner or Operator certifies, subject to civil and criminal penalties for making a false submission to the U. S. Government, that he or she has corrected the violations, submitted true and accurate documentation of their correction, and submitted payment to the U.S. Treasury for the amount of \$ 210.00 in payment of the full proposed penalty amount, as described in Part I of this Form. |
| Chris Patel (Name of On-site Representative if not the Owner or Operator) Name and address of the UST Owner or Operator (circle which applies). Name: Chris Patel | The Owner or Operator agrees to comply with the terms of the Compliance Order in Part II.B. Without admitting liability for the violations cited in Part I, the Owner or Operator signing below waives any objections to EPA's jurisdiction with respect to the Compliance Order and this Settlement Agreement, and consents to EPA's final approval of this Settlement Agreement without further notice. The Owner or Operator waives the opportunity for a public hearing pursuant to RCRA section 9006. |
| Address: 200 E. Avenue A Hutchinson, Kansas 67501 A duly designated officer, employee, or representative of the EPA or a duly designated officer or employee of the State or Tribe inspected this facility. EPA has reviewed the inspection report and other relevant materials and has identified the following violation(s) of the UST regulations promulgated or approved by EPA under Subtitle I of the Resource Conservation and Recovery Act (RCRA) (42 U.S.C. § 6991 et seq.). | Once EPA signs the Settlement Agreement, EPA will take no further enforcement action against the Owner or Operator for the civil violations described in Part I, provided the violations have been timely corrected and the penalty has been paid. EPA does not waive its right to enforce against the Owner or Operator for any other violations not described in Part I and violations of the UST requirements or other requirements listed in Part I that were not corrected in a timely manner. |
| Violation: Failure to provide adequate testing for piping system. The required annual function test (FT) on the line leak detector (LLD) has not been performed in the past year. | This Settlement Agreement and Compliance Order will become effective once signed by EPA and is binding on EPA and the Owner or Operator upon signature by both parties. Final approval of the Settlement Agreement and Compliance Order is in the sole discretion of the Regional Administrator, Region 7, EPA, or his or her authorized delegate. Upon final approval, EPA shall mail a copy of this document to the Owner or Operator signing below. |
| Cite: 40 CFR § 280.44(a) Proposed Penalty: \$ 210.00 | SIGNATURE BY OWNER, OPERATOR, OR AUTHORIZED REPRESENTATIVE: Name (print): Pachage Title (print): Pachage |
| Cite: Proposed Penalty: \$ 3. Violation: | B. Compliance Order: This Compliance Order is issued under the authority of RCRA section 9006 to resolve the civil violations identified in Part I. The |
| Cite: Proposed Penalty: \$ | Owner or Operator is ordered to correct the violations, submit true and accurate documentation that the violations were corrected, and pay the total penalty amount listed in Part I of this Form. This Compliance Order shall become final and enforceable only upon signature by an EPA official with the authority to sign this document. |
| Cite: Proposed Penalty: \$ 5. Violation: | SIGNATURE BY EPA APPROVING THE SETTLEMENT AGREEMENT AND COMPLIANCE ORDER: Name (print): Robert L. Ratvick Title (print): Regional Tudicial Officer |
| Cite: Proposed Penalty: \$ | Notes: Date: 401. 15.20 |
| PROPOSED PENALTY TOTAL: \$ 210.00 EPA finds the Owner or Operator in violation of the above referenced UST | MIRRIS 15 110 PRINTERION |
| Mayet ESISIL Date: 4/12/2011 | 01:0 122 |

(Signature of Authorized Officer or Employee of EPA)

IN THE MATTER OF Zip Trip, Respondent Docket No. RCRA-07-2011-0008

CERTIFICATE OF SERVICE

I certify that a true and correct copy of the foregoing Underground Storage Tank (UST) Field Citation Form for Expedited Settlement was sent this day in the following manner to the addressees:

Copy hand delivered to Attorney for Complainant:

Raymond C. Bosch Assistant Regional Counsel Region 7 United States Environmental Protection Agency 901 N. 5th Street Kansas City, Kansas 66101

Copy by Certified Mail Return Receipt to:

Chris Patel, Partner Zip Trip 200 E Avenue A Hutchinson, Kansas 67501

Dated: 41511

Kathy Robinson

Hearing Clerk, Region 7