
U.S. ENVIRONMENTAL PROTECTION AGENCY, REGION 7 11201 Renner Boulevard, Lenexa, Kansas 66219 UNDERGROUND STORAGE TANK FIELD CITATION FORM FOR EXPEDITED SETTLEMENT DOCKET NO. RCRA-07-2013-0013

-		
	PART I: INSPECTION SUMMARY	PART II: SETTLEMENT AGREEMENT/COMPLIANCE ORDER
	On: <u>September 25, 2012</u> (Date of Inspection) At: <u>Omaha Valero #103 (NE State ID #450)</u>	A. Settlement Agreement: The Owner or Operator by signing this Settlement Agreement (or by having an authorized representative sign it) agrees to settle the violations identified in Part I, subject to the following terms and conditions:
	(Facility Name and identification Number)	The Owner or Operator certifies, subject to civil and criminal penalties for making a false submission to the U.S. Government, that he or she has
	Address: 3874 Hamilton Street Omaha, Nebraska 68131	corrected the violations, submitted true and accurate documentation of their correction, and submitted payment to the U.S. Treasury for the amount of \$630 in payment of the full proposed penalty amount, as described in Part I of
	Mr. Richard Castro	this Form.
	(Name of On-site Representative if not the Owner or Operator)	The Owner or Operator agrees to comply with the terms of the Compliance Order in Part II.B. Without admitting Ilability for the violations cited in Part I,
	Name and address of the UST Owner or Operator (circle which applies).	the Owner or Operator signing below waives any objections to EPA's jurisdiction with respect to the Compliance Order and this Settlement Agreement, and consents to EPA's final approval of this Settlement
	Name: Mr. Richard Castro	Agreement without further notice. The Owner or Operator waives the opportunity for a public hearing pursuant to RCRA section 9006.
	Address:1111 Willis Avenue	
	Wheeling, Illinois 60090	Once EPA signs the Settlement Agreement, EPA will take no further enforcement action against the Owner or Operator for the civil violations described in Part I, provided the violations have been timely corrected and the
	A duly designated officer, employee, or representative of the EPA or a duly designated officer or employee of the State or Tribe inspected this facility.	penalty has been paid. EPA does not waive its right to enforce against the Owner or Operator for any other violations not described in Part i and violations of the UST requirements or other requirements listed in Part I that
	EPA has reviewed the inspection report and other relevant materials and has identified the following violation(s) of the UST regulations promulgated or	were not corrected in a timely manner.
	approved by EPA under Subtitle I of the Resource Conservation and Recovery Act (RCRA) (42 U.S.C. § 6991 et seq.).	This Settlement Agreement and Compliance Order will become effective once signed by EPA and is binding on EPA and the Owner or Operator upon
	1. Violation: Failure to operate and maintain corrosion protection system	signature by both parties. Final approval of the Settlement Agreement and Compliance Order is in the sole discretion of the Regional Administrator,
	continuously.	Region 7, EPA, or his or her authorized delegate. Upon final approval, EPA shall mail a copy of this document to the Owner or Operator signing below.
	Cite:40 C.F.R. § 280.31(b) [NSFM Title 159 6-002.02A]	
	Proposed Penalty: \$210.00	SIGNATURE BY OWNER, OPERATOR, OR AUTHORIZED REPRESENTATIVE
	2. Violation: Inadequate operation or maintenance of automatic tank gauge.	Name (print): Richard CASLED
	Cite: 40 C.F.R. § 280.43(d) [NSFM Title 159 7-004.04]	Title (print): Managen A
	Proposed Penalty: \$420.00	Signature:
	PROPOSED PENALTY TOTAL: \$630.00	B. Compliance Order: This Compliance Order is issued under the authority
Ì		of RCRA section 9006 to resolve the civil violations identified in Part I. The Owner or Operator is ordered to correct the violations, submit true and
		accurate documentation that the violations were corrected, and pay the total penalty amount listed in Part I of this Form. This Compliance Order shall
		become final and enforceable only upon signature by an EPA official with the authority to sign this document.
		SIGNATURE BY EPA APPROVING THE SETTLEMENT AGREEMENT AND COMPLIANCE ORDER:
	EPA finds the Owner or Operator in violation of the above referenced UST regulations.	Name (print): KARINA BORROMED
		Title (print): REGIONALJUDILIAL OFFILER
	Mugchet Stockel Date: 8/27/13	Signature: Karina Boromet Date: 9-10-13
	(Signature of Authorized Officer or Employee of EPA)	olgnatale. 1 Date
		Notes:
		1 0 10 1 1 JUC 2107
		4. TARLEY AND A CONTRACTOR AND A CONTRAC
1		1

View Images

103

The image of the item you selected is displayed below. To return to the previous page, select 'Back'. To make the image larger or smaller select 'Enlarged View' or 'Normal View'.



IN THE MATTER OF Conoco #103, Respondent Docket No. RCRA-07-2013-0013

CERTIFICATE OF SERVICE

I certify that a true and correct copy of the foregoing Order was sent this day in the following manner to the addressees:

Copy by email to Attorney for Complainant:

bosch.raymond@epa.gov

Copy by email to Respondent:

Richard Castro NMR LLC, 1111 Willis Avenue Wheeling, Illinois 60090

Dated:

14noon

Kathy Robinson Hearing Clerk, Region 7