



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2019 FEB -6 AM 9:44

FEB 06 2019

FILED  
EPA REGION VIII  
HEARING CLERK

Ref: 8ENF-W-SDW

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Mr. Carl Ray Pace  
Cozy Mobile Home Park Public Water System  
1575 E. Monroe Avenue #72  
Riverton, Wyoming 82801

Re: Administrative Order Violation # 2, Cozy Mobile Home Public Water System,  
PWS ID #5600181, Docket No. SDWA-08-2018-0026

Dear Mr. Pace:

On July 18, 2018, the U.S. Environmental Protection Agency issued an Administrative Order (Order) ordering you (Respondent), as owner of the Cozy Mobile Park Public Water System (System), to comply with the Safe Drinking Water Act, 42 U.S.C. Section 300f et seq., and its implementing regulations, the National Primary Drinking Water Regulations, 40 C.F.R. part 141. On October 16, 2018, the EPA issued an Administrative Order Violation (AOV) letter due to your noncompliance with the Order.

Our records indicate that you are still in violation of the Order. The EPA is calculating a penalty due to your continued non-compliance with the Order and is authorized to assess up to \$55,907 per day per violation. Among other things, the Order included the following summarized requirements (from paragraphs 13 and 16 of the Order), which have not been conducted:

- Within 30 days after receipt of this Order, and as required by the Drinking Water Regulations thereafter, Respondent shall monitor the System's water for nitrate, in accordance with 40 C.F.R. § 141.23(a) and (d).
- Within 30 days after receipt of this Order, Respondent shall prepare a 2017 CCR (to include all information required by 40 C.F.R. §§ 141.153 and 154) for the System for 2017 and distribute the CCR to the System's consumers and the EPA. Respondent shall also certify to the EPA by October 1, 2018, that the CCR has been distributed to the System's customers and that information is correct and consistent with monitoring data previously provided to the EPA. Thereafter, Respondent shall prepare and distribute annual CCRs and provide certifications as required by 40 C.F.R. §§ 141.151-141.155.

If you have any questions please contact Christina Carballal by phone at 1-800-227-8917, extension 6046, or (303) 312-6046 or via email at [carballal-broome.christina@epa.gov](mailto:carballal-broome.christina@epa.gov). If you are represented by an attorney who has questions, please ask the attorney to direct legal questions to Mia Bearley, Enforcement Attorney, who may be reached by phone at (800) 227-8917, extension 6554, or (303) 312-6554 or via email at [bearley.mia@epa.gov](mailto:bearley.mia@epa.gov).

We urge your prompt attention to this matter.

Sincerely,

A handwritten signature in black ink, appearing to read 'A. Urdiales', with a long horizontal flourish extending to the right.

Aaron Urdiales, Acting Director  
Water Technical Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: WY DEQ/DOH (via email)  
Melissa Haniewicz, EPA Regional Hearing Clerk