
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 8, MONTANA OFFICE



2014 NOV -5 AM 8: 11



Ref: 8MO

NOV -5 2014

CERTIFIED MAIL RETURN RECEIPT REQUESTED

Ms. Tracy Stone-Manning, Director Montana Department of Environmental Quality 1520 E. Sixth Avenue Helena, Montana 59620-0901

Re: Notice of Violation for Lambert County Sewer and Water District, PWS ID # MT0002590, Docket No. SDWA-08-2015-0001

Dear Ms. Stone-Manning:


According to records that the U.S. Environmental Protection Agency (EPA) has obtained from the Montana Department of Environmental Quality (State) and the State's Public Water Supply Online Query Reports, the Lambert County Sewer and Water District Public Water Supply System (System) referenced above has violated certain provisions of the National Primary Drinking Water Regulations at 40 C.F.R. part 141 (Drinking Water Regulations).

The EPA promulgated the Drinking Water Regulations under the authority of the Safe Drinking Water Act (the Act), 42 U.S.C. §§ 300f, et seq. The EPA is issuing this notice of violation pursuant to section 1414(a) of the Act, 42 U.S.C. § 300g-3(a), which authorizes the EPA to issue an administrative compliance order or file a lawsuit concerning the System if the State does not commence an appropriate enforcement action within thirty days of receiving this notice. The violations are listed below.

Dates of Violations	Violations
2011-2013	Failure to monitor for synthetic organic (pesticides/herbicides) contaminants. [40 C.F.R. § 141.24]
2 nd Quarter 2014	Exceeded the Maximum Contaminate Level for Fluoride. [40 C.F.R. § 141,62(b)]
2011-2014	Failure to report above violations to the State. [40 C.F.R. § 141.31(b)]

The EPA is also sending a copy of this notice of violation to the System.

If the State does not commence an appropriate enforcement action concerning the System within 30 days from the State's receipt of the notification, the EPA will likely issue an administrative order to the owner and/or operator of the System.



Please have your staff notify Sienna Meredith at (406) 457-5026 within 20 days if your records show any discrepancies with the violations cited above, if your staff learns of any change in the System's compliance status, or if there are any questions or comments. Thank you for your assistance.

Sincerely,

James H. Eppers, Supervisory Attorney

Legal Enforcement Program

Office of Enforcement, Compliance and Environmental Justice

Julie A. DalSoglio, Director EPA Region 8 Montana Office

cc: Brian Ligon, Lambert County Sewer and Water District
(via certified mail w/ return receipt)
Kenney Hill, Lambert County Sewer and Water District
Grant Weston, Lambert County Sewer and Water District Public Water System
Sandy Kust, RATES
Tina Artemis, EPA Regional Hearing Clerk
John Arrigo, MDEQ (by email)
Jon Dilliard, MDEQ (by email)
Chad Anderson, MDEQ (by email)