



2008 JUN 19 AM 8:26

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

Ref: 8ENF-W

JUN 19 2008

CERTIFIED MAIL-
RETURN RECEIPT REQUESTED

Buffalo Valley Water District
P.O. Box 321
Moran, WY 83013

Re: Administrative Order Addendum #2
Docket No. SDWA-08-2008-0009
PWS ID # 5600435

Dear Mr. Leys:

This addendum to the Administrative Order (AO) issued December 11, 2007 to the Buffalo Valley Water District approves your May 12, 2008 request for an extension to complete the project that was submitted to EPA on February 15, 2008 and incorporates the new schedule into the AO. In your May 12, 2008 request for extension letter, the Buffalo Valley Water District stated that there was a delay in the backflow device installation because you have experienced difficulties in obtaining updated specifications and costs for the devices, and because many of the homes in the subdivision are second/vacation homes and as a result it has been difficult to contact some of the owners. This letter constitutes the written approval by EPA of the new schedule, as indicated below. Please be advised that the Buffalo Valley Water District must continue to submit monthly progress reports to EPA outlining progress made in completing these activities as required in paragraph 11, on page 2 of the AO, and must continue to comply with the total coliform maximum contaminant levels as required in paragraph 8 on page 2 of the AO.

<u>Action</u>	<u>Deadline</u>	<u>Completion</u>
The System will operate its chlorination equipment on a continual basis to prevent total coliform contamination.	May 9, 2008	February 11, 2008 and ongoing
Conduct System review to determine location of cross-connection control installation.	May 9, 2008	March 17, 2008
All lot services which do not currently have back-flow devices at the points of entry into residences will have them installed.	August 9, 2008	
All yard hydrants, outdoor spigots, etc. which are ahead of the residences' entry points will have back-flow devices directly attached to them.	August 9, 2008	

Please contact Shawn McCaffrey, at (303) 312-6515 if you have any questions concerning this Addendum.

Sincerely,



Diane L. Sipe, Director
 Technical Enforcement Program
 Office of Compliance, Enforcement,
 and Environmental Justice



David J. Janik, Acting Director
 Matthew Cohn, Acting Supervisory Attorney
 Legal Enforcement Program
 Office of Enforcement, Compliance
 and Environmental Justice

cc: WY DEQ (via email)
 WY DOH (via email)