



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2014 AUG 19 AM 8:29

EPA REGION VIII  
HEARING CLERK

AUG 19 2014

Ref: 8ENF-W

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Kenneth Bousfield, Director  
Division of Drinking Water  
Utah Department of Environmental Quality  
P.O. Box 144830  
Salt Lake City, UT 84114-4830

Re: Notice of Violation for Country Estates Mobile Home Park, PWS ID # UTAH26060  
Docket No. **SDWA-08-2014-0030**

Dear Mr. Bousfield:

According to records that the United States Environmental Protection Agency has obtained from the Utah Department of Environmental Quality (State), the public water supply system referenced above (System) has violated certain provisions of the National Primary Drinking Water Regulations at 40 C.F.R. part 141 (Drinking Water Regulations).

The EPA promulgated the Drinking Water Regulations under the authority of the Safe Drinking Water Act (the Act), 42 U.S.C. §§ 300f, *et seq.* The EPA is issuing this notice of violation pursuant to section 1414(a) of the Act, 42 U.S.C. § 300g-3(a), which authorizes the EPA to issue an administrative compliance order or file a lawsuit concerning the System if the State does not commence an appropriate enforcement action within 30 days of receiving this notice. The violations are listed below.

**Dates of Violations**

**Violations**

April 2, 2010	Failure to address significant deficiencies. [40 C.F.R. §§ 141.403 and 404]
2012	Failure to monitor for nitrate. [40 C.F.R. § 141.23]
2008-2010	Failure to monitor for synthetic organic contaminants (herbicides/pesticides). [40 C.F.R. § 141.24]
2008-2010	Failure to monitor for inorganic contaminants. [40 C.F.R. § 141.23]




2009 and 2012 Failure to monitor for lead and copper. [40 C.F.R. § 141.86]  
3<sup>rd</sup> Quarter 2010 Failure to monitor for radium-228. [40 C.F.R. § 141.26]  
2008-2010 Failure to monitor for sodium, sulfate and TDS. [UAC R309-205-5(3)]  
(State violations)  
2011-2013 Failure to report above violations to the State. [40 C.F.R. § 141.31(b)]


The EPA is also sending a copy of this notice of violation to the System.

If the State does not commence an appropriate enforcement action concerning the System within 30 calendar days from the State's receipt of the notification, EPA will likely issue an administrative order to the owner and/or operator of the System.

Please have your staff notify Olive Hofstader at (303) 312-6467 within 20 calendar days if your records show any discrepancies with the violations cited above, if your staff learns of any change in the System's compliance status, or if there are any questions or comments. Thank you for your assistance.

Sincerely,

  
James H. Eppers, Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

  
Arturo Palomares, Director  
Water Technical Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: Tina Artemis, EPA Regional Hearing Clerk  
Patti Fauver, UTDEQ Drinking Water Rule Section Manager (by email)  
Maurice Stewart, Owner, Country Estates Mobile Home Park  
(via certified mail/return receipt requested)  
Bill Shuster, Manager, Country Estates Mobile Home Park (by email)  
Dwight Hill, Env. Health Director, Wasatch County Health Dept. (by email)

