



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2007 SEP 13 PM 1:39

SEP 13 2007

RECEIVED
HEARING CLERK

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Mr. Robert Day, Vice-President
Sleepy Hollow Homeowners Association, Inc.
aka Sleepy Hollow Subdivision
6304 Irving Blvd.
Gillette, WY 82718

Bret Wolz, Operator
Falcon Consulting Services
P.O. Box 3943
Gillette, WY 82717

RE: Emergency Administrative
Order issued under Section 1431
SDWA to Sleepy Hollow Subdivision
Docket No. SDWA-08-2007-0068
PWS ID #5600764

Dear Messrs. Day and Wolz:

On August 2, 2007, the U.S. Environmental Protection Agency (EPA) issued an Emergency Administrative Order (Order) under section 1431 of the Safe Drinking Water Act (the Act), 40 U.S.C. § 300i, to the Sleepy Hollow Homeowners Association, Inc., and Bret Wolz, owner and operator respectively of the Sleepy Hollow Subdivision public water system (the System). This letter confirms the verbal notice provided to you by Kimberly Pardue Welch of EPA on September 5, 2007, that weekly bacteriological monitoring is no longer required. Therefore pursuant to the Order, the System may resume monthly monitoring. Additionally, the System is no longer required to monitor and record the daily chlorine residual in the distribution system or submit to EPA weekly progress reports on the status of the System.

This decision is based on samples collected by the System on August 21, 2007, August 28, 2007, and September 6, 2007 that were analyzed as total coliform negative. Sleepy Hollow Subdivision must collect a total of five routine samples in September 2007 as required by 40 C.F.R. 141.21(b)(5), which requires a public water system that

has one or more total coliform positive samples to collect at least 5 routine samples during the next month the system provides water to the public. The system is required to comply with all other provisions of the Order. Penalties for failing to comply are set forth in the Order.

We appreciate your cooperation. If you have any questions regarding this matter, please contact Kimberly Pardue Welch at (303) 312-6983. If you are represented by an attorney or have legal questions, please ask your attorney to call Marc Weiner, Enforcement Attorney, at (303) 312-6913.

Sincerely,



Diane Sipe, Director
Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



Michael T. Risner, Director
David J. Janik, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice