



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8**

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2008 AUG -7 PM 2:05

RECEIVED  
AUG 14 2008

Ref: 8 ENF-W

AUG - 7 2008

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

The Honorable Matthew Feldman  
Mayor, Town of Dixon  
POB 26  
Dixon, WY 82323

RE: Emergency Administrative Order  
Town of Dixon  
Docket No. SDWA-08-2008-0060  
PWS ID #5600059

Dear Mayor Feldmann:


On May 22, 2008, the US Environmental Protection Agency (EPA) issued an Emergency Administrative Order (the Order) ordering the Town of Dixon (the Town) to take various measures in response to high levels of turbidity in the town's drinking water supply.

This letter serves as written notice that effective July 22, 2007, pursuant to the Order, daily special purpose bacteriological, turbidity and chlorine residual monitoring is no longer required and may now be reduced to weekly monitoring. This letter confirms the verbal and email notice provided by Kathelene Brainich of EPA on July 22, 2008. This notice is based on total coliform monitoring conducted July 10 to 20, 2008, with each sample analyzed as total coliform negative and turbidity and chlorine residual samples meeting acceptable levels. Weekly monitoring shall be conducted until you are notified in writing by EPA that bacteriological sampling may be returned to monthly and special purpose turbidity and chlorine residual sampling can be discontinued. All weekly special purpose turbidity and chlorine residual monitoring results shall be reported to EPA by telephone, and weekly bacteriological results shall be sent to EPA by fax immediately upon receiving the results.

The remainder of the Order remains in effect. The Town must continue to comply with the monitoring required by the Surface Water Treatment Rule, which consists of monitoring chlorine residual when taking samples for the Total Coliform Rule, daily turbidity sampling of the filtered water, and point of entry monitoring of chlorine residual leaving the 20,000 gallon contact tank. The Town must also comply with the interim measures that were outlined in EPA's July 14, 2008, letter.

If you have any questions you may contact Kathelene Brainich at 1-800-227-8917, extension 6481 or (303) 312-6481 or Lisa Kahn at extension 6896 or (303) 312-6896.

Sincerely,



Diane L. Sipe, Director  
Technical Enforcement Program  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice



David J. Janik, Director  
Matthew Cohn, Acting Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: WY DEQ/DOH (via e-mail)