



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2008 AUG 12 11:5:22

BRIDGER VALLEY
HEARING ROOM

Ref: ENF-W

AUG 12 2008

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Mr. Bob Stoddard, Chairman
Bridger Valley Joint Powers Board
P.O. Box 615
Mountain View, WY 82939

Mr. Rocky Irick, Operator
Bridger Valley Joint Powers Board
P.O. Box 615
Mountain View, WY 82939

Re: Emergency Administrative
Order Addendum
Bridger Valley Joint Powers Board
Docket No. SDWA-08-2008-0056
PWS ID #WY5600757

Dear Messrs. Stoddard and Irick:

This addendum to the Emergency Administrative Order (the Order) issued May 21, 2008 to the Bridger Valley Joint Powers Board, incorporates plans and a schedule for system modifications and operation improvements outlined in the June 23, 2008 letter from Rocky Irick, on behalf of the Bridger Valley Joint Powers Board public water system (the System). This letter constitutes the written approval by EPA of the schedule set forth in this letter. As provided in paragraph D.1.h. (on page 14) of the Order, the effect of today's approval is to incorporate the following schedule into the Order. Each deadline in this schedule will be enforceable as if it were part of the Order itself.

The following schedule lists the action to be taken, deadline date and completion date if applicable.

| <u>Action</u> | <u>Deadline</u> | <u>Completion</u> |
|--|--------------------------------|-------------------|
| SCADA system adjustment to allow higher readings | | June 23, 2008 |
| Install valve between the two treatment trains | October 31, 2008 | |
| Create maintenance schedules for all operations of the plant and distribution system | December 31, 2008 | |
| Create standard operating procedures for jar testing | December 31, 2008 | |
| Conduct plant specific training for all operators | December 31, 2008 | |
| Notify EPA in writing of completion of plans and schedule. | Within two weeks of completion | |

EPA understands that the Bridger Valley Joint Powers Board is also currently in the process of drafting a Chain of Command Memorandum of Agreement which will detail responsibilities of each consecutive system and procedures for notifying the community in future similar events. Please provide a copy to the Agency upon completion. EPA also recognizes the long-term plan to build a new storage reservoir.

Please be advised that Bridger Valley Joint Powers Board is required to comply with all provisions of the Emergency Administrative Order. Penalties for failing to comply are set forth in the Order. Please contact Kimberly Pardue Welch, at (303) 312-6983 if you have any questions concerning this Addendum. If you are represented by an attorney, please ask your attorney to call Amy Swanson at the above 800 number, extension 6906, or at (303) 312-6906.

Sincerely,



Diane L. Sipe, Director
Technical Enforcement Program
Office of Compliance, Enforcement,
and Environmental Justice



David J. Janik, Director
Matthew Cohn, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: Dave Dasher, Mountain View Public Works Director
WY DEQ (via email)
WY DOH (via email)

