



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2007 APR 12 AM 9:59

EPA REGION VIII
HEARING CLERK

APR 12 2007

Ref: ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

John H Gothard, Jr., Registered Agent
Hauck Enterprises, L.L.C.
P.O. Box 711
Heber City, UT 84032

Re: Administrative Order Addendum
Docket No. SDWA-08-2007-0011
PWS ID #UTAH26050

Dear Mr. Gothard:

This addendum to the Administrative Order issued January 30, 2007, to Hauck Enterprises, L.L.C., owner of The Other End water system, incorporates the schedule for treatment and modifications to The Other End water system outlined in the plans and drawings for construction modifications, which EPA received on March 6, 2007, from Robert Armstrong at Armstrong Drilling, Inc., on behalf of Hauck Enterprises, L.L.C. On March 19, 2007, Kenneth Bousfield, Executive Secretary of the Utah Drinking Water Board, gave written approval for the well construction modifications.

This letter constitutes the written approval by EPA of the schedule set forth in this letter. As provided in Paragraph 4 of the "order" section of the January 30, 2007 Administrative Order, the effect of today's approval is to incorporate the following schedule into the Administrative Order. Each deadline in the schedule will be enforceable as if it were part of the Administrative Order itself.

The following schedule lists the action to be taken, deadline date and completion date if applicable.

<u>Action</u>	<u>Deadline</u>	<u>Completion</u>
Submit to EPA and the State detailed plans for bringing the System into compliance with maximum contaminant levels (MCL) for total coliform	February 30, 2007	February 20, 2007
Complete well construction modifications including the following items:	July 30, 2007	
Replace sanitary seal around the well head to prevent contamination from entering the well	July 30, 2007	
Install an air relief valve on the discharge pipe which is properly down turned with a No. 14 mesh screen	July 30, 2007	
Ensure ground surface slopes away from wellhead	July 30, 2007	
Develop cross connection control program	July 30, 2007	
Include 1) a smooth nose tap sample, 2) check valve, 3) means of measuring flow on the well discharge pipe	July 30, 2007	
Notify State and EPA of completion of well construction modifications	Within one week of completion of well construction modifications	
Monitor the water for nitrate (this addendum serves as an extension of the deadline for monitoring nitrate as stated in the AO)	Within two weeks of completion of well construction modifications	

Please contact Kimberly Pardue Welch, at (303) 312-6983 if you have any questions concerning this Addendum.

Sincerely,



Diane L. Sipe, Director
Technical Enforcement Program
Office of Compliance, Enforcement,
and Environmental Justice



David J. Janik, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc:

Patti Fauver, UT DEQ
Dave Hansen, UT DEQ
Katie Hauck
Kurt Hauck



Printed on Recycled Paper