



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8**

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2010 JUN 21 AM 11:02

FILED
EPA REGION VIII
HEARING CLERK

Ref: 8 ENF-W

JUN 21 2010

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

The Honorable Matthew Feldmann
Mayor, Town of Dixon
POB 26
Dixon, WY 82323

RE: Emergency Administrative Order
Town of Dixon
Docket No. SDWA-08-2010-0050
PWS ID #5600059

Dear Mayor Feldmann:

On June 8, 2010, the US Environmental Protection Agency (EPA) issued an Emergency Administrative Order (the Order) ordering the Town of Dixon (the Town) to take various measures in response to the loss of pressure in the Town's drinking water distribution system.

The Order required the Town to issue a public notice and boil order, and to continue the notice until receiving notification from EPA to suspend it. This letter confirms the verbal notice provided by Lisa Kahn of EPA on June 12, 2010, that EPA hereby suspends the "Boil Order and Public Notice" section of the Order (page 2, paragraph 2), because the Town's water supply no longer presents an imminent and substantial endangerment.

This letter also serves as written notice that effective June 12, 2010, pursuant to the Order (page 3, paragraph 6), daily special purpose bacteriological and chlorine residual monitoring is no longer required and may now be reduced to weekly monitoring as verbally communicated to the Town by Lisa Kahn on June 12, 2010. This notice is based on total coliform monitoring conducted June 9-11, 2010, with each sample analyzed as total coliform negative and chlorine residual samples meeting acceptable levels. Weekly monitoring shall be conducted until the Town is notified in writing by EPA that bacteriological sampling may be returned to monthly and special purpose and chlorine residual sampling can be discontinued. All weekly special purpose monitoring results shall be reported to EPA by fax immediately upon receiving the results.

The remainder of the Order remains in effect.

If you have any questions you may contact Kathelene Brainich at 1-800-227-8917, extension 6481 or (303) 312-6481. Any questions from the Town's attorney should be directed to Sheldon Mueller, Enforcement Attorney, who may be reached at (303) 312-6916.

Sincerely,



Darcy O'Connor, Acting Director
Technical Enforcement Program
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



Michael T. Risner, Director
David Rochlin, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DEQ/DOH (via e-mail)
Tina Artemis, EPA Regional Hearing Clerk