



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2010 DEC 16 PM 2:45

FILED
EPA REGION VIII
HEARING CLERK

DEC 16 2010

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Honorable Bill Shain, Mayor
Town of Pine Bluffs
220 Main Street
Pine Bluffs, WY 82082

RE: Emergency Administrative
Order under Section 1431 SDWA
Docket No. **SDWA-08-2011-0004**
Town of Pine Bluffs Public
Water System
PWS ID #WY5600040

Dear Mayor Shain:


On October 27, 2010, the U.S. Environmental Protection Agency (EPA) issued an Emergency Administrative Order (Order) under section 1431 of the Safe Drinking Water Act (the Act), 40 U.S.C. § 300i, to the Town of Pine Bluffs, owner and/or operator of the Town of Pine Bluffs public water system (the system). This letter confirms the verbal notice provided to Tom McDonough, by Shawn McCaffrey of EPA on December 9, 2010, that weekly bacteriological monitoring in the distribution system is no longer required. At this time, the system may resume monthly bacteriological monitoring. This notice is based on bacteriological monitoring conducted on November 1, November 8, November 15, November 22, November 29, and December 6, 2010 which were total coliform negative. The system is required to comply with all other provisions of the Order. Penalties for failing to comply are set forth in the Order.

We appreciate your cooperation. If you have any questions regarding this matter, please contact Shawn McCaffrey at (303) 312-6515. If you are represented by an attorney or have legal questions, please ask your attorney to call Marc Weiner, Senior Enforcement Attorney, at (303) 312-6913.

Sincerely,



Michael T. Risner, Director
David Janik, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



Arturo Palomares, Director
Water Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice
U.S. Environmental Protection Agency-Region 8

cc: Tina Artemis, EPA Regional Hearing Clerk
WY DOH & DEQ (via email)
Tom McDonough, Operator