From:	Minter, Jill
To:	"cecilboyle@yahoo.com"; speteerssho@yahoo.com
Cc:	Livingston, Peggy; Haniewicz, Melissa; Alan Huston; Clay Vanhouten; Dan Chamberlain (dchamberlain@warws.com); Doug Evans; Gary Hickman (ghickman@laramiecounty.com); James Brough (james.brough@wyo.gov); Jon Cecil; Karen Farley (karen.farley@wyo.gov); Kevin Schwaiger; Kim Parker; Linda Stratton; Lorraine Werner; Mark Baron (mark.baron@wyo.gov); Mark Pepper; Paul Lohman; Rich Cripe (rich.cripe@wyo.gov); Sarah Geffre; Stan Miller; William Tillman
Subject:	Closure of Emergency Order for Town of Shoshoni (ID#5600053), Freemont County - Docket # SDWA-08-2019-0015
Date:	Tuesday, April 9, 2019 4:02:07 PM
Attachments:	Problem Corrected PN Template.docx

The EPA has decided to close the Emergency Administrative Order (Order) issued on April 2, 2019, to the Town of Shoshoni re: the Town of Shoshoni Public Water System (ID#5600053). The EPA has determined that the requirements of the Order have been completed.

Following repeat disinfection and flushing of the transmission line servicing Wells #2, #5 and #6, daily total coliform special purpose samples taken from the transmission line on Sunday April 7th and Monday, April 8th, have been analyzed as safe for two consecutive days. Therefore the condition of the BOIL ORDER DISCONTINUE, that water from the transmission line remain isolated from the town's distribution system, can also be discontinued and water from the transmission line servicing Wells #2, #5 and #6 can be added to the storage tank and distribution system.

Attached for your use, at the Town's discretion, is a Problem Corrected PN Template. The EPA is not requiring the town to use this template.

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact me.

Jill

Jill Minter | Drinking Water Enforcement | USEPA Region 8 (8ENF-W- SDW) | 1595 Wynkoop Street | Denver, CO 80202-8917 | minter.jill@epa.gov | phone: 303-312-6084 | fax: 303-312-7518