



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8

1595 Wynkoop Street  
DENVER, COLORADO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2016 FEB -3 PM 1:52

FILED  
EPA REGION VIII  
HEARING CLERK

FEB 03 2016

Ref: 8ENF-W

Phil Jordan, Owner (via email: [jordanpro@vcn.com](mailto:jordanpro@vcn.com))  
Keyhole Resort/Marina Public Water System

Re: Administrative Order Closure, Keyhole Resort Marina Public Water System,  
PWS ID #WY5600373, Docket No. SDWA-08-2014-0027

Dear Mr. Jordan:

This letter is to inform you of the EPA's decision to close the Administrative Order (Order) issued to you on August 7, 2014, regarding the Keyhole Resort Marina Public Water System (Marina). The EPA has determined that you have complied with the requirements of the Order and therefore we will close it at this time.

If you decide to use the Marina well (WL02) in the future, either in lieu of or in addition to the water provided to the Marina by the Keyhole State Park Public Water System since 2015, you must first complete corrective action of the insufficient well height and lack of a sanitary seal on the well casing significant deficiencies outlined in the Order and provide the EPA photographic evidence of completion.

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties of up to \$37,500 per day of violation.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact Kathelene Brainich at (303) 312-6481.

Sincerely,

Kimberly Pardue-Welch, Team Lead  
Drinking Water Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: WY DEQ & WY DOH (via email)  
Tina Artemis, EPA Regional Hearing Clerk