

R8 Hearing Clerk

From: Brookins, Rachel
Sent: Wednesday, July 31, 2024 8:58 AM
To: corryat@churchofjesuschrist.org
Cc: d.north@natronacounty-wy.gov; R8 Hearing Clerk; jan.haase@churchofjesuschrist.org; drinkingwater@churchofjesuschrist.org; Lee, Dale; Anthony Rivers; Ashley Stegeman; Ellis, Bradley; Clay Vanhouten; Lewis, Dennis; Doug Evans; Erica East; Jennifer Escobedo; Justin Latham; Hendon2, Keenan; Kim Parker; Lillian Freed; Lorraine Werner; Baron, Mark; markp; Matthew Peterson; Ruth Heald; Sara Budge; Sarah Geffre; stanley.miller@wyo.gov; Tyrel Owens; Harris, Jamie S. (she/her/hers); Bedell, Emily; Shalkey, Jane; Latino, Steven; Cantor, Tiffany; Tyson, Elizabeth; Bell, Marlon; Stanton, Noah; Swanson, Amy; Wells, Ellen; Detty, Joan; Tourney, Seth; StClair, Kyle (he/him/his)
Subject: Closure of Emergency Administrative Order – MHVC 66 Ranch (WY5601446) Docket No. SDWA-08-2024-0035, Natrona County

Good morning,

The EPA has decided to close the Emergency Administrative Order (Order) regarding the MHVC 66 Ranch Public Water System. The EPA has determined that there are no remaining requirements of the Order. System improvements included disinfecting and flushing of the frost-free hydrant utilized for collecting coliform samples.

You may discontinue collecting weekly “special” samples and resume your regular, monthly routine total coliform sampling.

Please be aware that the Level 2 Assessment is still open, and you are required to comply with all remaining requirements detailed in it. Please coordinate with Jamie Harris on these requirements.

Please also be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact me.

Rachel Brookins, P.E.

EPA Region 8 | ECAD | SDWA Enforcement Unit
303.312.6509 | Brookins.Rachel@epa.gov