



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2007 APR 27 AM 8:33

APR 27 2007

EPA REGION VIII
HEARING CLERK

Ref: 8 ENF-W

CERTIFIED MAIL LETTER
RETURN RECEIPT REQUESTED

Amanda Eckdahl and Dale Eckdahl
Mountain High Resorts, Inc.
WyColo Lodge
4039 Hwy 230
Laramie, WY 82070

RE: Violation of Emergency Administrative
Order issued under Section 1431 SDWA
concerning the WyColo Lodge
PWS ID #: 5601558
Docket No. SDWA-08-2007-0044

Dear Mr. and Ms. Eckdahl:

On April 4, 2007, the US Environmental Protection Agency (EPA) issued an Emergency Administrative Order (EAO) to the two of you and to Mountain High Resorts Inc., a corporation for which the two of you are the sole directors. The EAO was prompted by findings of coliform contamination in the public water supply system at the WyColo Lodge.

Among other things, the EAO directed you, within 10 days of the April 4, 2007 EAO, to:

- a. investigate and identify the cause of *E. coli* and fecal coliform positive contamination in the WyColo Lodge public water system,
- b. apply for a permit from DEQ to install continuous disinfection,
- c. install continuous disinfection,
- d. have a cross connection survey completed by a qualified cross connection surveyor, and
- e. remedy any cross connections or potential cross connections.

[EAO, paragraph D.1, Page 10]

Our records indicate that you failed to perform all of the above mentioned requirements within the 10-day time period.



EPA is considering additional enforcement action as a result of your non-compliance with the EAO. Violating an Administrative Order may lead to (1) a penalty of up to \$32,500 per day per violation of the EAO, and/or (2) a court injunction ordering compliance.

If you have any questions or wish to have an informal conference with EPA, you may contact Peggy Livingston, Enforcement Attorney, at (303) 312-6858 or at the following address:

Peggy Livingston
Enforcement Attorney
U.S. EPA, Region 8 (8-ENF-L)
1595 Wynkoop Street
Denver, Colorado 80202

We urge your prompt attention to this matter.

Sincerely,



Lisa Kahn, Team Leader
Drinking Water Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WDEQ (via email)
WDH (via email)