

R8 Hearing Clerk

From: Carballal-Broome, Christina
Sent: Thursday, December 26, 2024 12:01 PM
To: chipmarvin@gmail.com; clearwateroperations@gmail.com
Cc: Ashley Stegeman; Clay Vanhouten; Lewis, Dennis; Doug Evans; Erica East; Fernandez, Jason; Jennifer Escobedo; Justin Latham; Hendon2, Keenan; Kim Parker; Lorraine Werner; Baron, Mark; markp; Matthew Peterson; Ruth Heald; Sara Budge; Sarah Geffre; stanley.miller@wyo.gov; Tyrel Owens; R8 Hearing Clerk; Cantor, Tiffany; Rathbone, Colleen (she/her/hers); Wells, Ellen; Detty, Joan; Bearley, Mia; Langenfeld, Matthew; Harris, Jamie S. (she/her/hers); Bertelmann, Bolor; Sharma, Pragati
Subject: Closure Squaw Creek Water District Emergency Administrative Order PWSID #WY5600737, Docket No. SDWA-08-2024-0034, Teton County, WY

The EPA has decided to close the Squaw Creek Water District Public Water System Emergency Administrative Order (Order). The EPA has determined that the emergency requirements of the Order have been corrected.

Outside the scope of the above-referenced closed Order, the Squaw Creek Water District Public Water System (System) has uncorrected open significant deficiencies regarding necessary tank hatch improvements. Specifically, the System's upper tanks ST01, ST02, ST03, and ST04 System are in need of corrective actions, as outlined in EPA's Sanitary Survey Report emailed to you on February 21, 2024. EPA is tracking these significant deficiencies under the Ground Water Rule and encourages you to continue to work with Matt Langenfeld, Region 8 Groundwater Rule Manager, to determine next steps and to address any questions or concerns you might have about necessary actions.

Finally, please be aware that you are still required to comply with all National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for your attention to these matters. If you have any questions, please feel free to contact me.

Christina Carballal

U.S. EPA – Region 8 | SDWA Enforcement | 8ECA-W-S |
1595 Wynkoop Street, Denver, CO 80202 | Phone: 303.312.6046 |