6/15/2023

10:09 AM

Received by

EPA Region VIII Hearing Clerk

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 8

IN THE MATTER OF: Wrangler Estates, Inc. Nespondent. Wrangler Estates Public Water System PWS ID #WY5601474

1. This Order is issued under the authority vested in the Administrator of the United States Environmental Protection Agency (EPA) by section 1414(g) of the Safe Drinking Water Act (Act), 42 U.S.C. § 300g-3(g), as properly delegated to the undersigned official.

2. Wrangler Estates, Inc. (Respondent) is a Wyoming corporation that owns and operates the Wrangler Estates Public Water System (System), which provides piped water to the public in Campbell County, Wyoming, for human consumption.

3. The System is supplied by a groundwater source accessed via two wells. The water is treated by being pumped through a gaseous chlorination system.

4. The System has approximately 87 service connections and regularly serves an average of approximately 250 year-round residents. Therefore, the System is a "public water system" and a "community water system" as defined in 40 C.F.R. § 141.2 and section 1401 of the Act, 42 U.S.C. § 300f.

5. Respondent is a "person" as defined in section 1401(12) of the Act, 42 U.S.C. § 300f(12), and is subject to the Act and 40 C.F.R. part 141 (Part 141). Part 141 is an "applicable requirement" as defined in section 1414(i) of the Act, 42 U.S.C. § 300g-3(i).

6. Part 141 includes monitoring requirements. The EPA has sent Respondent annual notifications of the specific monitoring requirements that apply to the System.

VIOLATIONS

7. Respondent is required to complete corrective action of a significant deficiency or comply with an EPA-approved corrective action plan and schedule within 120 calendar days (or earlier if instructed by the EPA) of receiving written notification from the EPA of a significant deficiency. 40 C.F.R. § 141.404(a). Respondent is required to notify the EPA within 30 calendar days of completion of a significant deficiency corrective action. 40 C.F.R. § 141.405(a)(2). The EPA sent the Respondent a sanitary survey report dated October 28, 2019, which detailed significant deficiencies. The EPA approved a corrective action schedule to complete corrective actions by March 25, 2021, and extended to December 11, 2021. The EPA's record reflects that the Respondent failed to complete all corrective actions by December 11, 2021, and therefore, violated this requirement.

Wrangler Estates, Inc Wrangler Estates Public Water System ECN: 600.0182.2023_Wrangler Page 2 of 4

8. Respondent is required to monitor the System's water for certain radionuclides once every six years. 40 C.F.R. § 141.26(a). Respondent failed to monitor the System's water for radionuclides during the 2014 to 2019 monitoring period, and therefore, violated this requirement.

9. Respondent is required to notify the public of certain violations of Part 141 and, within 10 calendar days after completing public notice, provide a copy of the public notice and certification to the EPA. 40 C.F.R. §§ 141.31(d) and 141.201-141.211. The violation identified in paragraph 7, above, is classified as a violation requiring Tier 2 public notice within 30 calendar days, according to 40 C.F.R. § 141.203. The EPA's records reflect that the Respondent failed to notify the public of the violation cited in paragraph 7 and failed to submit a copy of the public notice and certification to the EPA and therefore, violated this requirement.

10. Respondent is required to report any failure to comply with any Part 141 to the EPA within 48 hours (except where Part 141 specifies a different time period). 40 C.F.R. § 141.31(b). Respondent failed to report the violations cited in paragraphs 7 and 8, above, to the EPA and therefore, violated this requirement.

<u>ORDER</u>

Respondent is ordered to perform the following actions upon Respondent's receipt of this Order (unless a different deadline is specified below):

11. Respondent is ordered to comply with all provisions of the Act and Part 141, including but not limited to each requirement cited above.

12. Within 30 calendar days of receipt of this Order, Respondent shall consult with the EPA regarding action to correct significant deficiencies and shall submit a proposed schedule and plan to the EPA for completion of all corrective actions specified below. The plan shall include proposed modifications to the System and estimated costs of modifications. The EPA will review the proposed schedule and any approved schedule (Schedule) shall be incorporated into this Order with each milestone to be an enforceable requirement upon written approval by the EPA. Within 10 calendar days after completing all tasks included in the Schedule, Respondent shall notify the EPA of the project's completion. Respondent shall provide sufficient evidence of the project's completion to the EPA, including photographs of the corrective actions. Thereafter, if the EPA identifies any significant deficiency at the System, Respondent shall complete corrective action for each significant deficiency and provide notification to the EPA within 30 calendar days of completion, as required by 40 C.F.R. §§ 141.403(a) and 141.405(a)(2).

Corrective Actions:

- Tank ST01: The air vent and access hatch for Tank ST01 NW Storage Tank must be inspected and the structure/condition compared to the Tech Tips for Finished Water Storage Facilities.
- Tank ST01: The air vent on Tank ST01 NW Storage Tank must have a solid cover to prevent rain and blown debris from entering the tank.

Wrangler Estates, Inc Wrangler Estates Public Water System ECN: 600.0182.2023_Wrangler Page 3 of 4

- Tank ST02: The air vent and access hatch for Tank ST02 SE Storage Tank must be inspected and the structure/condition compared to the Tech Tips for Finished Water Storage Facilities.
- Tank ST02: The air vent on Tank ST02 SE Storage Tank must have a solid cover to prevent rain and blown debris from entering the tank.
- Well WL01: Maki #1 must be fitted with a functioning sanitary seal that is tightly bolted and does not allow contamination to enter the well.
- Well WL02: Maki #2 must be fitted with a functioning sanitary seal that is tightly bolted and does not allow contamination to enter the well.

13. Respondent shall monitor the System's water for radionuclides in accordance with 40 C.F.R. § 141.26(a). Respondent is next required to sample for radionuclides during the 2021 through 2026 monitoring period. Respondent shall report results to the EPA within the first 10 calendar days following the end of the required monitoring period. 40 C.F.R. § 141.31(a).

14. Within 30 calendar days after receipt of this Order, and quarterly thereafter as long as the violation cited in paragraph 7, above, persists, Respondent shall notify the public of this violation. Thereafter, following any future violation of Part 141, Respondent shall comply with any applicable public notice provisions of 40 C.F.R. part 141, subpart Q. Within 10 calendar days after providing public notice, Respondent shall submit a copy of the notice and certification to the EPA. 40 C.F.R. § 141.31(d). Templates and instructions are available at: https://www.epa.gov/region8-waterops/reporting-forms-drinking-water-systems-wyoming-and-tribal-lands-epa-region-8#pn.

15. Respondent shall report any violation of Part 141 to the EPA within 48 hours of the violation occurring, as required by 40 C.F.R. § 141.31(b). However, if a different time period for reporting is specified in this Order or Part 141, Respondent shall report within that different period.

16. If Respondent (a) leases or sells the System to another person or entity, or (b) contracts with or hires any other person or entity to operate the System, Respondent must, within 10 calendar days, provide a copy of this Order to the lessee, purchaser, or contractor and notify the EPA in writing of the change. In either of these circumstances, Respondent will remain obligated to comply with this Order.

17. Respondent must send all reporting and notifications required by this Order to the EPA at:

Email: R8DWU@epa.gov, and latino.steven@epa.gov

GENERAL PROVISIONS

18. This Order is binding on Respondent, its successors and assigns, and any person (*e.g.*, employee, contractor, or other agent) acting in concert with Respondent.

19. This Order does not constitute a waiver, suspension, or modification of any requirement of the Act or Part 141. Issuance of this Order is not an election by the EPA to forgo any civil or criminal action.

Wrangler Estates, Inc Wrangler Estates Public Water System ECN: 600.0182.2023_Wrangler Page 4 of 4

20. Violation of any part of this Order, the Act, or Part 141 may subject Respondent to a civil penalty of up to \$67,544 (as adjusted for inflation) per day of violation, a court injunction ordering compliance, or both. 42 U.S.C. § 300g-3; 40 C.F.R. part 19; 88 Fed. Reg. at 989 (January 6, 2023).

21. Respondent may seek federal judicial review of this Order pursuant to section 1448(a) of the Act, 42 U.S.C. § 300j-7(a).

Issued: June 13, 2023.

Colleen Rathbone, Branch Manager Water Enforcement Branch Enforcement and Compliance Assurance Division