

NPDES ID	Outfall	Monitoring Period End Date	DMR Value Received Date	Statistical Base Long Desc	Parameter	Limit Value	Limit Unit Desc	DMR Value
KS0079243	001	12/31/2015	1/1/2016	Monthly Geometric	E. coli	2358	Number per 100 Milliliters	2419.99
KS0079243	001	12/31/2015	1/1/2016	Monthly Average	Solids, total suspended	30	Milligrams per Liter	64
KS0079243	001	12/31/2015	1/1/2016	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	64
KS0079243	001	1/31/2016	2/1/2016	Monthly Average	BOD, 5-day, 20 deg. C	30	Milligrams per Liter	73
KS0079243	001	1/31/2016	2/1/2016	Maximum Weekly Average	BOD, 5-day, 20 deg. C	45	Milligrams per Liter	73
KS0079243	001	1/31/2016	2/1/2016	Monthly Geometric	E. coli	2358	Number per 100 Milliliters	2419.99
KS0079243	001	1/31/2016	2/1/2016	Monthly Average	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	31.4
KS0079243	001	1/31/2016	2/1/2016	Daily Maximum	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	31.4
KS0079243	001	1/31/2016	2/1/2016	Monthly Average	Solids, total suspended	30	Milligrams per Liter	68
KS0079243	001	1/31/2016	2/1/2016	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	68
KS0079243	001	4/30/2016	5/1/2016	Daily Minimum	pH	6	Standard Units	4.81
KS0079243	001	4/30/2016	5/1/2016	Monthly Average	Solids, total suspended	30	Milligrams per Liter	62
KS0079243	001	4/30/2016	5/1/2016	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	62
KS0079243	001	5/31/2016	6/1/2016	Monthly Geometric	E. coli	160	Number per 100 Milliliters	2419.99
KS0079243	001	5/31/2016	6/1/2016	Monthly Average	Solids, total suspended	30	Milligrams per Liter	45
KS0079243	001	9/30/2016	10/1/2016	Monthly Geometric	E. coli	160	Number per 100 Milliliters	687
KS0079243	001	11/30/2016	12/1/2016	Monthly Geometric	E. coli	2358	Number per 100 Milliliters	2419.99
KS0079243	001	11/30/2016	12/1/2016	Monthly Average	Solids, total suspended	30	Milligrams per Liter	36
KS0079243	001	2/28/2017	3/1/2017	Monthly Average	Solids, total suspended	30	Milligrams per Liter	32
KS0079243	001	4/30/2017	5/1/2017	Monthly Geometric	E. coli	160	Number per 100 Milliliters	461
KS0079243	001	5/31/2017	6/1/2017	Monthly Geometric	E. coli	160	Number per 100 Milliliters	2419.99
KS0079243	001	6/30/2017	7/1/2017	Monthly Geometric	E. coli	160	Number per 100 Milliliters	411
KS0079243	001	10/31/2017	11/1/2017	Daily Minimum	pH	6	Standard Units	5.17
KS0079243	001	11/30/2017	12/1/2017	Monthly Average	BOD, 5-day, 20 deg. C	30	Milligrams per Liter	37
KS0079243	001	11/30/2017	12/1/2017	Monthly Average	Solids, total suspended	30	Milligrams per Liter	137
KS0079243	001	11/30/2017	12/1/2017	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	137
KS0079243	001	12/31/2017	1/1/2018	Daily Minimum	pH	6	Standard Units	5.41
KS0079243	001	12/31/2017	1/1/2018	Monthly Average	Solids, total suspended	30	Milligrams per Liter	136
KS0079243	001	12/31/2017	1/1/2018	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	136
KS0079243	001	1/31/2018	2/1/2018	Daily Minimum	pH	6	Standard Units	5.48
KS0079243	001	1/31/2018	2/1/2018	Monthly Average	Solids, total suspended	30	Milligrams per Liter	89
KS0079243	001	1/31/2018	2/1/2018	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	89
KS0079243	001	2/28/2018	3/1/2018	Daily Minimum	pH	6	Standard Units	5.64
KS0079243	001	2/28/2018	3/1/2018	Monthly Average	Solids, total suspended	30	Milligrams per Liter	64
KS0079243	001	2/28/2018	3/1/2018	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	64
KS0079243	001	3/31/2018	4/1/2018	Daily Minimum	pH	6	Standard Units	5.49
KS0079243	001	3/31/2018	4/1/2018	Monthly Average	Solids, total suspended	30	Milligrams per Liter	74
KS0079243	001	3/31/2018	4/1/2018	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	74
KS0079243	001	4/30/2018	5/1/2018	Monthly Average	Solids, total suspended	30	Milligrams per Liter	46
KS0079243	001	4/30/2018	5/1/2018	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	46
KS0079243	001	5/31/2018	6/1/2018	Monthly Average	Solids, total suspended	30	Milligrams per Liter	32
KS0079243	001	6/30/2018	7/1/2018	Daily Minimum	pH	6	Standard Units	4.55
KS0079243	001	6/30/2018	7/1/2018	Monthly Average	Solids, total suspended	30	Milligrams per Liter	43
KS0079243	001	7/31/2018	8/1/2018	Monthly Average	Nitrogen, ammonia total [as N]	12.6	Milligrams per Liter	15.2
KS0079243	001	7/31/2018	8/1/2018	Monthly Average	Solids, total suspended	30	Milligrams per Liter	72
KS0079243	001	7/31/2018	8/1/2018	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	72
KS0079243	001	8/31/2018	9/1/2018	Monthly Geometric	E. coli	160	Number per 100 Milliliters	344.999
KS0079243	001	8/31/2018	9/1/2018	Monthly Average	Nitrogen, ammonia total [as N]	12.6	Milligrams per Liter	35.4
KS0079243	001	8/31/2018	9/1/2018	Daily Maximum	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	35.4
KS0079243	001	9/30/2018	10/1/2018	Monthly Geometric	E. coli	160	Number per 100 Milliliters	308
KS0079243	001	9/30/2018	10/1/2018	Monthly Average	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	43.9

Received by
EPA Region 7
Hearing Clerk

KS0079243	001		9/30/2018	10/1/2018	Daily Maximum	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	43.9
KS0079243	001		10/31/2018	11/1/2018	Monthly Geometric	E. coli	160	Number per 100 Milliliters	866
KS0079243	001		12/31/2018	1/1/2019	Monthly Geometric	E. coli	2358	Number per 100 Milliliters	2419.99
KS0079243	001		12/31/2018	1/1/2019	Monthly Average	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	31.8
KS0079243	001		12/31/2018	1/1/2019	Daily Maximum	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	31.8
KS0079243	001		1/31/2019	2/1/2019	Monthly Average	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	22
KS0079243	001		1/31/2019	2/1/2019	Daily Maximum	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	22
KS0079243	001		2/28/2019	3/1/2019	Monthly Average	BOD, 5-day, 20 deg. C	30	Milligrams per Liter	69.5
KS0079243	001		2/28/2019	3/1/2019	Maximum Weekly Average	BOD, 5-day, 20 deg. C	45	Milligrams per Liter	69.5
KS0079243	001		2/28/2019	3/1/2019	Monthly Geometric	E. coli	2358	Number per 100 Milliliters	2419.99
KS0079243	001		2/28/2019	3/1/2019	Monthly Average	Solids, total suspended	30	Milligrams per Liter	100
KS0079243	001		2/28/2019	3/1/2019	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	100
KS0079243	001		3/31/2019	4/1/2019	Monthly Average	Solids, total suspended	30	Milligrams per Liter	32.2
KS0079243	001		4/30/2019	5/1/2019	Monthly Average	Solids, total suspended	30	Milligrams per Liter	44
KS0079243	001		5/31/2019	6/1/2019	Monthly Geometric	E. coli	160	Number per 100 Milliliters	2419.99
KS0079243	001		5/31/2019	6/1/2019	Monthly Average	Solids, total suspended	30	Milligrams per Liter	31.8
KS0079243	001		6/30/2019	7/1/2019	Monthly Geometric	E. coli	160	Number per 100 Milliliters	1550
KS0079243	001		6/30/2019	7/1/2019	Monthly Average	Solids, total suspended	30	Milligrams per Liter	32.3
KS0079243	001		7/31/2019	8/1/2019	Monthly Geometric	E. coli	160	Number per 100 Milliliters	548
KS0079243	001		7/31/2019	8/1/2019	Monthly Average	Nitrogen, ammonia total [as N]	12.6	Milligrams per Liter	13.6
KS0079243	001		8/31/2019	9/1/2019	Monthly Geometric	E. coli	160	Number per 100 Milliliters	2419.99
KS0079243	001		9/30/2019	10/1/2019	Daily Minimum	pH	6	Standard Units	5.9
KS0079243	001		11/30/2019	12/1/2019	Monthly Average	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	51.9
KS0079243	001		11/30/2019	12/1/2019	Daily Maximum	Nitrogen, ammonia total [as N]	17.3	Milligrams per Liter	51.9
KS0079243	001		12/31/2019	1/1/2020	Daily Minimum	pH	6	Standard Units	5.2
KS0079243	001		12/31/2019	1/1/2020	Monthly Average	Solids, total suspended	30	Milligrams per Liter	50
KS0079243	001		12/31/2019	1/1/2020	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	50
KS0079243	001		1/31/2020	2/1/2020	Daily Minimum	pH	6	Standard Units	5.1
KS0079243	001		1/31/2020	2/1/2020	Monthly Average	Solids, total suspended	30	Milligrams per Liter	97
KS0079243	001		1/31/2020	2/1/2020	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	97
KS0079243	001		2/29/2020	3/1/2020	Monthly Average	Solids, total suspended	30	Milligrams per Liter	36.5
KS0079243	001		3/31/2020	4/1/2020	Monthly Average	Solids, total suspended	30	Milligrams per Liter	30.5
KS0079243	001		4/30/2020	5/1/2020	Daily Minimum	pH	6	Standard Units	5
KS0079243	001		4/30/2020	5/1/2020	Monthly Average	Solids, total suspended	30	Milligrams per Liter	81.2
KS0079243	001		4/30/2020	5/1/2020	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	81.2
KS0079243	001		5/31/2020	6/1/2020	Daily Minimum	pH	6	Standard Units	4.9
KS0079243	001		5/31/2020	6/1/2020	Monthly Average	Solids, total suspended	30	Milligrams per Liter	57.3
KS0079243	001		5/31/2020	6/1/2020	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	57.3
KS0079243	001		6/30/2020	7/1/2020	Monthly Geometric	E. coli	160	Number per 100 Milliliters	4839.99
KS0079243	001		7/31/2020	8/1/2020	Daily Minimum	pH	6	Standard Units	5.7
KS0079243	001		8/31/2020	9/1/2020	Daily Minimum	pH	6	Standard Units	4.7
KS0079243	001		8/31/2020	9/1/2020	Monthly Average	Solids, total suspended	30	Milligrams per Liter	32.8
KS0079243	001		9/30/2020	10/1/2020	Daily Minimum	pH	6	Standard Units	4.3
KS0079243	001		9/30/2020	10/1/2020	Monthly Average	Solids, total suspended	30	Milligrams per Liter	56.7
KS0079243	001		9/30/2020	10/1/2020	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	56.7
KS0079243	001		10/31/2020	11/1/2020	Daily Minimum	pH	6	Standard Units	4.8
KS0079243	001		11/30/2020	12/1/2020	Daily Minimum	pH	6	Standard Units	4.8
KS0079243	001		11/30/2020	12/1/2020	Monthly Average	Solids, total suspended	30	Milligrams per Liter	62
KS0079243	001		11/30/2020	12/1/2020	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	62
KS0079243	001		12/31/2020	1/1/2021	Monthly Average	BOD, 5-day, 20 deg. C	30	Milligrams per Liter	37.1
KS0079243	001		12/31/2020	1/1/2021	Monthly Average	Nitrogen, ammonia total [as N]	18.1	Milligrams per Liter	25.3
KS0079243	001		12/31/2020	1/1/2021	Daily Maximum	Nitrogen, ammonia total [as N]	18.1	Milligrams per Liter	25.3

KS0079243	001	12/31/2020	1/1/2021	Monthly Average	Solids, total suspended	30	Milligrams per Liter	86
KS0079243	001	12/31/2020	1/1/2021	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	86
KS0079243	001	1/31/2021	2/1/2021	Monthly Average	Nitrogen, ammonia total [as N]	18.1	Milligrams per Liter	35.7
KS0079243	001	1/31/2021	2/1/2021	Daily Maximum	Nitrogen, ammonia total [as N]	18.1	Milligrams per Liter	35.7
KS0079243	001	2/28/2021	3/1/2021	Monthly Geometric	E. coli	2358	Number per 100 Milliliters	20342.5
KS0079243	001	3/31/2021	4/1/2021	Monthly Average	Solids, total suspended	30	Milligrams per Liter	45.3
KS0079243	001	3/31/2021	4/1/2021	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	45.3
KS0079243	001	4/30/2021	5/1/2021	Monthly Geometric	E. coli	160	Number per 100 Milliliters	368
KS0079243	001	5/31/2021	6/1/2021	Monthly Average	BOD, 5-day, 20 deg. C	30	Milligrams per Liter	36.4
KS0079243	001	5/31/2021	6/1/2021	Monthly Average	Solids, total suspended	30	Milligrams per Liter	78
KS0079243	001	5/31/2021	6/1/2021	Maximum Weekly Average	Solids, total suspended	45	Milligrams per Liter	78
KS0079243	001	6/30/2021	7/1/2021	Monthly Average	Solids, total suspended	30	Milligrams per Liter	37
KS0079243	001	7/31/2021	8/1/2021	Monthly Geometric	E. coli	160	Number per 100 Milliliters	3650
KS0079243	001	8/31/2021	9/1/2021	Daily Minimum	pH	6	Standard Units	5.2