



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2007 NOV 13 AM 8:42

Ref: ENF-W

EPA REGION VIII  
HEARING OFFICE

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

William T. Bass, Forest Supervisor  
USDA Forest Service, Bighorn National Forest  
2013 Eastside 2<sup>nd</sup> Street  
Sheridan, WY 82801

Re: Administrative Order Addendum  
Sibley Lake Campground  
Bighorn National Forest  
Docket No. SDWA-08-2007-0034  
PWS ID #WY5680231

Dear Mr. Bass:

This Addendum to the Administrative Order issued by the U.S. Environmental Protection Agency to the USDA Forest Service on March 13, 2007 incorporates the schedule for treatment and modification completion outlined in the September 25, 2007 letter from Esther Fishbaugh of Gallatin Canyon Campgrounds on behalf of the Sibley Lake Campground public water system (PWS). In addition to serving as the Addendum to the March 13, 2007 Administrative Order, this letter constitutes EPA's written approval of the schedule set forth in this Addendum. The effect of today's approval is to incorporate the following schedule into the Administrative Order. Each deadline in the schedule will be enforceable as if it were part of the Administrative Order itself. Please note that any modifications to the drinking water system must also be approved by the State prior to construction.

EPA acknowledges that the PWS has taken steps to bring the drinking water system into compliance with the total coliform MCL. These steps include installing faucets with backflow prevention on all service outlets; pressurizing the system to check for leaks; cleaning silt buildup and sanitizing and flushing the system at the beginning and middle of the season; installing check valves for three faucets that are located higher than the tank (in order to prevent the possibility of backflow); and resetting the pressure tank to between 35 – 50 psi to improve faucet operation.

The following schedule lists the action to be taken, deadline date and completion date if applicable.

<u>Action</u>	<u>Deadline</u>	<u>Completion</u>
Submit to EPA detailed plans for bringing the System into compliance with maximum contaminant levels (MCL) for total coliform	September 30, 2007	September 26, 2007
Lower the storage tank float to reduce water level in the tank below 500 gallons in an effort to decrease the likelihood of stagnant water in the tank	June 2008	
Extend the Sibley Well # 2 casing so that it terminates at least 18" above the concrete slab to provide protection against surface runoff and drainage problems	July 2008	
Construct a fence surrounding the wellhead to provide protection from unauthorized intrusion	July 2008	
If needed, extend the drop pipe (sucker pipe) further into the well to keep water drawdown from being too close to the pump intake	As needed	
If Sibley Lake fails to comply with the total coliform MCLs during the 2008 season, the PWS will purchase and install a UV system	July 2009	
Issue public notice for violations included in the Administrative Order.	May 31, 2008	

Please be advised that the Sibley Lake Campground is required to comply with all provisions of the Administrative Order. Penalties for failing to comply are set forth in the Order. Please contact Kimberly Pardue Welch at (303) 312-6983 if you have any questions concerning this Addendum. If you are represented by an attorney, please ask your attorney to call Jessie Goldfarb at the above 800 number, extension 6926, or at (303) 312-6926.

Sincerely,



Diane L. Sipe, Director  
Technical Enforcement Program  
Office of Compliance, Enforcement,  
and Environmental Justice



David J. Janik, Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: Esther Fishbaugh, Gallatin Canyon Campgrounds  
Bruce Kjerstad, Civil Engineer Technician, Bighorn National Forest  
WY DEQ (via email)  
WY DOH (via email)

