



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 5

77 WEST JACKSON BOULEVARD

CHICAGO, IL 60604-3590

JUN 28 2018

REPLY TO THE ATTENTION OF:

CERTIFIED MAIL #7009 1680 0000 7647 3125
RETURN RECEIPT REQUESTED

Colonel Robert L. Henderson
Commander, 375th Mission Support Group
206 West Bucher Street
Scott AFB, Illinois 62225

Re: Notice of Violation and Compliance Order/Settlement Agreement for USTs at the building 565 facility, Scott Air Force Base, Illinois **RUST-05-2018-0011**

Dear Colonel Henderson:


On June 21, 2016, the U.S. Environmental Protection Agency, Underground Storage Tank (UST) Section, conducted an inspection with the Illinois Office of the State Fire Marshal at Scott Air Force Base, located at 206 West Bucher Street, Scott AFB, Illinois. Several UST violations were identified and conveyed to Scott AFB informally after the inspections (i.e., verbally and via emails), in an EPA November, 30, 2017 Notice of Violation letter (NOV), and in an EPA April 18, 2018 NOV letter.

The April 18, 2018, Notice of Violation and a Compliance Order/Settlement Agreement (Field Citation) was issued to address the remaining UST violation (i.e., failure to provide adequate overfill protection for two of the remaining UST at building 565) which was unaddressed and to close the case. We have received your signed copy of the Settlement Agreement, dated May 30, 2018 and the check for a total of \$250 in penalties. On March 09, 2018, we received the last supporting documentation on recent installation and testing for the overfill prevention violation.

The Settlement Agreement states that it is effective upon EPA's final approval. I have enclosed a signed and dated copy of the approved Settlement Agreement. The original Settlement Agreement will remain in the EPA's files. We also have accepted and processed your check (#1019) as part of the settlement process. This letter will serve to document closure of FC and all other UST issues/violations identified during the June, 2018 inspection and in the above referenced documents (i.e., NOV's).

If you have any further questions, please feel free to contact Arturo Cisneros, of my staff, at 312/886-7447.

Sincerely,

A handwritten signature in cursive script that reads "Gary J. Victorine". The signature is written in black ink and is positioned above the printed name and title.

Gary J. Victorine, Chief
RCRA Branch

cc: Fred Schneller, Illinois OSFM

U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA) REGION 5
77 West Jackson Boulevard (LR-8J), Chicago, Illinois 60604-3590
UNDERGROUND STORAGE TANK (UST) FIELD CITATION FORM FOR EXPEDITED SETTLEMENT NO. R5-UST-18-010-AC

PART I: INSPECTION SUMMARY

On: 04/16/2018 Time: 09:58 AM

At: Scott Air Force Base
 Address: 206 West Bucher Street
Scott AFB, IL 62225

Ms. Carla Daggitt
 (Name of Site Representative if not the Owner or Operator)

Name and address of the UST Operator

Name: Scott Air Force Base
 Address: 206 West Bucher Street
Scott AFB, IL 62225

A duly designated officer, employee, or representative of the EPA or a duly designated officer or employee of the State or Tribe inspected this facility. EPA has reviewed the inspection report and other relevant materials and has identified the following violation(s) of the UST regulations promulgated or approved by EPA under Subtitle I of the Resource Conservation and Recovery Act (RCRA) (42 U.S.C. § 6991 et seq).

1. Violation: Installation of inadequate overfill prevention equipment in a new tank

Cite: 40 CFR 280.20(c)(1)(ii) Proposed Penalty: \$250

2. Violation:

Cite: 40 CFR Proposed Penalty:

3. Violation:

Cite: 40 CFR Proposed Penalty:

4. Violation:

Cite: 40 CFR Proposed Penalty:

TOTAL PROPOSED PENALTY: \$250

EPA finds the Owner or Operator in violation of the above referenced UST regulations.

[Signature]
 (Signature of EPA Inspector)

4-16-18
 (Date)

Part II: SETTLEMENT AGREEMENT/COMPLIANCE ORDER

A. Settlement Agreement: The Owner or Operator by signing this Settlement Agreement (or by having an authorized representative sign it) agrees to settle the violations identified in Part I, subject to the following terms and conditions:

The Owner or Operator certifies, subject to civil and criminal penalties for making a false submission to the U. S. Government, that he or she has corrected the violations, submitted true and accurate documentation of their correction, and submitted payment to the U.S. Treasury for the amount of \$250 in payment of the full proposed penalty amount, as described in Part I of this Form.

The Owner or Operator agrees to comply with the terms of the Compliance Order in Part II.B. Without admitting liability for the violations cited in Part I, the Owner or Operator signing below waives any objections to EPA's jurisdiction with respect to the Compliance Order and this Settlement Agreement, and consents to EPA's final approval of this Settlement Agreement without further notice. The Owner or Operator waives the opportunity for a public hearing pursuant to RCRA section 9006.

Once EPA signs the Settlement Agreement, EPA will take no further enforcement action against the Owner or Operator for the civil violations described in Part I, provided the violations have been timely corrected and the penalty has been paid. EPA does not waive its right to enforce against the Owner or Operator for any other violations not described in Part I and violations of the UST requirements or other requirements listed in Part I that were not corrected in a timely manner.

This Settlement Agreement and Compliance Order will become effective once signed by EPA and is binding on EPA and the Owner or Operator upon signature by both parties. Final approval of the Settlement Agreement and Compliance Order is in the sole discretion of the Regional Administrator, Region 5, EPA, or his or her authorized delegate. Upon final approval, EPA shall mail a copy of this document to the Owner or Operator signing below.

SIGNATURE BY OWNER, OPERATOR, OR AUTHORIZED REPRESENTATIVE:

Name (Print): Col Robert L. Henderson
 Title (Print): 375 Mission Support Group Comander
 Signature: HENDERSON,ROBERT.L Digitally signed by HENDERSON,ROBERT.L. DN: cn=ROBERT.L.HENDERSON, o=EPA, ou=Region 5, email=robert.l.henderson@epa.gov, c=US, date=2018.05.17 06:16:17 -0500 Date: 30 May 18

B. Compliance Order: This Compliance Order is issued under the authority of RCRA section 9006 to resolve the civil violations identified in Part I. The Owner or Operator is ordered to correct the violations, submit true and accurate documentation that the violations were corrected, and pay the total penalty amount listed in Part I of this Form. This Compliance Order shall become final and enforceable only upon signature by an EPA official with the authority to sign this document.

Name (Print): Gary J. Victorine
 Title (Print): Chief RCRA BRANCH
 Signature: [Signature] Date: 6/28/18

Notes:

RUST-05-2018-0011

