



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

1595 WYNKOOP STREET
DENVER, COLORADO 80202-1129
Phone 800-227-8917

<http://www.epa.gov/region08>

2011 JUL -5 PM 12:48

FILED
EPA REGION VIII
HEARING CLERK

Ref: 8ENF-W

JUL 05 2011

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Doris Sherman
POB 20431
Cheyenne, WY 82003

Re: Administrative Order Addendum
Doris Sherman
Restway Travel Park Public Water System
Docket No. SDWA-08-2010-0009
PWS ID #5601292

Dear Ms. Sherman:

This Addendum to the Administrative Order (Order) issued to you on December 30, 2009, approves the plan submitted to EPA on May 25, 2011. The plan is hereby incorporated into the Order to address the August 30, 2010, total coliform maximum contaminant level (MCL) violation in lieu of installation of disinfection. All requirements of the Order remain in effect, including installation and continuous operation of disinfection equipment or processes within 30 days if the system's water again exceeds the total coliform MCL (page 2, paragraph 8).


<u>Action</u>	<u>Completion Date</u>
Raise access points/pipes to the cistern from ground level to 18" above ground level and replace the access cap on the cistern to prevent surface debris and water from entering the water system.	May 25, 2011
Institute a detailed maintenance program to properly disinfect the cistern and distribution lines each year before starting up the system in the spring.	May 25, 2011
Incorporating the recommendations from WARWS, institute sanitary sampling techniques to help reduce the possibility of operator error.	May 25, 2011
Increase total coliform compliance monitoring at the system from quarterly to monthly during the operational season of June through September.	continuous




Printed on Recycled Paper

Please contact Kathelene Brainich, Environmental Specialist, at (303) 312-6481 if you have any questions concerning this Addendum.

Sincerely,



Arturo Palomares, Director
Water Technical Enforcement Program
Office of Compliance, Enforcement,
and Environmental Justice



David J. Janik, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DEQ and DOH (via email)
Tina Artemis, EPA Regional Hearing Clerk

