

**From:** [Minter, Jill](#)  
**To:** [Jimmy Chauhan](#)  
**Cc:** [Haniewicz, Melissa \(Missy\)](#); [Cantor, Tiffany](#); [Rathbone, Colleen](#); [Wells, Ellen](#); [Detty, Joan](#); [Castelli, Matthew \(he/him\)](#); [Langenfeld, Matthew](#); [Harris, Jamie S. \(she/her\)](#); [StClair, Kyle \(he/him/his\)](#); [Kahn, Lisa \(she/her\)](#); [justin.latham@wyo.gov](#); [ashley.stegeman@wyo.gov](#); [william.tillman@wyo.gov](#); [bradley.ellis@wyo.gov](#); [doug.evans@wyo.gov](#); [dennis.lewis@wyo.gov](#); [Brough, James](#); [Kim Parker](#); [Lorraine.werner@wy.usda.gov](#); [mark.baron@wyo.gov](#); [roykehs@laramiecounty.com](#); [rheald@cnchd.org](#); [sara.budge@wyo.gov](#); [geffres@sweet.wy.us](#); [stanley.miller@wyo.gov](#); [markp](#); [clay.vanhouten@wyo.gov](#)  
**Subject:** Closure of Emergency Administrative Order - Three Forks Muddy Gap (WY5601326), Docket No. SDWA-08-2020-0043, Carbon County, WY  
**Date:** Friday, October 8, 2021 5:16:03 PM

---

The EPA has decided to close the Emergency Administrative Order (Order) regarding the public water system specified in the subject line. The EPA has determined that there are no remaining requirements of the Order. System improvements included the following: 1) Installed new septic tank and leach field; 2) Installed new drain line to septic system; 3) Replaced broken water line to dump-station; 4) Repaired and replaced all broken water distribution lines; 5) Repaired and resealed pitless adaptor; 6) Installed new sump pump; 7) Cleaned well pit and crawl space; 8) Replaced well vent screen with new 24 mesh screen; and 9) Disinfected and flushed well and distribution system following all repairs.

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and penalties.

Thank you for resolving these issues. If you have questions regarding this matter, please contact me.

Jill Minter  
Enforcement Case Manager

---

Jill Minter | Drinking Water Enforcement | USEPA Region 8 (8ENF-W- SD) | 1595 Wynkoop Street |  
Denver, CO 80202-8917 | [minter.jill@epa.gov](mailto:minter.jill@epa.gov) | phone: 303-312-6084

*Beginning March 16<sup>th</sup>, I am working remotely. My phone has been forwarded, I am checking voicemail, and am always available via email. 8*