



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129

Phone 800-227-8917

<http://www.epa.gov/region08> 2009 JUN -8 PM 1:14

Ref: 8ENF-W

JUN 8 2009

CERTIFIED MAIL LETTER
RETURN RECEIPT REQUESTED

Sapp Bros Travel Center
Attn: Willie Kolkman
12500 East I-80 Service Road
Cheyenne, WY 82009

Re: Administrative Order Addendum
Docket No. SDWA-08-2009-0034
Deike Estates Improvement
and Service District
PWS ID #WY5601034

Dear Mr. Kolkman:

Pursuant to paragraph 8 of the Administrative Order (AO) issued March 4, 2009 to the Deike Estates Improvement and Service District, this Addendum to the AO incorporates the schedule for completing system modifications as outlined in the April 20, 2009 letter and April 29, 2009 email from Russell Dahlgren on behalf of the Deike Estates Improvement and Service District to EPA. This letter constitutes the written approval by EPA of the Deike Estates Improvement and Service District planned actions as indicated in the chart below. All actions must be completed by July 17, 2009, in accordance with paragraph 7 of the Order. Please be advised that the Deike Estates Improvement and Service District must continue to meet the total coliform rule maximum contaminant level (MCL) requirements and notify EPA within 10 days after all improvements required by the plan have been completed as required in paragraph 9 of the AO.

In addition, in order to ensure that disinfected water is supplied throughout the distribution system after the modifications have been made, EPA is requiring additional chlorine residual monitoring as described below:

Once chlorination equipment has been installed and operating, take chlorine residual measurements at 3 different sampling points in the distribution system (always including T Joe's bar) once per week for 4 weeks and provide results to EPA within 10 days after the end of the fourth week. EPA will discuss these results with you and determine if any additional actions may be needed. These chlorine residual measurements are in addition to routine chlorine residual monitoring taken with quarterly bacteriological samples.

<u>Action</u>	<u>Deadline</u>	<u>Completion</u>
The chlorine feed pump will be wired to operate in unison with the lead well (Sapp Brothers #1).	July 17, 2009	
The chlorine injection point will be moved so that the chlorine is injected to water flowing into both the storage tank and to the distribution system.	July 17, 2009	

Please be advised that the Deike Estates Improvement and Service District is required to comply with all provisions of the AO. Penalties for failing to comply are set forth in the Order. Please contact Shawn McCaffrey at (303) 312-6515 if you have any questions concerning this Addendum. If you are represented by an attorney, please ask your attorney to call Peggy Livingston at the above 800 number, extension 6858, or at (303) 312-6858.

Sincerely,



Diane L. Sipe, Director
 Technical Enforcement Program
 Office of Compliance, Enforcement,
 and Environmental Justice



David Rochlin, Supervisory Attorney
 Legal Enforcement Program
 Office of Enforcement, Compliance
 and Environmental Justice

cc: Molly Hutchins, Chief Operator
 Russell Dahlgren, Dahlgren Consulting
 WY DEQ (via email)
 WY DOH (via email)
 Tina Artemis, EPA Regional Hearing Clerk