



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2008 JUN 19 10:51:21

Ref: 8ENF-W

JUN 19 2008

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Honorable Mayor Bradshaw  
Town of Lyman  
P.O. Box 300  
100 East Sage Street  
Lyman, WY 82937

Gary Hutchinson, Public Works Director  
Town of Lyman Water System  
P.O. Box 300  
Lyman, WY 82937

RE: Emergency Administrative  
Order issued under Section 1431  
SDWA to Town of Lyman  
Docket No. SDWA-08-2008-0058  
PWS ID #5600033

Dear Mayor Bradshaw and Mr. Hutchinson:

On May 21, 2008, the U.S. Environmental Protection Agency (EPA) issued an Emergency Administrative Order (Order) under section 1431 of the Safe Drinking Water Act (the Act), 40 U.S.C. § 300i, to the Town of Lyman, owner of the Town of Lyman water system (the System) which is a consecutive water system to the Bridger Valley Joint Powers Board public water system. This letter confirms the verbal notice provided to Rocky Irick, Operator of the Bridger Valley Joint Powers Board, who is coordinating response to the Orders among all four involved water systems, by Kimberly Pardue Welch of EPA on June 10, 2008 that weekly bacteriological monitoring, chlorine residual, and turbidity monitoring are no longer required at the Town of Lyman water system. This notice is based on bacteriological monitoring conducted on May 28, 2008 and June 4, 2008 which were analyzed as total coliform negative as well as chlorine residual and turbidity monitoring conducted on these same dates. Therefore pursuant to the Order, the System may resume monthly monitoring. The System is required to comply with all other provisions of the Order. Penalties for failing to comply are set forth in the Order.

We appreciate your cooperation. If you have any questions regarding this matter, please contact Kimberly Pardue Welch at (303) 312-6983. If you are represented by an attorney or have legal questions, please ask your attorney to call Amy Swanson, Enforcement Attorney, at (303) 312-6906.

Sincerely,



---

David J. Janik, Director  
Matthew Cohn, Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice



---

Diane Sipe, Director  
Technical Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice