



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2008 SEP -3 AM 8:24

EPA REGION VIII  
HEARING CLERK

SEP 3 2008

Ref: 8ENF-W

CERTIFIED MAIL-  
RETURN RECEIPT REQUESTED

William T. Bass, Forest Supervisor  
USDA Forest Service, Bighorn National Forest  
2013 Eastside 2<sup>nd</sup> Street  
Sheridan, WY 82801

Re: Administrative Order Addendum #2  
Docket No. SDWA-08-2007-0034  
PWS ID #WY5680231 – Sibley Lake  
Campground

Dear Mr. Bass:

This Addendum to the Administrative Order (AO) issued by the U.S. Environmental Protection Agency to the USDA Forest Service on March 13, 2007, approves the revised project completion schedule outlined in the July 31, 2008 email from Esther Fishbaugh of Gallatin Canyon Campgrounds on behalf of the Sibley Lake Campground public water system (PWS). In her July 31, 2008 email, Ms. Fishbaugh stated that there was a two week delay in project completion due to late snow melt at the Sibley Lake Campground. The effect of today's approval is to incorporate the new schedule into the AO, as indicated below. Please be advised that the Sibley Lake Campground is required to comply with all of the provisions of the AO. EPA commends the USDA Forest Service and Gallatin Canyon Campgrounds for installing a UV system at the Sibley Lake Campground, although this action was not yet required.

<u>Action</u>	<u>Deadline</u>	<u>Completion</u>
Submit to EPA detailed plans for bringing the PWS into compliance with maximum contaminant levels (MCL) for total coliform.	September 30, 2007	September 26, 2007
Lower the storage tank float to reduce water level in the tank below 500 gallons in an effort to decrease the likelihood of stagnant water in the tank.	June 2008	June 5, 2008
Extend the Sibley Well #2 casing so that it terminates at least 18" above the concrete slab to provide protection against surface runoff and drainage problems.	July 2008	August 31, 2008
Construct a fence surrounding the wellhead to provide protection from unauthorized intrusion. In lieu of a fence, the Forest Service will install a locking mechanism on the wellhead.	July 2008	August 31, 2008
If needed, extend the drop pipe (sucker pipe) further into the well to keep water drawdown from being too close to the pump intake.	As needed	
If Sibley Lake fails to comply with the total coliform MCLs during the 2008 season, the PWS will purchase and install a UV system.	July 2009	June 5, 2008
Issue public notice for violations included in the AO.	May 31, 2008	June 6, 2008

Please contact Shawn McCaffrey at (303) 312-6515 if you have any questions concerning this Addendum.

Sincerely,



Diane L. Sipe, Director  
Technical Enforcement Program  
Office of Enforcement, Compliance,  
and Environmental Justice



David J. Janik, Director  
Matthew Cohn, Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: Esther Fishbaugh, Gallatin Canyon Campgrounds  
Bruce Kjerstad, Civil Engineer Technician, Bighorn National Forest  
WY DEQ (via email)  
WY DOH (via email)